

# REGIONAL DISTRICT OF NANAIMO

## Water Service Area Annual Report 2016



## **Decourcey Water System**

June 2017

**REGIONAL DISTRICT OF NANAIMO**

*Water & Utility Services Department*

6300 Hammond Bay Rd, Nanaimo, BC Canada V9T 6N2 | Ph 250-390-6560 | Fax 250-390-1542



## Table of Contents

1.0	Introduction .....	1
2.0	Decourcey Water Service Area .....	1
2.1	Groundwater Wells.....	1
2.2	Reservoirs .....	1
2.3	Distribution System.....	1
3.0	Water Sampling and Testing Program .....	2
4.0	Water Quality - Source Water and Distribution System .....	2
5.0	Water Quality Inquiries and Complaints.....	3
6.0	Groundwater Production and Consumption .....	3
7.0	Maintenance Program .....	4
8.0	Operator Certification .....	4
9.0	Water Service Area Projects .....	5
9.1	2016 Completed Studies & Projects .....	5
9.2	2017 Proposed Projects & Upgrades .....	5
10.0	Emergency Response Plan .....	5
11.0	Cross Connection Control .....	6
12.0	Closing.....	6

Appendix A - Map of Decourcey Water Service Area

Appendix B - Water Quality Testing Results

Appendix C - Emergency Response Plan

**1.0 Introduction**

The following annual report describes the Decourcey Water Service Area and summarizes the water quality and production data from 2016. This report also includes a summary of inquiries and complaints, completed and proposed maintenance activities, Operator Certification, the Emergency Response Plan, and the Cross Connection Control Program.

This report is to be submitted Island Health by the Spring of 2017.

**2.0 Decourcey Water Service Area**

The Decourcey Water Service Area was established in 1998 in a rural area south of Nanaimo, and comprises two properties on Bissel Road and three properties on Pylades Drive. The water source for the Decourcey Water Service Area comes from one groundwater well located nearby. The water supply is stored in one reservoir and is chlorinated manually. A map of the Decourcey Water Service Area is provided in Appendix A for reference.

**2.1 Groundwater Wells**

One groundwater production well is present at 3284 Bissel Road, Cedar, B.C.

Well / Name	Well Depth	Wellhead Protection In-Place	Treated/Untreated with Chlorine
#1	61.0 m	Yes	Treated

**2.2 Reservoirs**

One steel above-ground reservoir is present at 3280 Bissel Road, and has a capacity of 136 m<sup>3</sup> (30,000 imperial gallons).

**2.3 Distribution System**

The water distribution system in Decourcey is composed entirely of 150mm PVC watermains (0.7 km). Four fire hydrants are located in the water service area.



**Decourcey Water Storage Reservoir**


### 3.0 Water Sampling and Testing Program

Water sampling and testing is carried out weekly in the distribution system. Notably, the chlorine residual levels are tested weekly to ensure the absence of bacterial regrowth in the watermains. The following table includes a summary of all testing:

Timing	Location	Tests
Weekly	RDN (in-house) Laboratory	Total coliforms, E.Coli Temperature, pH, Conductivity, Turbidity, Cl <sub>2</sub> Residual, Salinity, TDS Monthly- Iron and Manganese
Monthly	BC Centre for Disease Control or Maxxam	Total coliforms, E.Coli (BC CDC) Chloride, Fluoride (well water) (Maxxam)
Quarterly	Maxxam	THMs (Trihalomethanes in treated water)
Annual Source Water Testing (every Fall)	Maxxam	Complete potability testing of all raw well water, including T-Ammonia
Annual System Water Testing (every Spring)	Maxxam	Complete potability testing of distribution system, including T-Ammonia

### 4.0 Water Quality - Source Water and Distribution System

Water quality test reports are posted monthly on the RDN website at [www.rdn.bc.ca](http://www.rdn.bc.ca) in the Services section, under “Water & Utility Services”. Tables of water quality testing results for both the source water and the distribution system are provided in Appendix B of this report.



The Conductivity and Chloride levels in the Decourcey well water appear to have stabilized since 2010.

### 5.0 Water Quality Inquiries and Complaints

No complaints were received from the Decourcey water service area in 2016. Water Services staff responded to power outage alarms twice in 2016. The pump controls were reset manually by the on-call operator, and the water stored in the reservoir did not drop below 80% capacity.


Weekly monitoring of individual household water use from May to September was undertaken by Water Services staff. Direct contact with property owners was made on several occasions to advise that water conservation should be taken quite seriously in order to protect the community drinking water supply, and to maintain water storage for fire protection. A letter was mailed to all Decourcey water system users in November 2016 to advise that Stage 4 watering restrictions (the most strict level) would remain in-place until the water level in the Decourcey well rose to at least 12 meters above the pump, and stabilized for three consecutive months. This level was considered by RDN staff to represent the threshold for well recovery, and help reduce the potential for saltwater intrusion. A follow-up letter is expected to be mailed in early 2017 to advise water system users when the water level in the well has recovered.

A summary of the water system incidents in 2016 is given in the table below.

Activity in 2016	Date(s)	History/Notes
Boil Water Advisories	None	None, ever.
High Turbidity Events	None	None, ever.
Equipment Malfunction	None	None.
Water Main Breaks	None	None.
Pump Failures	None	Temp power outages.

### 6.0 Groundwater Production and Consumption

The monthly groundwater production in the Decourcey system for the past 5 years is shown in the chart below. Groundwater production in 2016 was similar to previous years, except a period of higher than normal use during March and April. This increase may be attributed to warm spring temperatures and an early start to the watering season.



In the fall/winter of 2015/2016, the average usage per home in Decourcey was 0.38 cubic metres per day (83 imperial gallons). In the summer of 2016, the average water usage was 1.24 cubic metres per day (273 imperial gallons). Based on these figures, the annual consumption per capita is estimated to be 280 L/day (based on 2.4 people/household). This consumption is **3% more** than the average of all the other RDN water systems of 271 L/day/capita in 2016.

**7.0 Maintenance Program**

A weekly pump station inspection is carried out to reduce or eliminate the risk of contamination and system failure, and to ensure the consistent application of chlorine for treatment purposes. Watermains are flushed once annually in the Spring. Fire hydrants are serviced once per year (either ‘A-level’ or ‘B-level’ maintenance) in the Fall. Twenty-four hour on-call coverage is in place to respond to water system emergencies and alarms.

**8.0 Operator Certification**

The Regional District Water & Utility Services staff are comprised of one Manager, one Project Engineer, one Engineering Technologist, one Chief Operator, and seven certified Level 2 Water Distribution System Operators. The operators receive ongoing training and certification in:

- ✓ Water Treatment
- ✓ Water Distribution
- ✓ Wastewater Collection
- ✓ Cross Connection Control
- ✓ Asbestos Awareness
- ✓ Chlorine Handling
- ✓ WHMIS (Workplace Hazardous Material Information System)
- ✓ TDG (Transportation of Dangerous Goods)
- ✓ Confined Space Awareness
- ✓ Traffic Control
- ✓ Fall Protection
- ✓ First Aid

## 9.0 Water Service Area Projects

### 9.1 2016 Completed Studies & Projects

- Pressure tank in pumphouse was replaced;
- Completed an “Existing Use Groundwater Application” to Ministry of Forests, Lands and Natural Resource Operations (FLNRO);
- Sent an information letter to owners regarding conservation and saltwater intrusion;
- Achieved two Operators’ Backflow Assembly Tester re-certification;
- Enforced the outdoor sprinkling regulations;
- Completed annual fire hydrant maintenance (‘B’ service this year);
- Carried out a comprehensive water conservation campaign (Team WaterSmart);
- Updated and improved the RDN website at [www.rdn.bc.ca](http://www.rdn.bc.ca);
- Updated the Emergency Response Plan;
- Applied a rainwater harvesting incentive (rain barrels);
- Maintained a high level of water quality;
- Continued quality control through regular testing and monitoring of water system; and,
- Completed additional educational programs.

### 9.2 2017 Proposed Projects & Upgrades

- Send an updated letter to residents regarding the well level and water conservation;
- Update the Emergency Response Plan;
- Enforce the outdoor sprinkling regulations;
- Complete annual fire hydrant maintenance;
- Continue quality control through regular testing and monitoring of water system;
- Complete additional educational program; and
- Continue to offer rainwater harvesting (rain barrel) and other water-saving incentives.

## 10.0 Emergency Response Plan

The Regional District Emergency Response Plan (ERP) contains procedures and contact information to efficiently respond to water system emergencies such as contamination of water supply, loss of supply, pump failure, and drought management. The ERP was reviewed and updated in 2016, and copies are available on our website, at each RDN office, in each pumphouse, and in each Water Services vehicle. A copy of the ERP is also attached to this report in Appendix C.

## 11.0 Cross Connection Control

In 2012, *Regional District of Nanaimo Water Use Regulation Bylaw No. 1654* was adopted which includes enhanced cross connection control and backflow protection wording. A separate Cross Connection Control bylaw was deemed not to be required.

A database of commercial customers was set-up in order to keep track of the maintenance history of testable backflow assemblies at each site. Two RDN Operators achieved their Backflow Assembly Tester re-certification in 2016. The RDN Chief Operator has been designated as the Cross Connection Control Manager.

## 12.0 Closing

An annual report for the year 2017 will be prepared and submitted to Island Health in the Spring of 2018. Annual reports are also available on our website at [www.rdn.bc.ca](http://www.rdn.bc.ca) in the SERVICES section, under Water & Utility Services then WaterSmart Communities.



Stuart Channel  
Yellow Point



**APPENDIX A**

**MAP OF DECOURCEY  
WATER SERVICE AREA**

## DECOURCEY WATER SERVICE AREA



## APPENDIX B

### WATER QUALITY TESTING RESULTS

# DECOURCEY WATER SYSTEM



## Facility Location:

Pylades Dr, Cedar

**Facility Information:** Facility Type: DWS

## Facility Sampling History:

<u>Location</u>	<u>Date</u>	<u>Total Coliform</u>	<u>E. Coli</u>
2458 Pyldades Drive, Cedar	12-Dec-2016	L1	L1
2458 Pyldades Drive, Cedar	7-Nov-2016	L1	L1
2458 Pyldades Drive, Cedar	3-Oct-2016	L1	L1
2458 Pyldades Drive, Cedar	6-Sep-2016	L1	L1
2458 Pyldades Drive, Cedar	8-Aug-2016	L1	L1
2458 Pyldades Drive, Cedar	25-Jul-2016	L1	L1
2458 Pyldades Drive, Cedar	4-Jul-2016	L1	L1
2458 Pyldades Drive, Cedar	6-Jun-2016	L1	L1
2458 Pyldades Drive, Cedar	9-May-2016	L1	L1
2458 Pyldades Drive, Cedar	11-Apr-2016	L1	L1
2458 Pyldades Drive, Cedar	21-Mar-2016	L1	L1
2458 Pyldades Drive, Cedar	7-Mar-2016	L1	L1
2458 Pyldades Drive, Cedar	1-Feb-2016	L1	L1
2458 Pyldades Drive, Cedar	4-Jan-2016	L1	L1

## Interpreting Sample Reports

In VIHA, the results of drinking water sampling are reported using the following coding system:

L1 Less than 1 (no detectable bacteria) - Meaning: No bacteria present

OG Overgrown - Meaning: Too many background bacteria to give an accurate count

EST Estimated Count

A Sample not tested; Too long in transit

C Sample leaked/broken in transit

D Sample not tested; No collection date given

T Sample submitted unsatisfactory. Exceeded 30 hours holding time, please resample.

NS No sample received with requisition



CDWG=Canadian Drinking Water Guidelines  
OG= Operational Guidance Value

MAC=Maximum Acceptable Concentration  
AO= Asthetic Objective.



Red font indicates non-compliance with Canadian Drinking Water Guidelines

	Units	CDWG		May 14 2012	May 27 2013	May 12 2014	May 19 2015	May 9 2016	
<b>Miscellaneous Inorganics</b>									
Fluoride	mg/L	1.5	MAC	0.14	<0.5	0.13	0.15	0.15	
Alkalinity (total as CaCO <sub>3</sub> )	mg/L			180	200	170	184	196	
<b>Anions</b>									
Dissolved Sulphate	mg/L	500	AO	22.1	22.8	19.9	21.5	26.3	
Dissolved Chloride	mg/L	250	AO	65	63	61	82	81	
Nitrite	mg/L	1	MAC	<0.05	<0.05	<0.05	<0.0050	<0.0050	
<b>Miscellaneous</b>									
Apparent Colour	Colour Unit			4	<5	<5	<5	5	
<b>Nutrients</b>									
Total Ammonia	mg/L			0.05	<0.01	<0.02	0.014	0.0062	
<b>Physical Properties</b>									
Conductivity	µS/cm			642	625	576	678	689	
pH	pH	6.5:8.5	AO	7.9	7.8	7.7	8.26	8.25	
TDS	mg/L	500	AO	406	362	324	364	384	
Turbidity	NTU			<0.5	<5	<0.5	0.2	0.16	
<b>Microbiological Parameters</b>									
E.coli	MPN/100mL	<1	MAC	<1.0	<1.0	<1.0	<1.0	<1.0	
Total Coliforms	MPN/100mL	<1	MAC	<1.0	<1.0	<1.0	<1.0	<1.0	
<b>Calculated Parameters</b>									
Total Hardness (CaCO <sub>3</sub> )	mg/L			42	39	35	40.9	42	
Nitrate	mg/L	10	MAC	<0.05	<0.05	<0.05	<0.020	<0.020	
<b>Elements</b>									
Total Mercury	mg/L	0.001	MAC	<0.00001	<0.00001	<0.00001	<0.00001	<0.00001	
<b>Total Metals</b>									
Total Aluminum	mg/L	0.1	OG	<0.005	<0.005	<0.025	0.0052	<0.003	
Total Antimony	mg/L	0.006	MAC	<0.0002	<0.0001	<0.0005	<0.0005	<0.0005	
Total Arsenic	mg/L	0.01	MAC	0.0006	0.00023	0.00035	0.00021	<0.00022	
Total Barium	mg/L	1	MAC	0.013	0.0138	0.0103	0.0109	0.0098	
Total Beryllium	mg/L			<0.00004	<0.00005	<0.00025	<0.0001	<0.0001	
Total Bismuth	mg/L			<0.001	<0.0001	<0.0005	<0.001	<0.001	
Total Boron	mg/L	5	MAC	0.187	0.127	0.115	0.124	0.109	
Total Cadmium	mg/L	0.005	MAC	<0.00001	<0.00001	<0.00005	<0.00001	<0.00001	
Total Chromium	mg/L	0.05	MAC	0.0006	<0.0005	<0.0025	<0.001	<0.001	
Total Cobalt	mg/L			<0.00002	<0.0001	<0.0005	<0.0005	<0.0005	
Total Copper	mg/L	1	AO	0.006	0.0087	0.0137	0.00615	0.00403	
Total Iron	mg/L	0.3	AO	0.074	0.032	0.034	0.104	0.0163	
Total Lead	mg/L	0.01	MAC	0.0002	0.0004	<0.0005	0.00048	<0.0002	
Total Manganese	mg/L	0.05	AO	<0.005	0.003	<0.0050	0.0035	<0.001	
Total Molybdenum	mg/L			<0.0001	0.00014	<0.00025	<0.001	<0.001	
Total Nickel	mg/L			<0.001	0.0002	<0.0010	<0.001	<0.001	
Total Selenium	mg/L	0.05	MAC	<0.0006	<0.0001	<0.0005	<0.0001	<0.0001	
Total Silicon	mg/L			7.47	7.71	6.74	8.22	9	
Total Silver	mg/L			<0.00001	<0.00005	<0.00025	<0.00002	<0.00002	
Total Strontium	mg/L			0.168	0.171	0.135	0.173	0.177	
Total Thallium	mg/L			<0.00001	<0.00001	<0.00005	<0.00005	<0.00005	
Total Tin	mg/L			<0.0001	0.0002	<0.0005	<0.005	<0.005	
Total Titanium	mg/L			<0.001	<0.0005	<0.0025	<0.005	<0.005	
Total Uranium	mg/L	0.02	MAC	<0.0004	0.00005	<0.00005	<0.0001	<0.0001	
Total Vanadium	mg/L			0.0003	0.0003	<0.0005	<0.005	<0.005	
Total Zinc	mg/L	5	AO	0.035	0.0383	0.0581	0.0349	0.0258	
Total Zirconium	mg/L						<0.0005	<0.0005	
Total Calcium	mg/L			13	12.2	10.9	13	12.7	
Total Magnesium	mg/L			2.28	2.14	1.85	2.08	2.49	
Total Potassium	mg/L			0.9	0.8	0.5	0.755	0.886	
Total Sodium	mg/L	200	AO	131	129	115	111	128	
Total Sulphur	mg/L						8.1	9.2	



# Regional District of Nanaimo - Water Services Department

## Decourcey Water Analysis - 2016 Monthly Report



Date	Sample Location (Address)	Health Department		In-House									
		E. coli *	Total Coliform *	E.coli *	Total Coliform *	Temp. (°C)	pH	Free Chlorine Residual (mg/L)	Total Dissolved Solids (mg/L)	Salinity (%)	Conductivity (µS/cm)	Total Iron (mg/L)	Manganese (mg/L)
5-Dec-16	2458 Pylades			0	1		7.57	0.07	336.0	0.34	688.0	0.02	0.000
12-Dec-16	2458 Pylades	0	0	0	2	5	7.52	0.02	336.0	0.34	689.0		
	<b>Average</b>	0	0	0	1.5	5.0	7.5	0.05	336.0	0.3	688.5	0.02	0.000
	<b>Maximum</b>	0	0	0	2	5	7.57	0.07	336	0.34	689	0.02	0.000
	<b>Minimum</b>	0	0	0	1	5	7.52	0.02	336	0.34	688	0.02	0.000

Red font indicates non-compliance with Canadian Drinking Water Guidelines

Aesthetic Objective for Iron is ≤0.3 mg/L

Aesthetic Objective for Manganese is ≤0.05mg/L

\*Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Yellow Column Coliform tests are completed by Health Department

Blue column tests are completed by RDN

**Comments:**

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.



# Regional District of Nanaimo - Water Services Department

## Decourcey Water Analysis - 2016 Monthly Report



Date	Sample Location (Address)	Health Department		In-House									
		E. coli *	Total Coliform *	E.coli *	Total Coliform *	Temp. (°C)	pH	Free Chlorine Residual (mg/L)	Total Dissolved Solids (mg/L)	Salinity (%)	Conductivity (µS/cm)	Total Iron (mg/L)	Manganese (mg/L)
7-Nov-16	2458 Pylades	0	0	0	0	11	7.33	0.01	342.0	0.34	702.0	0.01	0.027
14-Nov-16	2458 Pylades			0	1	12	7.42	0.03	339.0	0.34	695.0		
21-Nov-16	2458 Pylades			0	1	8	7.35	0.02	339.0	0.34	695.0		
28-Nov-16	2458 Pylades			0	1	7	7.23	0.01	335.0	0.34	679.0		
	<b>Average</b>	0	0	0	0.75	9.5	7.3	0.02	338.8	0.3	692.8	0.01	0.027
	<b>Maximum</b>	0	0	0	1	12	7.42	0.03	342	0.34	702	0.01	0.027
	<b>Minimum</b>	0	0	0	0	7	7.23	0.01	335	0.34	679	0.01	0.027

Red font indicates non-compliance with Canadian Drinking Water Guidelines

Aesthetic Objective for Iron is ≤0.3 mg/L

Aesthetic Objective for Manganese is ≤0.05mg/L

\*Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Yellow Column Coliform tests are completed by Health Department

Blue column tests are completed by RDN

**Comments:**

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.





# Regional District of Nanaimo - Water Services Department

## Decourcey Water Analysis - 2016 Monthly Report



Date	Sample Location (Address)	Health Department		In-House									
		E. coli *	Total Coliform *	E.coli *	Total Coliform *	Temp. (°C)	pH	Free Chlorine Residual (mg/L)	Total Dissolved Solids (mg/L)	Salinity (%)	Conductivity (µS/cm)	Total Iron (mg/L)	Manganese (mg/L)
3-Oct-16	2458 Pylades	0	0	0	0	12	7.52	0.03	348.0	0.35	712.0	0.01	0.008
11-Oct-16	2458 Pylades			0	0	11	7.47	0.03	343.0	0.34	704.0		
17-Oct-16	2458 Pylades			0	0	10	7.54	0.02	351.0	0.35	720.0		
24-Oct-16	2458 Pylades			0	0	10	7.48	0.00	342.0	0.34	702.0		
	<b>Average</b>	0	0	0	0	10.8	7.5	0.02	346.0	0.3	709.5	0.01	0.008
	<b>Maximum</b>	0	0	0	0	12	7.54	0.03	351	0.35	720	0.01	0.008
	<b>Minimum</b>	0	0	0	0	10	7.47	0	342	0.34	702	0.01	0.008

Red font indicates non-compliance with Canadian Drinking Water Guidelines

Aesthetic Objective for Iron is ≤0.3 mg/L

Aesthetic Objective for Manganese is ≤0.05mg/L

\*Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Yellow Column Coliform tests are completed by Health Department

Blue column tests are completed by RDN

**Comments:**

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.



# Regional District of Nanaimo - Water Services Department

## Decourcey Water Analysis - 2016 Monthly Report



Date	Sample Location (Address)	Health Department		In-House									
		E. coli *	Total Coliform *	E.coli *	Total Coliform *	Temp. (°C)	pH	Free Chlorine Residual (mg/L)	Total Dissolved Solids (mg/L)	Salinity (%)	Conductivity (µS/cm)	Total Iron (mg/L)	Manganese (mg/L)
6-Sep-16	2458 Pylades	0	0	0	0	17	7.62	0.04	354.0	0.35	725.0	0.02	0.001
13-Sep-16	2458 Pylades			0	8	17	7.52	0.00	364.0	0.36	746.0		
19-Sep-16	2458 Pylades			0	1	16	7.51	0.01	349.0	0.35	714.0		
26-Sep-16	2458 Pylades			0	1	13	7.56	0.02	351.0	0.35	720.0		
	<b>Average</b>	0	0	0	2.5	15.8	7.6	0.02	354.5	0.4	726.3	0.02	0.001
	<b>Maximum</b>	0	0	0	8	17	7.62	0.04	364	0.36	746	0.02	0.001
	<b>Minimum</b>	0	0	0	0	13	7.51	0.00	349	0.35	714	0.02	0.001

Red font indicates non-compliance with Canadian Drinking Water Guidelines

Aesthetic Objective for Iron is ≤0.3 mg/L

Aesthetic Objective for Manganese is ≤0.05mg/L

\*Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Yellow Column Coliform tests are completed by Health Department

Blue column tests are completed by RDN

**Comments:**

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.



# Regional District of Nanaimo - Water Services Department

## Decourcey Water Analysis - 2016 Monthly Report



Date	Sample Location (Address)	Health Department		In-House									
		E. coli *	Total Coliform *	E.coli *	Total Coliform *	Temp. (°C)	pH	Free Chlorine Residual (mg/L)	Total Dissolved Solids (mg/L)	Salinity (%)	Conductivity (µS/cm)	Total Iron (mg/L)	Manganese (mg/L)
2-Aug-16	2458 Pylades			0	0	17	7.48	0.01	357.0	0.36	730.0	0.01	0.027
8-Aug-16	2458 Pylades	0	0	0	0	18	7.39	0.02	376.0	0.38	769.0		
15-Aug-16	2458 Pylades			0	0	19	7.45	0.02	369.0	0.37	755.0		
22-Aug-16	2458 Pylades			0	31	19	7.45	0.04	356.0	0.36	733.0		
29-Aug-16	2458 Pylades			0	22	19	7.65	0.02	351.0	0.35	723.0		
<b>Average</b>		0	0	0	10.6	18.4	7.5	0.02	361.8	0.4	742.0	0.01	0.027
<b>Maximum</b>		0	0	0	31	19	7.65	0.04	376	0.38	769	0.01	0.027
<b>Minimum</b>		0	0	0	0	17	7.39	0.01	351	0.35	723	0.01	0.027

Red font indicates non-compliance with Canadian Drinking Water Guidelines

Aesthetic Objective for Iron is ≤0.3 mg/L

Aesthetic Objective for Manganese is ≤0.05mg/L

\*Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Yellow Column Coliform tests are completed by Health Department

Blue column tests are completed by RDN

**Comments:**

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.



# Regional District of Nanaimo - Water Services Department

## Decourcey Water Analysis - 2016 Monthly Report



Date	Sample Location (Address)	Health Department		In-House									
		E. coli *	Total Coliform *	E.coli *	Total Coliform *	Temp. (°C)	pH	Free Chlorine Residual (mg/L)	Total Dissolved Solids (mg/L)	Salinity (%)	Conductivity (µS/cm)	Total Iron (mg/L)	Manganese (mg/L)
4-Jul-16	2458 Pylades	0	0	0	0	15	7.33	0.06	364.0	0.36	747.0	0.01	0.011
11-Jul-16	2458 Pylades			0	0	15	7.38	0.08	367.0	0.37	752.0		
18-Jul-16	2458 Pylades			0	0		7.32	0.03	367.0	0.37	750.0		
25-Jul-16	2458 Pylades			0	0		7.43	0.01	373.0	0.37	764.0		
	<b>Average</b>	0	0	0	0	15.0	7.4	0.05	367.8	0.4	753.3	0.01	0.011
	<b>Maximum</b>	0	0	0	0	15	7.43	0.08	373	0.37	764	0.01	0.011
	<b>Minimum</b>	0	0	0	0	15	7.32	0.01	364	0.36	747	0.01	0.011

Red font indicates non-compliance with Canadian Drinking Water Guidelines

Aesthetic Objective for Iron is ≤0.3 mg/L

Aesthetic Objective for Manganese is ≤0.05mg/L

\*Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Yellow Column Coliform tests are completed by Health Department

Blue column tests are completed by RDN

**Comments:**

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.



# Regional District of Nanaimo - Water Services Department

## Decourcey Water Analysis - 2016 Monthly Report



Date	Sample Location (Address)	Health Department		In-House									
		E. coli *	Total Coliform *	E.coli *	Total Coliform *	Temp. (°C)	pH	Free Chlorine Residual (mg/L)	Total Dissolved Solids (mg/L)	Salinity (%)	Conductivity (µS/cm)	Total Iron (mg/L)	Manganese (mg/L)
6-Jun-16	2458 Pylades	0	0	0	0	14	7.76	0.04	374.0	0.37	764.0	0.01	0.022
13-Jun-16	2458 Pylades			0	0	14	7.43	0.02	366.0	0.37	750.0		
21-Jun-16	2458 Pylades			0	0		7.39	0.03	357.0	0.36	728.0		
27-Jun-16	2484 Pylades			0	0		7.41	0.04	362.0	0.36	740.0		
	<b>Average</b>	0	0	0	0	14.0	7.5	0.03	364.8	0.4	745.5	0.01	0.022
	<b>Maximum</b>	0	0	0	0	14	7.76	0.04	374	0.37	764	0.01	0.022
	<b>Minimum</b>	0	0	0	0	14	7.39	0.02	357	0.36	728	0.01	0.022

Red font indicates non-compliance with Canadian Drinking Water Guidelines

Aesthetic Objective for Iron is ≤0.3 mg/L

Aesthetic Objective for Manganese is ≤0.05mg/L

\*Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Yellow Column Coliform tests are completed by Health Department

Blue column tests are completed by RDN

**Comments:**

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.



# Regional District of Nanaimo - Water Services Department

## Decourcey Water Analysis - 2016 Monthly Report



Date	Sample Location (Address)	Health Department		In-House									
		E. coli *	Total Coliform *	E.coli *	Total Coliform *	Temp. (°C)	pH	Free Chlorine Residual (mg/L)	Total Dissolved Solids (mg/L)	Salinity (%)	Conductivity (µS/cm)	Total Iron (mg/L)	Manganese (mg/L)
2-May-16	2485 Pylades			0	0	14	7.46	0.02	353.0	0.35	723.0		
9-May-16	2458 Pylades	0	0	0	0	12	7.45	0.05	343.0	0.34	702.0	0.02	0.008
16-May-16	2458 Pylades			0	0	13	7.55	0.00	356.0	0.36	723.0		
24-May-16	2458 Pylades			0	0	14	7.52	0.02	366.0	0.36	749.0		
30-May-16	2458 Pylades			0	0	13.5	7.54	0.02	371.0	0.37	758.0		
	<b>Average</b>	0	0	0	0	13.3	7.5	0.02	357.8	0.4	731.0	0.02	0.008
	<b>Maximum</b>	0	0	0	0	14	7.55	0.05	371	0.37	758	0.02	0.008
	<b>Minimum</b>	0	0	0	0	12	7.45	0	343	0.34	702	0.02	0.008

Red font indicates non-compliance with Canadian Drinking Water Guidelines

Aesthetic Objective for Iron is ≤0.3 mg/L

Aesthetic Objective for Manganese is ≤0.05mg/L

\*Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Yellow Column Coliform tests are completed by Health Department

Blue column tests are completed by RDN

**Comments:**

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.



# Regional District of Nanaimo - Water Services Department

## Decourcey Water Analysis - 2016 Monthly Report



Date	Sample Location (Address)	Health Department		In-House									
		E. coli *	Total Coliform *	E.coli *	Total Coliform *	Temp. (°C)	pH	Free Chlorine Residual (mg/L)	Total Dissolved Solids (mg/L)	Salinity (%)	Conductivity (µS/cm)	Total Iron (mg/L)	Manganese (mg/L)
11-Apr-16	2458 Pylades	0	0	0	0	9	7.36	0.02	294.0	0.29	604.0	0.01	0.006
18-Apr-16	2458 Pylades			0	0	10	7.49	0.02	320.0	0.32	656.0		
25-Apr-16	2458 Pylades			0	0		7.54	0.03	324.0	0.32	663.0		
	<b>Average</b>	0	0	0	0	9.5	7.5	0.02	312.7	0.3	641.0	0.01	0.006
	<b>Maximum</b>	0	0	0	0	10	7.54	0.03	324	0.32	663	0.01	0.006
	<b>Minimum</b>	0	0	0	0	9	7.36	0.02	294	0.29	604	0.01	0.006

**Red font indicates non-compliance with Canadian Drinking Water Guidelines**

Aesthetic Objective for Iron is ≤0.3 mg/L      Aesthetic Objective for Manganese is ≤0.05mg/L

\*Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Yellow Column Coliform tests are completed by Health Department

Blue column tests are completed by RDN

**Comments:**

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.



# Regional District of Nanaimo - Water Services Department

## Decourcey Water Analysis - 2016 Monthly Report



Date	Sample Location (Address)	Health Department		In-House									
		E. coli *	Total Coliform *	E.coli *	Total Coliform *	Temp. (°C)	pH	Free Chlorine Residual (mg/L)	Total Dissolved Solids (mg/L)	Salinity (%)	Conductivity (µS/cm)	Total Iron (mg/L)	Manganese (mg/L)
7-Mar-16	2458 Pylades	0	0	0	0	8	7.50	0.01	321.0	0.32	658.0	0.03	0.024
14-Mar-16	2458 Pylades			0	0	8	7.49	0.01	308.0	0.31	636.0		
21-Mar-16	2458 Pylades	0	0	0	0	7	7.64	0.02	326.0	0.32	672.0		
29-Mar-16	2458 Pylades			0	0	9	7.32	0.03	273.0	0.27	566.0		
	<b>Average</b>	0	0	0	0	8.0	7.5	0.02	307.0	0.3	633.0	0.03	0.024
	<b>Maximum</b>	0	0	0	0	9	7.64	0.03	326	0.32	672	0.03	0.024
	<b>Minimum</b>	0	0	0	0	7	7.32	0.01	273	0.27	566	0.03	0.024

**Red font indicates non-compliance with Canadian Drinking Water Guidelines**

Aesthetic Objective for Iron is ≤0.3 mg/L      Aesthetic Objective for Manganese is ≤0.05mg/L

\*Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Yellow Column Coliform tests are completed by Health Department

Blue column tests are completed by RDN

**Comments:**

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.





# Regional District of Nanaimo - Water Services Department

## Decourcey Water Analysis - 2016 Monthly Report



Date	Sample Location (Address)	Health Department		In-House									
		E. coli *	Total Coliform *	E.coli *	Total Coliform *	Temp. (°C)	pH	Free Chlorine Residual (mg/L)	Total Dissolved Solids (mg/L)	Salinity (%)	Conductivity (µS/cm)	Total Iron (mg/L)	Manganese (mg/L)
1-Feb-16	2458 Pylades	0	0	0	0	9	7.37	0.02	315.0	0.32	653.0	0.04	0.008
9-Feb-16	2458 Pylades			0	0	8	7.57	0.02	318.0	0.32	652.0		
15-Feb-16	2485 Pylades			0	0	6	7.34	0.00	324.0	0.33	658.0		
22-Feb-16	2458 Pylades			0	0	7	7.76	0.02	319.0	0.32	656.0		
	<b>Average</b>	0	0	0	0	7.5	7.5	0.02	319.0	0.3	654.8	0.04	0.008
	<b>Maximum</b>	0	0	0	0	9	7.76	0.02	324	0.33	658	0.04	0.008
	<b>Minimum</b>	0	0	0	0	6	7.34	0	315	0.32	652	0.04	0.008

**Red font indicates non-compliance with Canadian Drinking Water Guidelines**

Aesthetic Objective for Iron is ≤0.3 mg/L

Aesthetic Objective for Manganese is ≤0.05mg/L

\*Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Yellow Column Coliform tests are completed by Health Department

Blue column tests are completed by RDN

**Comments:**

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.



# Regional District of Nanaimo - Water Services Department

## Decourcey Water Analysis - 2016 Monthly Report



Date	Sample Location (Address)	Health Department		In-House									
		E. coli *	Total Coliform *	E.coli *	Total Coliform *	Temp. (°C)	pH	Free Chlorine Residual (mg/L)	Total Dissolved Solids (mg/L)	Salinity (%)	Conductivity (µS/cm)	Total Iron (mg/L)	Manganese (mg/L)
4-Jan-16	2458 Pylades	0	0	0	0	7	7.60	0.00	282.0	0.28	581.0	0.02	0.009
11-Jan-16	2458 Pylades			0	0	4	7.34	0.01	351.0	0.35	720.0		
18-Jan-16	2458 Pylades			0	0	6	7.22	0.02	325.0	0.33	666.0		
25-Jan-16	2458 Pylades			0	0	6	7.36	0.00	326.0	0.33	669.0		
	<b>Average</b>	0	0	0	0	5.8	7.4	0.01	321.0	0.3	659.0	0.02	0.009
	<b>Maximum</b>	0	0	0	0	7	7.6	0.02	351	0.35	720	0.02	0.009
	<b>Minimum</b>	0	0	0	0	4	7.22	0	282	0.28	581	0.02	0.009

Red font indicates non-compliance with Canadian Drinking Water Guidelines

Aesthetic Objective for Iron is ≤0.3 mg/L

Aesthetic Objective for Manganese is ≤0.05mg/L

\*Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Yellow Column Coliform tests are completed by Health Department

Blue column tests are completed by RDN

**Comments:**



Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.



## Decourcey Monthly Well Testing

## Chloride (mg/L)

Month	Year													
	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016
Jan	6.4	31.0	6.5	38.4	53.1	58.5	7.4	7.4	7.4	46.4	56.0	8.7	6.1	
Feb	16.06	27.8	7.2	42.0	8.1	9.9	7.2	6.9	6.9	61.0	56.0	7.7	5.4	
Mar	20.71	31.5	6.0	9.5	6.6	37.5	53.5	13.5	13.5	8.1	8.8	41.3	56	
Apr	6.06	31.8	16.3	5.8	7.9	9.6	62.5	71.3	71.3	11.6	51.0	71.0	73	
May	36.4	31.7	29.4	21.1	39.9	<2.0	85.4	95.1	95.1	75.0	73.0	81.0	89	
Jun	27.8	26.8	28.1	38.5	39.4	10.6	91.8	108.0	108.0	104.0	90.0	63.0	78	
Jul	16.7	60	15.4	15.7	29.7	12.7	169.0	108.0	108.0	91.0	76.0	83.0	80	
Aug	40.7	33.0	12.6	32.4	32.4	13.4	92.6	92.7	92.7	75.0	79.0	79.1	19	
Sep	26.4	7	14.9	13.0	24.6	68.4	84.1	84.4	84.4	72.0	75.0	71.6	75	
Oct	22.9	44.8	55.1	19.6	36	36	83.8	81.9	81.9	82	89	74	75	
Nov	35.4	41.7	39.6	22.5	15.0	5.3	20.2	91.5	91.5	78.0	85	81.9	78	
Dec	8.2	37	7.4	50	56.3	7.7	10.1	8.7	97.8	20.7	85	13.7	18	
<b>Avg</b>	<b>23.39</b>	<b>30.17</b>	<b>22.76</b>	<b>24.36</b>	<b>28.16</b>	<b>23.85</b>	<b>58.81</b>	<b>56.50</b>	<b>71.54</b>	<b>60.40</b>	<b>67.16</b>	<b>60.66</b>	<b>59.14</b>	<b>39.59</b>









## Decourcey Monthly Well Testing

## Fluoride (mg/L)

Month	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016
Jan		0.11	0.2	<1.0	0.2	0.2	0.20	0.1	0.12	0.13	0.14			0.051
Feb	0.16	0.21	0.1	<1.0	0.1	0.1	0.20	0.1	0.11	0.12	0.13	0.07	0.12	0.068
Mar	0.15	0.17	0.2	<1.0	0.1	0.2	0.11	0.2	0.17	0.10	0.09	0.13	0.11	0.12
Apr	0.12	0.2	<1.0	<.1	0.2	0.2	0.20	0.2	0.20	0.11	0.13	0.16	0.14	0.13
May	0.17	0.21	<0.1	0.2	0.2	0.2	0.20	<1.0	0.17	0.14	0.15	0.13	0.16	0.16
Jun	0.6	0.23	<1.0	0.2	0.2	0.3	0.18	0.2	0.13	0.13	0.17	0.20	0.17	0.18
Jul	0.2	0.26	<1.0	0.3	<0.1	0.3	0.13	0.2	0.15	0.15	0.19	0.17	0.15	0.19
Aug	0.3		<0.1	0.3	0.3	0.3			0.16	0.17	0.20	<0.05	0.022	0.26
Sep	0.3	0.17	<0.1	0.3	0.3	0.2	0.20		<0.10	0.20	0.18	0.71	0.16	0.27
Oct	0.27		<1.0	0.3	<1.0	<1.0	<1.0	<1.0	<1	0.20	0.16	0.24	0.18	0.2
Nov	0.22	0.2	<1.0	<1.0	0.1	<0.1	<0.1		0.16	0.16		<0.05	0.13	0.049
Dec	0.09	0.17	<1.0	0.2	0.2	0.1	0.10	<1.0	0.15	0.12	0.14	0.09	0.08	0.073
<b>Avg</b>	<b>0.22</b>	<b>0.19</b>	<b>0.17</b>	<b>0.26</b>	<b>0.2</b>	<b>0.2</b>	<b>0.2</b>	<b>0.15</b>	<b>0.15</b>	<b>0.12</b>	<b>0.15</b>	<b>0.21</b>	<b>0.13</b>	<b>0.15</b>



Month	Year										
	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016
Jan											
Feb											
Mar		0.127	0.064	0.096	0.076	0.079	0.120	0.345	0.146	0.048	0.1388
Apr					0.087						
May	0.123										
Jun		0.118	0.090	0.026	0.072	0.096	0.058	0.027	0.054	0.019	0.0073
Jul	0.101										
Aug											
Sep	0.074	0.105	0.014	0.008		0.005	0.030	0.024	0.025	0.017	0.0063
Oct					0.057						
Nov											
Dec	0.114	0.119	0.069	0.035	0.036	0.046	0.070	0.044	0.046	0.0732	0.0218
<b>Avg</b>	<b>0.103</b>	<b>0.117</b>	<b>0.059</b>	<b>0.041</b>	<b>0.066</b>	<b>0.060</b>	<b>0.070</b>	<b>0.110</b>	<b>0.068</b>	<b>0.039</b>	<b>0.0436</b>



2006	Chloroform (mg/L)	Chlorodibromomethane (mg/L)	Bromodichloromethane (mg/L)	Bromoform (mg/L)	Total THM (mg/L)
May	0.018	0.045	0.027	0.033	0.123
July	0.006	0.035	0.013	0.047	0.101
Sept	0.001	0.006	0.002	0.065	0.074
Dec	0.004	0.027	0.007	0.076	0.114
<b>2007</b>					
M	0.016	0.045	0.023	0.043	0.127
J	0.012	0.044	0.019	0.043	0.118
S	0.002	0.011	0.003	0.089	0.105
D	0.003	0.009	0.003	0.104	0.119
<b>2008</b>					
M	0.005	0.005	0.002	0.052	0.064
J	0.003	0.017	0.004	0.066	0.09
S	<0.001	0.002	<0.001	0.012	0.014
D	0.002	0.003	0.002	0.062	0.069
<b>2009</b>					
M	0.003	0.004	0.002	0.087	0.096
J	0.002	0.002	<0.001	0.022	0.026
S	<0.001	0.001	<0.001	0.007	0.008
D	<0.001	0.002	<0.001	0.033	0.035
<b>2010</b>					
M	0.002	0.002	0.002	0.07	0.076
J	<0.001	0.004	0.001	0.067	0.072
S					0.057
D	<0.001	0.003	<0.001	0.033	0.036
<b>2011</b>					
M	0.003	0.005	0.001	0.07	0.079
J	0.095	<0.001	0.001	<0.001	0.096
S	<0.001	<0.001	<0.001	0.005	0.005
D	0.001	0.004	<0.001	0.041	0.046
<b>2012</b>					
M	0.002	0.005	<0.001	0.113	0.12
J	<0.001	0.004	<0.001	0.054	0.058
S	<0.001	0.004	<0.001	0.026	0.03
D	0.002	0.004	0.002	0.062	0.07
<b>2013</b>					
M	0.002	0.011	0.002	0.33	0.345
J	<0.001	0.002	<0.001	0.025	0.027
S	<0.001	0.004	<0.001	0.02	0.024
D	<0.001	0.003	<0.001	0.041	0.044
<b>2014</b>					
M	<0.001	0.004	0.001	0.141	0.146
J	0.001	0.005	<0.001	0.048	0.054
S	<0.001	<0.001	<0.001	0.025	0.025
D	0.001	0.003	<0.001	0.042	0.046
<b>2015</b>					
M	0.003	0.0046	0.0019	0.038	0.048
J	<0.001	0.002	<0.001	0.017	0.019
S	<0.001	0.0025	<0.001	0.014	0.017
D	0.0013	0.0054	0.0015	0.065	0.0732
<b>2016</b>					
M	0.0039	0.012	0.0029	0.12	0.139
J	<0.001	0.001	<0.001	0.0063	0.0073
S	<0.001	0.0021	<0.001	0.0042	0.0063
D	0.002	0.0043	0.0015	0.014	0.0218

**APPENDIX C**

**EMERGENCY RESPONSE PLAN**

# EMERGENCY RESPONSE PLAN

REGIONAL DISTRICT  
OF NANAIMO

**WATER SYSTEMS**





This page is intentionally blank.

## Contents

<b>Prime Responsibilities</b>	1
<b>Emergency Response and Recovery Actions</b>	1
<b>Communication Checklist</b>	2
- RDN Priority Contacts	2
- Key Communication Options	2
<b>Emergency Contact Numbers</b>	3-7
<b>Emergency Response Plans</b>	8
- Contamination of Source (incl. Turbidity events)	8
- Loss of Source	8
- Broken Water Main	9
- Chlorination Failure	9
- Pump Failure	9
- Power Failure	10
- Backflow or Back Siphonage	10
- Bacteria Count (RDN Lab)	10
- Flood Conditions	11
- Drought Management Plan	11
<b>Appendices</b>	
- Boil Water Notice	13
- Boil Water Info for the General Public	14-26
- Boil Water Order	27
- Unfit for Drinking Notice	28
- Service Interruption Notice	29
- Decision Tree for Responding to Turbidity Event	30
<b>Maps-Water Service Areas</b>	
- Nanoose Bay Peninsula	Map 1
- Madrona Pt/Wall Beach Neighbourhood	Map 2
- Fairwinds Neighbourhood	Map 3
- Arbutus Park Neighbourhood	Map 4
- West Bay Neighbourhood	Map 5
- Driftwood Neighbourhood	Map 6
- French Creek	Map 7
- Surfside	Map 8
- San Pareil	Map 9
- Englishman River	Map 10
- Melrose	Map 11
- Decourcey	Map 12
- Whiskey Creek	Map 13
- Descanso Bay Reg. Park	Map 14
- Horne Lake Reg. Park Water System	Map 15
- Rollo McClay Community Park Water System	Map 16
- Westurne Heights Water System	Map 17

## Prime Responsibilities

- Provide safe drinking water.
- Provide potable water for sanitation purposes.
- Provide water for fire suppression.
- Prevent unnecessary loss of stored water.
- Restore the integrity of the entire water system as soon as possible.
- Maintain integrity and quality of supply.

## Emergency Response and Recovery Actions

- Analyze the type and severity of the emergency.
- Provide emergency assistance to save lives.
- Reduce the probabilities of additional injuries or damage.
- Provide situational reporting to appropriate agencies as required.
- Perform emergency repairs based on priority demand.
- Return system to normal levels. (recovery)
- Evaluate response and preparedness plan.
- Revise plan as necessary.
- Provide maps, notices, and direction necessary for water recovery.

## Communication Checklist

In an emergency it will be important to contact the key people shown below. This will help reduce confusion and assist in ensuring any important messaging is done so correctly and quickly.

IF REQUIRED, CONTACT EMBC or Island Health BEFORE  
MAKING THE FOLLOWING CONTACTS AS PER THE EMERGENCY PLANS

## RDN Priority Contacts

MANAGER OF WATER SERVICES	CHRIS MIDGLEY (250) 729-5173
WATER SERVICES PROJECT ENGINEER	GERALD ST. PIERRE (250) 713-6957
MGR. REGIONAL & COMMUNITY UTILITIES	RANDY ALEXANDER (250) 729-5073
COMMUNICATIONS COORDINATOR	CHRISTINA GRAY (250) 390-4111
EMERGENCY COORDINATOR (or alternate)	ERICA BEAUCHAMP (250) 668-2167

## Key Communication Options

### Management Support

- Contact Electoral Area Director
- Contact the local radio station and provide a brief message if public health and safety are at risk. Follow up with a press release.

### Field Staff Support

- Post notices on household front doors.
- Attach warning signs to existing Watering Restriction signs in each community.
- Put up roadside signage at the entrance to the community.

### Administrative Support

- Provide information message on the RDN web site & social media.
- Review after hours office and voice mail messaging.
- Provide notification to other RDN staff.

## Emergency Contact Numbers

### Personnel Contacts

<i>Name</i>	<i>Position</i>	<i>Phone / Cell</i>
Dave Welz	Chief Operator	(250) 927-0295
Heather Dorken	Utilities Technician III	(250) 927-1452
Brian Hale	Utilities Technician III	(250) 951-8354
Randy Stearman	Utilities Technician II	(250) 927-1178
Brad Lancaster	Utilities Technician II	(250) 927-1849
Lyndon Jaworski	Utilities Technician II	(250) 954-8351
Greg Roberts	Utilities Technician II	(250) 927-1902
Shane Phillips	Utilities Technician II	(250) 927-4318
Chris Midgley	Manager of Water Services	(250) 729-5173
Gerald St. Pierre	Project Engineer, Water Services	(250) 713-6957
Deb Churko	Engineering Technologist	(250) 619-8851
Jack Eubank	Bylaw Officer <i>(Emerg. Coord. Alternate- 24hrs)</i>	(250) 713-4872
Brian Brack	Bylaw Officer <i>(Emerg. Coord. Alternate- 24hrs)</i>	(250) 714-3987

## Electoral Area Directors

Electoral Area	Director	Phone	E-mail Address
A	Alec McPherson	250-722-9472	alecmcpherson@shaw.ca
B	Howard Houle	250-247-8250	howard.houle@rdn.bc.ca
C	Maureen Young	250-754-5896	maureen_young@shaw.ca
E	Bob Rogers	250-468-9986	bob.rogers@rdn.bc.ca
F	Julian Fell	250-248-4296	fjfell.at.rdn@gmail.com
G	Joe Stanhope	250-248-6401	jstanhope@shaw.ca
H (Chair)	Bill Veenhof	778-424-2810	bill.veenhof@shaw.ca

## Government Agency Contacts

Ministry of Environment	Nanaimo	(250) 751-3100
Department of Fisheries and Oceans	Nanaimo	(250) 754-0230
Emergency Management BC (EMBC) and Dangerous Goods Spills (formerly PEP)	Victoria	1-800-663-3456
Island Health (Environmental Health Officer)	Parksville	(250) 947-8222
<ul style="list-style-type: none"> <li>Bill Wrathall- French Creek and San Pareil Water Systems</li> <li>Elizabeth Thomson- Surfside, Melrose, Whiskey Creek, Westurne Heights, and Horne Lake Water Systems</li> </ul>		
Island Health (Environmental Health Officer)	Nanaimo	(250) 755-6215
<ul style="list-style-type: none"> <li>Tim Bilyk- Decourcey Water System</li> <li>Anthony Griffin- Englishman River Community Water System and Nanoose Bay Peninsula Water System</li> <li>Jill Lucko- Descanso Bay and Rollo McClay Water Systems</li> <li>Murray Sexton, Public Health Engineer</li> <li>Dr. Paul Hasselback, Medical Health Officer</li> </ul>		(250) 755-6293 (250) 739-6304 or after hours 1-800-204-6166
City of Parksville		(250) 248-5412
<ul style="list-style-type: none"> <li>Chief Operator, Scott Churko</li> </ul>		(250) 927-1856 (cell)
Town of Qualicum Beach		(250) 752-6921
<ul style="list-style-type: none"> <li>Foreman, Cam Purdon</li> </ul>		(250) 927-1144 (cell)
District of Lantzville		(250) 390-4006
<ul style="list-style-type: none"> <li>Superintendent, Fred Spears</li> </ul>		(250) 713-0980 (cell)
North Cedar Improvement District		(250) 722-3711

## Government Agency Contacts Cont'd

Islands Trust Organization (Main office)	Gabriola Isl	(250) 247-2063
<ul style="list-style-type: none"> <li>Trustee Melanie Mamoser</li> <li>Trustee Heather O'Sullivan</li> </ul>	Gabriola Isl	(250) 247-2008
	Gabriola Isl	(250) 247-9574

## Emergency Services

Hospital	Nanaimo	(250) 754-2141
	Parksville ph.	(250) 248-2332 (Nan hospital)
	Oceanside Ctr	(250) 951-9550
	Gabriola Clinic	(250) 247-9922
Ambulance	Nanaimo	911 or (250) 758-8181
	Parksville	911 or (250) 248-3511
Police	Nanaimo	911 or (250) 754-2345
	Parksville	911 or (250) 248-6111
	Gabriola Isl	911 or (250) 247-8333
Fire Department	Parksville	911 or (250) 248-3242
	Coombs-Hilliers	911 or (250) 752-2144
	Nanoose Bay	911 or (250) 468-7141
	Qualicum Beach	911 or (250) 752-6921
	Cedar	911 or (250) 722-3122
	Gabriola Isl	911 or (250) 247-5601

## Priority Services

BC Hydro (Qualicum Beach number)	(250) 752-8012 or
BC Hydro (Power Outages & Electrical Emergencies)	1-888-769-3766
Telus	(250) 811-2323 or
<ul style="list-style-type: none"> <li>Paul McGrath cell 248-0983</li> </ul>	(250) 741-7713 or 741-7716
FortisBC (Teresen Gas)	(250) 248-4880
Shaw Cable (Nanaimo)	(250) 754-5571
CP Rail	1-800-716-9132
French Creek Pollution Control Centre	(250) 248-5794
Chlorine Manufacturer (Brentagg)	1-800-661-1830

## Community Contacts

District 69 School Board Office	(250) 248-4241
Nanoose Bay School	(250) 468-7414
Nanoose Children's Centre	(250) 468-1784
Nanoose Place	(250) 468-5339
Nanoose Post Office	(250) 468-7722
Canadian Forces Base Nanoose	(250) 756-5021 or 468-5004
	or (250) 468-2260 (MP Stn-24hr)
Descanso Bay Reg Park Operator(1)- Calvin Nguyen	(250) 713-4571
Descanso Bay Reg Park Operator(2)- Jessica Sedlock	(778) 806-0897
Horne Lake Reg Park Operator- Bill Woodhouse	(250) 927-4790

## Excavation Services

Shoreline Equipment (Doug Penny)	(250) 468-7759 or 755-9502
Rite on Time Excavation & Trucking (Cody)	(250) 927-1645
Degnen Excavators (Gabriola Isl)	(250) 247-8817

## Electrical Contractors

Canem Electric	(250) 468-1887
HPS Power Ltd. (Harvey Sommerfeld)	(250) 954-7463
TC Trades (Tom Frenette)	(250) 756-0077 or 668-0078
Ron Ruckman (Descanso Bay/Gabriola Isl)	(250) 247-0050

## Other Services

Plumbing Services (Maci Motor - Pump Repair)	(250) 248-4423
JC Plumbing (Descanso Bay/Gabriola Isl)	(250) 247-7574 or 713-6700
EPCOR (Parksville)	(250) 951-2460
Sand and Gravel (Ozero)	(250) 752-1482
Sand and Gravel (Lussier & Sons)	(250) 468-9994
Sand and Gravel (DBL)	(250) 248-3693
EMCON Road Maintenance (Gabriola Isl)	(250) 247-9420
EMCON (Parksville) After Hours Emerg 1-866-353-3136 or	(250) 248-6212
EMCON (Nanaimo/Cedar)	(250) 722-9494



## Other Services

Pump Truck (Action Tank Service)	(250) 248-3833
Pump Truck (Coast Environmental)	(250) 390-5080
Pump Truck and Toilet Rentals (A-1 Septic)	(250) 248-4438
Portable Washrooms (Coast Toilet Rentals)	(250) 753-7552
Bulk water supply (BC Water Service)	(250) 954-3628
Running Water Enterprises (Red Williams)	(250) 947-5197
Bottled water supply (Water Pure & Simple)	(250) 752-1373
Island H2O Services	(250) 754-4721
Summer Rain Water Delivery (Gabriola Isl)	(250) 247-9136
Kalicum Drilling	(250) 245-1220
RDN- Use our own water hauling tank and truck	(250) 248-4914

## Suppliers

Four Star Waterworks (piping)	(250) 954-3546
EMCO Water Works	(250) 756-3344
Corix Water Products	(250) 746-8877
Andrew Sheret (Parksville)	(250) 954-9997
Andrew Sheret (Nanaimo)	(250) 758-7383
Hwy Four Rentals (equipment & pumps)	(250) 248-1100
Irritex Pumps and Irrigation – (pumps)	(250) 248-7028
Windsor Plywood (miscellaneous building supplies)	(250) 752-3122
Albertsons Hardware (miscellaneous building supplies)	(250) 248-6888
Robinson Rentals	(250) 753-2465
United Rentals	(250) 758-3911

## Media Services

Christina Gray, RDN Communications Coordinator	1-877-607-4111 or 713-1075
Radio Station (CKWV) Nanaimo and Parksville	(250) 758-1131
TV Station (CHEK)	(250) 383-2435
Newspaper (PQ News and The Weekender)	(250) 248-4341
Gabriola Sounder	(250) 247-9337

## Emergency Response Plans

### Contamination of Source (Turbidity Events over 1 NTU, Spills, Accidents, Vandalism)

Actions:

- Notify Environmental Health Officer Ph. 250-947-8222 (or after-hours Medical Health Officer at 1-800-204-6166)
- Shut down pump
- Notify EMBC (Emergency Management BC)
- Notify all users if necessary under direction of Health Unit
- Contact government agencies for advice and assistance
- Contact local media for public service announcements
- Post signs and deliver notices to homes and businesses. (See attached samples)
- Arrange alternate source if necessary – i.e., bottled or bulk water
- Advise RDN supervisory personnel
- Advise local fire dept not to use fire hydrants

Contacts:

- Island Health
- EMBC (Emergency Management BC), and RCMP
- Ministry of Environment
- All schools and community centers – see “*Priority Contacts*” List
- RCMP if there has been vandalism

### Loss of Source (Loss Of Reservoir or Supply Lines)

Actions:

- Ensure pumps are shut off. (To protect pump)
- Notify all users
- Notify Environmental Health Officer Ph. 250-947-8222 (or after-hours Medical Health Officer at 1-800-204-6166)
- Arrange alternate source – i.e., bottled water, bulk water, storage tank
- Advise RDN supervisory personnel if necessary

Contacts:

- Island Health
- Ministry of Environment

## Emergency Response Plans Cont'd

### Broken Water Main

Actions:

- Shut pump off when backflow conditions have been prevented
- Call for repairs as required – i.e. excavator, backhoe
- Notify all users of interruption of service
- Notify Environmental Health Officer Ph. 250-947-8222 (or after-hours Medical Health Officer at 1-800-204-6166)
- Arrange alternate source if necessary
- Advise RDN supervisory personnel

Contacts:

- Island Health

### Chlorination Failure

Actions:

- Notify Environmental Health Officer Ph. 250-947-8222 (or after-hours Medical Health Officer at 1-800-204-6166)
- Shut off well pumps. Monitor reservoir levels.
- Notify all users to boil water for two minutes or take other disinfection procedures in accordance with recommendations of local health officials
- Post signs or deliver notices if necessary. (See attached samples)
- Arrange chlorinator repairs
- Arrange for alternate disinfection if necessary
- Advise RDN supervisory personnel

Contacts:

- Island Health
- Chlorinator manufacturer

### Pump Failure

Actions:

- Notify all users of interruption of service
- Call for repairs: pump manufacturer if necessary
- Notify Environmental Health Officer Ph. 250-947-8222 (or after-hours Medical Health Officer at 1-800-204-6166) (if interruption is not short term)
- Arrange alternate source if necessary – bottled or bulk water, etc.
- Advise RDN supervisory personnel if necessary

Contacts:

- Island Health

## Emergency Response Plans Cont'd

### Power Failure

Actions:

- Call BC Hydro. Find out when power will be restored
- Start back-up generator or arrange to get one
- Notify all users about interruption of service if backup not capable of maintaining supply
- Post signs or deliver notices if necessary. (See attached samples)
- Notify Environmental Health Officer Ph. 250-947-8222 (or after-hours Medical Health Officer at 1-800-204-6166)
- Arrange alternate source if necessary – bottled or bulk water, etc.
- Advise RDN supervisory personnel

Contacts:

- Island Health

### Backflow or Back Siphonage

Actions:

- Notify Environmental Health Officer Ph. 250-947-8222 (or after-hours Medical Health Officer at 1-800-204-6166)
- Notify all users to boil water for two minutes or take other disinfection procedures in accordance with recommendations of local health officials. (See attached samples)
- Purge and disinfect lines as directed, after corrections have been made
- Post signs or deliver notices if necessary. (See attached samples)
- Advise RDN supervisory personnel

Contacts:

- Island Health

### Bacteria Count (RDN Lab)

Actions:

- Notify Medical Health Officer Ph. 250-739-6304 (or after-hours 1-800-204-6166)
- Follow procedures in accordance with recommendations of local health officials
- Post signs or deliver notices if necessary. (See attached samples)
- Check if UV unit is working at Descanso Bay Reg Park, clean the UV bulb
- Arrange for alternate disinfection at Descanso Bay Reg Park if the UV unit is not working
- Advise RDN supervisory personnel

Contacts:

- Island Health

## Emergency Response Plans Cont'd

### Flood Conditions:

Actions:

- Notify Environmental Health Officer Ph. 250-947-8222 (or after-hours Medical Health Officer at 1-800-204-6166)
- Notify all users regarding the potential for water contamination, loss of pump, power, etc, Users should be advised to store some drinking water in advance, and to boil any suspect water for two minutes or disinfect with chlorine when flood conditions exist
- Phone government contacts
- Contact local media for public service announcement when customers can not be reached by phone
- Post signs or deliver notices if necessary. (See attached samples)
- Arrange alternate source if possible – i.e. bottled water, bulk hauler or storage tank
- Advise RDN supervisory personnel

Contacts:

- Island Health
- EMBC (Emergency Management BC)
- Ministry of Environment

### Drought Management Plan:

Actions:

- Monitor local well levels, streamflow, provincial drought rating, and provincial wildfire danger class rating
- Review historical water usage patterns to predict potential shortages
- Notify users early in the Spring/Summer about conservation strategies
- Manage water supply and maintain storage for fire flows
- Implement Stage 3 or Stage 4 watering restrictions, as required
- Reduce flows from all wells and from the Craig Bay Pump Station, if required
- Adjust chlorine dosing levels accordingly
- Notify Environmental Health Officer Ph. 250-947-8222 (or after-hours Medical Health Officer at 1-800-204-6166)
- Notify users in each affected water service area via roadside signage, hand-delivered notices, website alerts, e-messages, newspaper ads, radio/tv ads, and other means necessary

Contacts:

- Island Health
- EMBC (Emergency Management BC)

## APPENDICES

Boil Water Notice	13
Boil Water Info for the General Public	14-26
Boil Water ORDER	27
Unfit for Drinking Notice	28
Service Interruption Notice	29
Decision Tree for Responding to Turbidity Event	30



**SAMPLE**



## BOIL WATER NOTICE

\_\_\_\_\_ Water Service Area  
Effective Date: \_\_\_\_\_

Please note that all water used for domestic purposes (drinking, cooking, etc.) should be boiled before consumption. The boiling should be at a rolling boil and for a minimum of two (2) minutes.

RDN Water Services staff are continually monitoring the water supply system and will provide updates as they become available.

Watch for information updates at [www.rdn.bc.ca](http://www.rdn.bc.ca) (Water Services) and listen to your local radio station for more information.

This order will be in effect until further notice.

WATER SERVICES DEPT. CONTACT INFO:  
Administration ph. (250) 954-3792 or  
Field Office ph. (250) 248-4914 or  
E-mail: [rcu@rdn.bc.ca](mailto:rcu@rdn.bc.ca)



**BOIL WATER NOTICE INFORMATION FOR THE GENERAL PUBLIC  
DURING A BOIL WATER NOTICE CAUSED BY:  
INADEQUATE DISINFECTION**

This information is provided as a guide to help individuals reduce the risk of becoming ill from ingesting non-potable water. Individuals who follow these guidelines will greatly reduce their chance of becoming ill.

**What is a Boil Water Notice?**

A Boil Water Notice is a public announcement advising water system users that they should boil their tap water for drinking and other domestic purposes. It is a notice intended to protect the Publics' health from waterborne infectious agents that could be present or are known to be present in the community's drinking water supply.

**What is the difference between a Boil Water Notice and a Boil Water Order?**

A Boil Water Notice is a notice issued to the public as a health warning. In most cases it is the water supplier who notifies the public.

A Boil Water Order is legal document issued to the water supplier by the Health Authority requiring the water supplier to notify the public of a boil water notice.

**What are the health risks during a Boil Water Notice?**

The health risks are associated with ingesting water that contains microbiological agents that can cause disease. These pathogenic (disease causing) agents could include *Giardia*, *Cryptosporidia*, *E. coli*, *Campylobacter*, *Salmonella* and *Hepatitis A*. Boiling tap water for one minute is sufficient to destroy pathogens that could be present in the water.



There are numerous factors that influence whether a person becomes ill. First, there must be pathogens present in the water you consume. Not every glass of water is likely to contain pathogens. Even if the water you consume contains pathogens, those pathogens that are present must be viable. That is, they must be in a state where they can cause an illness and they must be present in large enough numbers to cause an illness. The number of pathogens needed to cause illness depends on the type of pathogen present, a person's size, age, and immune status.

The incubation period (time for symptoms to develop) will vary depending on the type of pathogen. For example, Giardia (beaver fever) could take up to four weeks to develop symptoms whereas E. coli could take up to ten days and as little as two days. For more information on waterborne diseases go to the following BC Health File;

<http://www.bchealthguide.org/healthfiles/hfile49a.stm>

Any persons believing that they are ill should see their doctor. Patients are sometimes requested to submit samples for laboratory analysis to assist in waterborne outbreak investigations.

It is important to note that Boil Water Notices are specific to microbiological threats. They are not appropriate to address threats from chemical contamination. Boiling chemically contaminated water will only result in the chemical becoming more concentrated or release the chemical into the air where it could be inhaled.

When there is a threat to a water supply from a chemical contaminated a more appropriate public health notice of "Do Not Drink the Water" would be issued.

### **What am I trying to kill when I'm boiling the water?**

Boiling water is recommended to kill pathogenic microbes that may be present in contaminated water. Bacteria such as *E. coli* and *Salmonella* are killed rapidly at temperatures over 60°C and a temperature of 72.4°C for 1 minute is needed to inactivate cryptosporidium. *Hepatitis A* and *Norovirus* are rapidly inactivated at temperatures above 65°C.

Based on the above information there is no need to boil water for prolonged periods of time. Although heating water to boiling is not needed it is the only end point easily recognized by the public without the use of thermometers. It is therefore recommended that the public bring the water to a rolling boil for one minute to ensure that all pathogens have been inactivated.

One minute should be added to the above boiling times if the water is cloudy or highly colored to ensure proper mixing and that all pathogens have been exposed to the high temperature. When boiling water at altitudes above 2000m (6,500 ft), water should be boiled for 2 minutes.

### **How can the water become contaminated?**

The water can become contaminated in a variety of ways. Some of these include:

- Heavy rainfall can wash contaminants into the water source
- Accidental spills in the water supply
- Breakdown of the disinfection process
- Break in water supply mains
- Vandalism
- Connections within the water system between potable and non-potable piping.

### **Is it necessary to boil all the water in the home during a boil water notice?**

No, it is not necessary to boil all your water. Water used for bathing, showering, laundry, toilet flushing and mopping of floors does not need to be boiled. During bathing, young children should be cautioned against swallowing the bath water or alternatively young children could be sponge bathed.

All other water should be boiled. Simply put, any water that has a chance of being ingested should be boiled. This would include water used for drinking, beverage concentrates, ice cubes, washing fruits and vegetables, or brushing teeth.

Severely immune-compromised individuals should always boil their tap water for the purposes above. See the link to BC Health Files number 56, December 2003.

<http://www.bchealthguide.org/healthfiles/hfile56.stm>.

Infant formulas should always be prepared by using boiled tap water or bottled water that is boiled. See the link to BC Health Files number 69b, May 2006.

<http://www.bchealthguide.org/healthfiles/hfile69b.stm>.

Drinking water for pets including dogs, cats, birds and reptiles should also be boiled.

### **How should tap water be boiled properly?**

Tap water should be boiled for at least one minute. Use any clean pot or kettle. Kettles that have automatic shut offs are acceptable.

### **How should tap water be boiled properly? *(continued)***

Health Canada suggests that microwave ovens can also be used using microwave-safe containers but cautions against forming superheated water (water heated above its boiling point without the formation of steam). When using microwaves, Health Canada suggests inserting a glass rod, wooden or plastic spoon in the container to prevent forming superheated water.

After boiling, let the water cool by leaving it on the counter or in the refrigerator in covered containers. Once the water is boiled, it can be stored in food grade containers at room temperature or in the refrigerator.

Shaking the water in the container or pouring the water between two containers and/or adding a pinch of salt can bring back flavor after boiling.

### **Are there alternatives to boiling water?**

Yes, there are. Although there are alternatives, not all of them will be feasible or practical in all situations. In part, it will depend on how much water you need and what you need it for. Safe alternatives to boiling water include:

- Using commercially prepared bottled water
- Obtaining water from an approved source that is not on a boil water notice, or
- Using bleach to disinfect small quantities of tap water. See the following chart or website for a guide to using bleach.

<http://www.bchealthguide.org/healthfiles/hfile49b.stm>

Disinfection using unscented household bleach (5% chlorine) works best with warm water. Add bleach to the water, shake or stir for thorough mixing and then let it stand for at least 30 minutes before drinking.

Gallons of water to disinfect (equivalent shown in brackets)	Amount of Household bleach (5%) to add*
1 gal. (4.5 litres)	2 drops (0.18 mL)
2 ½ gal. (10 litres)	5 drops (0.4 mL)
5 gal. (23 litres)	11 drops (0.9 mL)
10 gal. (45 litres)	22 drops (1.8 mL)
22 gal. (100 litres)	¾ teaspoon (4 mL)
45 gal. (205 litres)	1 ½ teaspoons (8 mL)
50 gal. (230 litres)	1 ¾ teaspoons (9 mL)
100 gal. (450 litres)	3 ½ teaspoons (18 mL)
220 gal. (1000 litres)	8 teaspoons (40 mL)
500 gal. (2200 litres)	6 tablespoons (90 mL)
1000 gal. (4550 litres)	6 ½ ounces or 12 tablespoons (180 mL)

A slight chlorine odour should still be noticeable at the end of the 30-minute waiting period if you have added enough bleach. If not, repeat the dosage and allow the water to stand an additional 15 minutes. If the water has too strong a chlorine taste, allow the water to stand exposed to the air for a few hours or pour it from one clean container to another several times.

The disinfection action of bleach depends as much on the waiting time after mixing as to the amount used. The longer the water is left to stand after adding bleach, the more effective the disinfection process will be.

**NOTE: Bleach does not work well in killing off *Cryptosporidium* parasites.**

The amount of bleach needed to kill *Cryptosporidium* makes the water almost impossible to drink. If *Cryptosporidium* is in the water, boiling is the best way to ensure that the water is safe to drink.

### **I have my own water treatment device do I still need to boil my water?**

If the device is designed to improve taste or reduce odour such as an activated carbon filter the answer is **YES** you should still boil your water.

If the device is designed to improve the chemical quality of the water such as reducing the iron content then the answer is **YES** you should still boil your water.

If the device is designed to improve water that is already potable the answer again is **YES** you should still boil your water.

There are numerous filters on the market designed to remove microorganisms and particulates. Most of these filters are not capable of removing viruses. Therefore, you should boil your water if you have a unit that cannot remove viruses.

If the device is designed to disinfect (destroy pathogens) water such as in an ultraviolet light (UV) disinfection unit you **might not** need to boil your water. There are numerous ultraviolet units; some are designed to disinfect raw water and some are designed to disinfect water that has already been disinfected at a central facility. For example, if the unit is classified by the National Sanitation Foundation (NSF) as meeting NSF Standard 55 Class A, it is designed to disinfect raw water. However, if the water within the distribution system is too turbid or cloudy, even a UV unit meeting NSF Standard 55 Class A may not work properly and you should still boil your water.

Reverse osmosis (RO) units are designed to filter water at the molecular level and should provide water that is free of pathogens. Thus, you **do not** have to boil your water if you have a reverse osmosis water treatment device.

There are many types of units on the market each designed to address specific water quality issues. It is recommended that you check with the unit's manufacturer to know exactly what your unit can do.

### **Can I purchase water from vending machines?**

It depends on how the water is treated. Local vending machines that use local water would only be acceptable if the vending machine can kill pathogens that might be present in the water. Check with the store or manufacturer to see if the unit is capable of providing water that is safe to drink.

Warning signs should be posted on vending units that are not capable of providing safe water. Alternatively, the machine should be turned off.

### **Are there any people or groups of people at higher risk?**

Yes. These people include any individual whose immune system is not fully developed or whose immune system is under stress such as infants, the elderly, immune compromised individuals and individuals already suffering from an illness. For more information go to the following BC Ministry of Health websites:

BC Health File: weakened immune systems

<http://www.bchealthguide.org/healthfiles/hfile56.stm>.

BC Health File: preparing infant formula

<http://www.bchealthguide.org/healthfiles/hfile69b.stm>.

### **Boil water or provide an alternative safe supply of water that is used for:**

- Drinking purposes- This includes all beverage concentrates such as fruit juice and iced tea
- Food preparation- This includes washing of fruits and vegetables
- Food contact surfaces

**Boil water or provide an alternative safe supply of water that is used for:  
(continued)**

Food contact surfaces are all those surfaces that food comes into contact with during the food preparation process. These surfaces include counter tops, cutting boards and chopping blocks. Food contact surfaces should be washed with clean water and then sanitized using an acceptable sanitizing agent. Sanitizing agents for food contact surfaces include bleach (12-15 mL of 5% bleach per litre of water), iodophors, quaternary ammonia compounds or hydrogen peroxide (3% solution).

- Oral hygiene (brushing teeth)
- Infant formula; see BC Health File; preparing infant formula at <http://www.bchealthguide.org/healthfiles/hfile69b.stm>.
- Ice making

It is important to note that freezing does not destroy most pathogens. Bacteria and viruses can survive in frozen products for long periods of time. Discard any ice made from contaminated or potentially contaminated water.

**Hand washing**

Using warm water and soap should be sufficient. Applying a hand sanitizer after washing with tap water would add an extra barrier of protection.

**Dishwashing by hand**

Dishes washed by hand should be sanitized for two minutes in a separate sink using a bleach solution (2 mL of bleach per litre of water) after the dishes have been washed and rinsed. The dishes should then be left to **air dry** prior to being used. Attempting to wash and sanitize dishes in the same sink at the same time is not recommended because soap, grease and food particles interfere with the sanitizing process.



### **Mechanical dishwashers**

Most residential home-style dishwashers do not provide a high enough temperature to kill all pathogens. Dishwashing units that reach 82 degrees Celsius (180 Fahrenheit) for twelve seconds (or an equivalent time-temperature relationship) during the final rinse cycle will destroy pathogens.

To optimize the disinfection process while using a residential dishwasher you should consider:

1. Using the highest temperature setting possible.
2. Running dishes through the dishwasher twice.
3. Sanitizing dishes afterwards in a sink containing a weak bleach solution (see dishes washed by hand above).
4. Letting the dishes air dry prior to use

### **Fruit and vegetable washing**

Thoroughly wash all produce with potable water especially those that are going to be eaten raw. This is a common sense practice that should be applied even when there is no public boil water notice.

### **Coffee Machines**

Coffee machines usually produce water around 70 to 80 degrees Celsius, which is sufficient to destroy pathogens. However, a sufficient amount of time is needed to ensure that all harmful organisms are destroyed. Therefore, let the coffee stand for at least five minutes before drinking.

### **Home canning**

To be safe, postpone home canning until the boil water notice has been rescinded.

### **Beer and wine making**

To be safe, postpone beer and wine making until the boil water notice has been rescinded.

### **When will the Boil Water Notice be rescinded?**

Only when the water supplier can provide potable water will the Health Authority rescind the Boil Water Notice. Once or more of the following usually achieves confirmation that the water is once again safe to drink.

These include:

- Identifying and fixing the source or sources of the problem,
- Implementing procedures to eliminate or reduce the chance for reoccurrence
- Performing water quality tests
- Flushing and disinfecting distribution lines and water storage facilities

### **Precautions to consider when the Boil Water Notice is lifted**

- Flush all water-using fixtures for 1 minute
- Run cold-water faucets and drinking fountains for 1 minute before using water
- Drain and flush all ice-making machines in your refrigerator
- Run water softeners through a regeneration cycle
- Drain and refill hot water heaters set below 45 deg C (normal setting is 60 deg C)
- Change any pre-treatment filters (under sink style and refrigerator water filters, carbon block, activated carbon, sediment filters, etc.)

**Can I speak to a person in Public Health if I have a question about the Boil Water Notice?**

Yes you can. For further information contact Island Health Officers at the following locations:

- Victoria ph. 250-519-3401
- Nanaimo ph. 250-755-6215
- Parksville ph. 250-947-8222
- Courtenay ph. 250-331-8518
- Island Health Office 6475 Metral Drive, Nanaimo, BC
- Island Health Office 489 Alberni Hwy, Parksville BC

After hours Medical Health Officer on call is 1-800-204-6166.

**Additional information can be found at the following BC, Canadian and US websites. These are:**

BC Health File; how to disinfect drinking water

<http://www.bchealthguide.org/healthfiles/hfile49b.stm>

BC Health File; weekend immune systems and water-borne infections

<http://www.bchealthguide.org/healthfiles/hfile56.stm>

BC Health File; waterborne disease in BC

<http://www.bchealthguide.org/healthfiles/hfile49a.stm>

BC Health File; cryptosporidiosis

<http://www.bchealthguide.org/healthfiles/hfile48.stm>

BC Health File; giardiasis

<http://www.bchealthguide.org/healthfiles/hfile10.stm>

BC Health File; safely preparing and storing baby formula

<http://www.bchealthguide.org/healthfiles/hfile69b.stm>

US EPA how to boil water and use bleach

<http://www.epa.gov/ogwdw000/faq/emerg.html>

US Centre for Disease Control; preventing cryptosporidiosis infection

<http://www.cdc.gov/ncidod/dpd/parasites/cryptosporidiosis/default.htm>

US Centre for Disease Control; Giardia fact sheet

[http://www.cdc.gov/ncidod/dpd/parasites/giardiasis/factsht\\_giardiasis.htm#prevention](http://www.cdc.gov/ncidod/dpd/parasites/giardiasis/factsht_giardiasis.htm#prevention)

US Centre for Disease Control; Preventing Cryptosporidium; a guide to water filters & bottled water

[http://www.cdc.gov/ncidod/dpd/parasites/cryptosporidiosis/factsht\\_crypto\\_prevent\\_water.htm](http://www.cdc.gov/ncidod/dpd/parasites/cryptosporidiosis/factsht_crypto_prevent_water.htm)

### **Information sources for developing this package includes**

- BC Ministry of Health
- Health Canada
- Alberta Environmental Health
- Washington State Department of Health
- BC Centre for Disease Control
- US EPA (Environmental Protection Agency)
- US Center for Disease Control
- NSF (National Sanitation Foundation)
- DWO (Drinking Water Officer's) Guide



**SAMPLE**



## NOTICE

# BOIL WATER ORDER

\_\_\_\_\_ Water Service Area  
Effective Date: \_\_\_\_\_

Please note that all water used for domestic purposes (drinking, cooking, etc.) should be boiled before consumption. The boiling should be at a rolling boil and for a minimum of two (2) minutes.

RDN Water Services staff are continually monitoring the water supply system and will provide updates as they become available.

Watch for information updates at [www.rdn.bc.ca](http://www.rdn.bc.ca) (Water Services) and listen to your local radio station for more information.

This order will be in effect until further notice.

For further information, please contact us at the numbers below.

WATER SERVICES DEPT. CONTACT INFO:  
Administration ph. (250) 954-3792 or  
Field Office ph. (250) 248-4918 or  
E-mail: [rcu@rdn.bc.ca](mailto:rcu@rdn.bc.ca)





REGIONAL  
DISTRICT  
OF NANAIMO

**SAMPLE**



**WARNING**

This water is  
considered **UNFIT**  
for drinking or  
domestic use

**EFFECTIVE** \_\_\_\_\_

For further information, please contact us at the numbers below.

WATER SERVICES DEPT. CONTACT INFO:  
Administration ph. (250) 954-3792 or  
Field Office ph. (250) 248-4914 or  
E-mail: [rou@rdn.bc.ca](mailto:rou@rdn.bc.ca)

Printed: June 10, 2016





**SAMPLE**



# NOTICE WATER SUPPLY SERVICE INTERRUPTION

\_\_\_\_\_ Service Area

**Date:** \_\_\_\_\_

**Location:** \_\_\_\_\_

**Hours:** \_\_\_\_\_

The Regional District of Nanaimo wishes to notify you that while improvements to the water system are in progress, water service will be interrupted.

The above time period is not definite, as the RDN will endeavor to keep you in service for as long as possible and have the water back in service as quickly as possible after the initial shutdown occurs.

When service is resumed, the water may be discoloured. This is due to disturbed deposits in the pipes and is not harmful. The RDN is not responsible for any damage resulting from interrupted service.


If you have any questions or require further information, please contact us at the numbers provided below.

WATER SERVICES DEPT. CONTACT INFO:  
Administration ph. (250) 954-3792 or  
Field Office ph. (250) 248-4914 or  
E-mail: [rcu@rdn.bc.ca](mailto:rcu@rdn.bc.ca)

Printed: June 10, 2016



Decision Tree for Responding to a Turbidity Event in Unfiltered Drinking Water






# MAPS

## Water Service Areas

Nanoose Bay Peninsula Water Service Area	Map 1
Madrona Pt/Wall Beach Neighbourhood	Map 2
Fairwinds Neighbourhood	Map 3
Arbutus Park Neighbourhood	Map 4
West Bay Neighbourhood	Map 5
Driftwood Neighbourhood	Map 6
French Creek Water Service Area	Map 7
Surfside Water Service Area	Map 8
San Pareil Water Service Area	Map 9
Englishman River Water Service Area	Map 10
Melrose Water Service Area	Map 11
Decourcey Water Service Area	Map 12
Whiskey Creek Water Service Area	Map 13
Descanso Bay Reg. Park Water System	Map 14
Horne Lake Reg. Park Water System	Map 15
Rollo McClay Community Park Water System	Map 16
Westurne Heights Water System	Map 17

# MAP 1 NANOOSE BAY PENINSULA






REGIONAL DISTRICT OF NANAIMO

**FAIRWINDS AREA OF NANOOSE BAY WATER SERVICE AREA (BL 867.02)**


Legend

- Service Area
- Building and Address


3124



MAP 3 FAIRWINDS




**MAP 4 ARBUS PAK**



**MAP 5 WEST BAY**


# EMERGENCY RESPONSE PLAN

## WATER SYSTEMS



# MAP 6 DRIFTWOOD






**MAP 7 FRENCH CREEK**




**SURFSIDE PROPERTIES WATER SERVICE AREA (BL 694)**


Legend


- Service Area
- Building and Address




**MAP 8 SURFSIDE**








MAP 11 MELROSE




MAP 12 DECOURCEY




**MAP 13 WHISKEY CREEK**






MAP 15 HORNE LAKE REG. PARK







**Legend**

	Cistern		3, PVC
	Flush Out		Westurne Heights Water
	Pumphouse		
	Well		

40 20 0 40 Meters

**MAP 17 WESTURNE HEIGHTS**