



## REQUEST FOR PROPOSALS No. 25-007

### RDN – SERVER ROOM FIRE SUPPRESSION SYSTEM

#### Addendum 1

Issued: January 27<sup>th</sup>, 2025

**Closing Date & Time: on or before 3:00 PM Pacific Time on February 6<sup>th</sup>, 2025**

#### Update to Scope of Work

It has come to light that the Victaulic Vortex system can be sized to account for dispersion of the atomized water into HVAC ducting. This addendum removes the HVAC ducting isolation from the scope of work. The following sections of the RFP are revised as per the below:

- Section 3, item A.ii:
  - Has been removed from the Scope of Work.
- Section 4, item D:
  - Examples of HVAC modifications are no longer required.
- Section 4, item H:
  - Description of warranty of the HVAC equipment is no longer required.
- Section 5:
  - Description of HVAC scope will not be evaluated.
- Section 5:
  - No warranty description required for HVAC scope.
- Appendix D:
  - Cost for HVAC modifications not required.
  - **Cost for Sprinkler head modifications is still required.**
  
- *Also, Respondent's are to confirm there are no health and safety risks to people and property if the atomized water enters the HVAC system as part of the submission.*

End of Addendum 1