

# REGIONAL DISTRICT OF NANAIMO

## Water Service Area Annual Report 2014



### Melrose Terrace Water System

June 2015

REGIONAL DISTRICT OF NANAIMO

*Water & Utility Services Department*

6300 Hammond Bay Rd, Nanaimo, BC Canada V9T 6N2 | Ph 250-390-6560 | Fax 250-390-1542

## Table of Contents

|     |  |   |
|-----|--|---|
| 1.  | Introduction.....  | 1 |
| 2.  | Melrose Water Service Area.....                            | 1 |
| 2.1 | Groundwater Wells .....                                    | 1 |
| 2.2 | Reservoirs.....  | 1 |
| 2.3 | Distribution System.....                                   | 1 |
| 3.  | Water Sampling and Testing Program.....                    | 2 |
| 4.  | Water Quality - Source Water and Distribution System ..... | 2 |
| 5.  | Water Quality Inquiries and Complaints .....               | 2 |
| 6.  | Groundwater Production and Consumption.....                | 3 |
| 7.  | Maintenance Program.....                                   | 3 |
| 8.  | Water System Projects .....                                | 4 |
| 8.1 | 2014 Completed Studies & Projects.....                     | 4 |
| 8.2 | 2015 Proposed Projects & Upgrades .....                    | 4 |
| 9.  | Emergency Response Plan.....                               | 4 |
| 10. | Cross Connection Control.....                              | 4 |
| 11. | Closing .....  | 5 |

Appendix A - Map of Melrose Water Service Area

Appendix B - Water Quality Testing Results

Appendix C - Emergency Response Plan

**1. Introduction**

The following annual report describes the Melrose Water Service Area and summarizes the water quality and production data from 2014. This report also includes a summary of inquiries and complaints, completed and proposed maintenance activities, the Emergency Response Plan, and the Cross Connection Control Program.

This report is to be submitted to Island Health by the Spring of 2015.

**2. Melrose Water Service Area**

The Melrose Water Service Area was established in April 2005 when the RDN acquired the existing Melrose Terrace Strata Plan VIS3747 water system. The water service area is comprised of 28 residential properties on Melrose Road located near the Alberni Highway southwest of Coombs. The water source for the Melrose Water Service Area comes from one groundwater well located nearby. The water is chlorinated and stored in a single reservoir. The water is then filtered through sand and charcoal filters before entering the distribution system. A portable generator is available in the event of a power outage. A map of the Melrose Water Service Area is provided in Appendix A for reference.

**2.1 Groundwater Wells**

One groundwater production well is present at the reservoir site on Melrose Road, west of Coombs, B.C.

| Well / Name | Well Depth | Wellhead Protection In Place | Treated/Untreated with Chlorine |
|-------------|------------|------------------------------|---------------------------------|
| #1          | 26.2 m     | Yes                          | Treated                         |

**2.2 Reservoirs**

One service reservoir (steel structure) is present at 3853 Melrose Road, and has a capacity of 136 m<sup>3</sup> (30,000 imperial gallons).

**2.3 Distribution System**

The water distribution system in Melrose is comprised of 0.3 km of 150mm PVC watermains. There are no fire hydrants located within the system.



**Melrose Pumphouse and Reservoir**

### 3. Water Sampling and Testing Program

Water sampling and testing is carried out weekly in the distribution system. The following table includes a summary of all testing:

| Timing                                     | Location                       | Tests   |
|--|--------------------------------|---|
| Weekly                                     | RDN (in-house) Laboratory      | Total coliforms, E.Coli<br>Temperature, pH, Conductivity<br>Chlorine residual, Salinity, TDS<br>Monthly- Iron and Manganese |
| Monthly                                    | BC Centre for Disease Control  | Total coliforms, E.Coli   |
| Annual Source Water Testing (every Fall)   | North Island Labs (now Maxxam) | Complete potability testing of raw well water (including T-Ammonia in 2014)   |
| Annual System Water Testing (every Spring) | North Island Labs (now Maxxam) | Complete potability testing of distribution system (including T-Ammonia in 2014)  |

### 4. Water Quality - Source Water and Distribution System

Up-to-date water quality reports and lab data are posted monthly on the RDN website at [www.rdn.bc.ca](http://www.rdn.bc.ca) in the Services section, under “Water & Utility Services” then “WaterSmart Communities”. Tables of water quality testing results for both the source water and distribution system are provided at the end of this report under Appendix B.

### 5. Water Quality Inquiries and Complaints

No complaints were received from the Melrose water service area in 2014. One inquiry was received, about whether a water service could be shut off at the road when the homeowner expected to be away for an extended period (The answer was yes.).




Melrose Road



## 6. Groundwater Production and Consumption

The monthly groundwater production in the Melrose system for the past 5 years is shown in the chart below. Groundwater production in 2014 was lower than previous years.



### Consumption

In the Fall/Winter of 2014, the average usage per home in the Melrose water service area was approximately 0.39 cubic metres per day (86 imperial gallons). In the summer, the average water usage was 0.51 cubic metres per day (112 imperial gallons). Based on these figures, the annual consumption per capita is estimated to be 178 L/day (based on 2.4 people per household). This consumption is 33% less than the RDN system average of 276 L/day/capita in 2014.

## 7. Maintenance Program

Regular maintenance and inspections are completed around the wellhead area to reduce or eliminate the risk of contamination and system failure, and to ensure the consistent application of chlorine for treatment purposes. Watermains are flushed once annually; in the Spring. There are no fire hydrants on the system.

Twenty-four hour on-call coverage is in place to respond to water system emergencies and alarms.

## 8. Water System Projects

### 8.1 2014 Completed Studies & Projects

- Updated the Water Services asset database;
- Updated the Emergency Response Plan;
- Updated the Standard Operating Procedures; and
- Enforced the outdoor sprinkling regulations;
- Carried out a comprehensive water conservation campaign (Team WaterSmart);
- Updated and improved the RDN website at [www.rdn.bc.ca](http://www.rdn.bc.ca);
- Utilized the Auto E-message service to notify member residents of water service disruptions and upcoming maintenance activities;
- Applied a rainwater harvesting incentive (rain barrels);
- Maintained a high level of water quality;
- Maintained excellent customer complaint and service request response times;
- Continued quality control through regular testing and monitoring of water system; and,
- Completed additional educational programs.

### 8.2 2015 Proposed Projects & Upgrades

- Conduct a reservoir inspection;
- Continue to offer a rainwater harvesting (rain barrel) and other water-saving incentives;
- Update the Emergency Response Plan;
- Re-certify Operator's Backflow Prevention Tester certification;
- Enforce the outdoor sprinkling regulations;
- Maintain a high level of water quality;
- Maintain excellent customer complaint and service request response times;
- Continue quality control through regular testing and monitoring of water system; and,
- Complete additional educational programs.

## 9. Emergency Response Plan

The Regional District Emergency Response Plan (ERP) contains procedures and contact information to efficiently respond to water system emergencies such as contamination of water supply, loss of supply, and pump failure. The ERP was reviewed and updated in 2014, and copies are available on our website, at each RDN office, in each pumphouse, and in each Water Services vehicle. A copy of the ERP is also attached to this report in Appendix C.

## 10. Cross Connection Control

A formalized Cross Connection Control Program was initiated in 2007. Cross connection controls in-place include dual check valves at each service connection, fire hydrant use permits, and water supply bylaws noting discontinued service if a threat to the water supply is perceived by staff.

In 2008, a review and comparison of successful cross-connection control programs in other small water systems nearby was undertaken. A database of commercial customers was set-up

in order to keep track of the maintenance history of testable backflow prevention assemblies at each site. Three RDN Operations staff achieved Backflow Prevention Tester’s certification. Two Operators plan to re-certify their Backflow Prevention Tester certification in 2015.

In 2012, *Regional District of Nanaimo Water Use Regulation Bylaw No. 1654, 2012* was adopted which includes enhanced cross connection control and backflow protection wording. A separate Cross Connection Control bylaw was deemed not to be required.

**11. Closing**

An annual report for the year 2015 will be prepared and submitted to Island Health in the Spring of 2016. Annual reports are also available on our website at [www.rdn.bc.ca](http://www.rdn.bc.ca) in the SERVICES section, under Water & Utility Services then WaterSmart Communities.




Melrose Road

**APPENDIX A**

**MAP OF MELROSE  
WATER SERVICE AREA**



MELROSE  
WATER SERVICE AREA



## APPENDIX B

### WATER QUALITY TESTING RESULTS

# MELROSE TERRACE COMMUNITY WATER SYSTEM



## Facility Location:

3887 Melrose Place  
Qualicum Beach

## Facility Information:

Facility Type: DWC

## Facility Sampling History:

| <u>Location</u>                        | <u>Date</u> | <u>Total Coliform</u> | <u>E. Coli</u> |
|--|-------------|-----------------------|----------------|
| 3927 Melrose Place, 3927 Melrose Place | 3-Dec-2014  | L1                    | L1             |
| 3927 Melrose Place, 3927 Melrose Place | 3-Nov-2014  | T                     | T              |
| 3927 Melrose Place, 3927 Melrose Place | 7-Oct-2014  | L1                    | L1             |
| 3927 Melrose Place, 3927 Melrose Place | 3-Sep-2014  | L1                    | L1             |
| 3927 Melrose Place, 3927 Melrose Place | 5-Aug-2014  | L1                    | L1             |
| 3927 Melrose Place, 3927 Melrose Place | 2-Jul-2014  | L1                    | L1             |
| 3927 Melrose Place, 3927 Melrose Place | 4-Jun-2014  | L1                    | L1             |
| 3927 Melrose Place, 3927 Melrose Place | 6-May-2014  | L1                    | L1             |
| 3927 Melrose Place, 3927 Melrose Place | 1-Apr-2014  | L1                    | L1             |
| 3927 Melrose Place, 3927 Melrose Place | 4-Mar-2014  | L1                    | L1             |
| 3927 Melrose Place, 3927 Melrose Place | 3-Feb-2014  | L1                    | L1             |
| 3927 Melrose Place, 3927 Melrose Place | 6-Jan-2014  | L1                    | L1             |
| 3927 Melrose Place, 3927 Melrose Place | 3-Dec-2013  | L1                    | L1             |
| 3927 Melrose Place, 3927 Melrose Place | 6-Nov-2013  | L1                    | L1             |
| 3927 Melrose Place, 3927 Melrose Place | 2-Oct-2013  | L1                    | L1             |
| 3927 Melrose Place, 3927 Melrose Place | 4-Sep-2013  | L1                    | L1             |
| 3927 Melrose Place, 3927 Melrose Place | 6-Aug-2013  | L1                    | L1             |
| 3927 Melrose Place, 3927 Melrose Place | 2-Jul-2013  | L1                    | L1             |
| 3927 Melrose Place, 3927 Melrose Place | 3-Jun-2013  | L1                    | L1             |

## Interpreting Sample Reports

In VIHA, the results of drinking water sampling are reported using the following coding system:

- L1 Less than 1 (no detectable bacteria) - Meaning: No bacteria present
- OG Overgrown - Meaning: Too many background bacteria to give an accurate count
- EST Estimated Count
- A Sample not tested; Too long in transit
- C Sample leaked/broken in transit
- D Sample not tested; No collection date given
- T Sample submitted unsatisfactory. Exceeded 30 hours holding time, please resample.
- NS No sample received with requisition

# Melrose Well Water Analysis Results

## Well # 1: 3853 Melrose Road

Canadian Drinking Water Guidelines Package



CDWG=Canadian Drinking Water Guidelines  
OG= Operational Guidance Value

MAC=Maximum Acceptable Concentration  
AO= Asthetic Objective

**Red font indicates non-compliance with Canadian Drinking Water Guidelines**

| Parameter                     | Water Quality Guidelines |         |     | 27-Oct       | 19-Oct      | 16-Oct       | 17-Oct      | 4-Nov        |  |
|-------------------------------|--------------------------|---------|-----|--------------|-------------|--------------|-------------|--------------|--|
|                               | Units                    | CDWG    |     | 2010         | 2011        | 2012         | 2013        | 2014         |  |
| Total Ammonia (N)             | mg/L                     |         |     |              |             | 0.17         | 0.17        | 0.20         |  |
| Color-Apparent                | CU                       |         |     | >150         | 310         | 240          | 26          | 520          |  |
| Conductivity                  | uS/cm                    |         |     | 349          | 351         | 416          | 425         | 406          |  |
| TDS                           | mg/L                     | ≤500    | AO  | 230          | 204         | 298          | 250         | 214          |  |
| Hardness (CaCO <sub>3</sub> ) | mg/L                     | 80-100  | AO  | <b>130</b>   | <b>140</b>  | <b>150</b>   | <b>150</b>  | <b>140</b>   |  |
| pH                            | pH units                 | 6.5-8.5 | AO  | 6.8          | 6.8         | 7            | 7           | 7            |  |
| Turbidity                     | NTU's                    | 5       | AO  | <b>34.7</b>  | <b>46</b>   | <b>40.2</b>  | <b>9.4</b>  | <b>15.0</b>  |  |
| Alkalinity                    | mg/L                     |         |     | 75           | 86          | 82           | 80          | 72           |  |
| Chloride                      | mg/L                     | ≤250    | AO  | 55.2         | 51.5        | 66           | 74          | 70.6         |  |
| Fluoride                      | mg/L                     | 1.5     | MAC | <1.0         | <0.1        | 0.06         | 0.06        | 0.06         |  |
| Sulfate                       | mg/L                     | 500     | AO  | 2.1          | 1.4         | 2.0          | 1.9         | 1.7          |  |
| Nitrate (N)                   | mg/L                     | 10      | MAC | <0.1         | 0.01        | <0.05        | <0.05       | 0.05         |  |
| Nitrite (N)                   | mg/L                     | 1       | MAC | <0.1         | <0.01       | <0.05        | <0.05       | <0.05        |  |
| T-Aluminum                    | mg/L                     | 0.100   | OG  | <0.005       | <0.005      | 0.003        | <0.005      | <0.005       |  |
| T-Antimony                    | mg/L                     | 0.006   | MAC | <0.0002      | <0.0002     | <0.0001      | <0.0002     | <0.0001      |  |
| T-Arsenic                     | mg/L                     | 0.010   | MAC | 0.0003       | 0.0004      | 0.00031      | 0.0004      | 0.00034      |  |
| T-Barium                      | mg/L                     | 1.0     | MAC | 0.024        | 0.026       | 0.0283       | 0.029       | 0.0302       |  |
| T-Beryllium                   | mg/L                     |         |     |              | <0.00004    | <0.00005     | <0.00004    | <0.00005     |  |
| T-Bismuth                     | mg/L                     |         |     |              | <0.001      | <0.0001      | <0.0010     | <0.0001      |  |
| T-Boron                       | mg/L                     | 5.0     | MAC | <0.005       | 0.008       | 0.007        | <0.005      | 0.005        |  |
| T-Cadmium                     | mg/L                     | 0.005   | MAC | <0.00001     | <0.00001    | 0.00001      | <0.00001    | <0.00001     |  |
| T-Calcium                     | mg/L                     |         |     | 33.4         | 36.5        | 38.3         | 36.5        | 36.9         |  |
| T-Chromium                    | mg/L                     | 0.05    | MAC | 0.0005       | 0.0006      | <0.0005      | 0.0004      | 0.0006       |  |
| T-Cobalt                      | mg/L                     |         |     |              | 0.00008     | <0.0001      | 0.00005     | <0.0001      |  |
| T-Copper                      | mg/L                     | ≤1.0    | AO  | 0.003        | 0.003       | 0.0025       | 0.002       | 0.0018       |  |
| T-Iron                        | mg/L                     | ≤0.3    | AO  | <b>9.08</b>  | <b>8.88</b> | <b>8.9</b>   | <b>9.81</b> | <b>9.54</b>  |  |
| T-Lead                        | mg/L                     | 0.010   | MAC | 0.0001       | 0.0006      | 0.0002       | 0.0009      | 0.0003       |  |
| T-Lithium                     | mg/L                     |         |     | <0.001       | <0.001      | 0.0005       | <0.001      | 0.0005       |  |
| T-Magnesium                   | mg/L                     |         |     | 11.8         | 11.5        | 13.8         | 14.4        | 12.8         |  |
| T-Manganese                   | mg/L                     | ≤0.05   | AO  | <b>0.264</b> | <b>0.27</b> | <b>0.264</b> | <b>0.27</b> | <b>0.265</b> |  |
| T-Mercury                     | mg/L                     | 0.001   | MAC | <0.00001     | <0.00001    | <0.0001      | <0.00001    | <0.00001     |  |
| T-Molybdenum                  | mg/L                     |         |     |              | <0.0001     | 0.00006      | 0.0012      | <0.00005     |  |
| T-Nickel                      | mg/L                     |         |     | <0.001       | <0.001      | <0.0002      | <0.001      | <0.0002      |  |
| T-Phosphorus                  | mg/L                     |         |     | 0.019        | <0.01       |              |             |              |  |
| T-Potassium                   | mg/L                     |         |     | 0.4          | 0.8         | 0.4          | 0.53        | 0.4          |  |
| T-Selenium                    | mg/L                     | 0.01    | MAC | <0.0006      | 0.0051      | <0.0001      | <0.0006     | <0.0001      |  |
| T-Silicon                     | mg/L                     |         |     |              | 13.7        | 15.7         | 13.9        | 15           |  |
| T-Silver                      | mg/L                     |         |     | <0.00001     | <0.00001    | <0.00001     | <0.00001    | <0.00005     |  |
| T-Sodium                      | mg/L                     | ≤200    | AO  | 21.8         | 12.8        | 15.1         | 18          | 17.1         |  |
| T-Strontium                   | mg/L                     |         |     |              | 0.07        | 0.071        | 0.076       | 0.0737       |  |
| T-Thallium                    | mg/L                     |         |     |              | <0.00001    | <0.00001     | <0.00001    | <0.00001     |  |
| T-Tin                         | mg/L                     |         |     |              | <0.0001     | 0.0004       | 0.0002      | 0.0007       |  |
| T-Titanium                    | mg/L                     |         |     |              | 0.006       | 0.0006       | 0.0013      | 0.0006       |  |
| T-Uranium                     | mg/L                     | 0.02    | MAC | <0.0004      | <0.0004     | <0.00001     | <0.0004     | <0.00001     |  |
| T-Vanadium                    | mg/L                     |         |     |              | 0.0023      | 0.0014       | 0.0013      | 0.0015       |  |
| T-Zinc                        | mg/L                     | ≤5.0    | AO  | 0.03         | 0.018       | 0.0172       | 0.312       | 0.187        |  |
| Total Coliform                | cfu/100ml                | <1      | MAC | <1.0         | <1.0        | <1.0         | <1.0        | <1.0         |  |
| E.coli                        | cfu/100ml                | <1      | MAC | <1.0         | <1.0        | <1.0         | <1.0        | <1.0         |  |

# Melrose Terrace Distribution Water Analysis Results

**Location: 3927 Melrose Road**

Canadian Drinking Water Guidelines Package



CDWG=Canadian Drinking Water Guidelines

MAC=Maximum Acceptable Concentration

OG= Operational Guidance Value

AO=Aesthetic Objective

**Red font indicates non-compliance with Canadian Drinking Water Guidelines**

| Parameters        | Water Quality Guidelines |         |     | 19-May<br>2010 | 18-May<br>2011 | 16-May<br>2012 | 5-Jun<br>2013 | 13-May<br>2014 |  |
|-------------------|--------------------------|---------|-----|----------------|----------------|----------------|---------------|----------------|--|
|                   | Units                    | CDWG    |     |                |                |                |               |                |  |
| Total Ammonia (N) | mg/L                     |         |     |                |                | 0.03           | <0.01         | <0.02          |  |
| Color-Apparent    | CU                       | ≤15     | AO  | <5             | <5             | 6              | 7             | <5             |  |
| Conductivity      | uS                       |         | MAC | 393            | 397            | 451            | 447           | 458            |  |
| TDS               | mg/L                     | 500     | AO  | 258            | 264            | 262            | 326           | 290            |  |
| Hardness (CaCO3)  | mg/L                     | 80-100  | AO  | 130            | 120            | 150            | 150           | 140            |  |
| pH                | pH units                 | 6.5-8.5 | AO  | 7              | 7.1            | 7.1            | 6.9           | 7              |  |
| Turbidity         | NTU's                    | 5       | AO  | <0.5           | <0.5           | <0.5           | <0.5          | <0.5           |  |
| Alkalinity        | mg/L                     |         |     | 87             | 93             | 92             | 86            | 84             |  |
| Chloride          | mg/L                     | 250     | AO  | 62             | 67.5           | 77             | 7             | 78             |  |
| Fluoride          | mg/L                     | 1.5     | MAC | <1.0           | <1.0           | 0.05           | <0.05         | 0.05           |  |
| Sulfate           | mg/L                     | ≤500    | AO  | <2.0           | <2.0           | 1              | 1.2           | 1.2            |  |
| Nitrate (N)       | mg/L                     | 10      | MAC | <0.1           | <0.1           | <0.05          | <0.05         | <0.05          |  |
| Nitrite (N)       | mg/L                     | 1       | MAC | <0.1           | <0.1           | <0.05          | <0.05         | <0.05          |  |
| T-Aluminum        | mg/L                     | 0.100   | OG  | 0.011          | <0.005         | <0.005         | <0.005        | <0.025         |  |
| T-Antimony        | mg/L                     | 0.006   | MAC | <0.0002        | <0.0002        | <0.0002        | <0.0002       | <0.0005        |  |
| T-Arsenic         | mg/L                     | 0.010   | MAC | <0.0002        | <0.0002        | <0.0002        | <0.0002       | <0.00025       |  |
| T-Barium          | mg/L                     | 1.0     | MAC | 0.025          | 0.025          | 0.026          | 0.032         | 0.0264         |  |
| T-Beryllium       | mg/L                     |         |     |                |                | <0.00004       | <0.00004      | <0.00025       |  |
| T-Boron           | mg/L                     | 5.0     | MAC | 0.014          | 0.006          | 0.008          | 0.006         | <0.010         |  |
| T-Bismuth         | mg/L                     |         |     |                |                | <0.001         | <0.0010       | <0.0005        |  |
| T-Cadmium         | mg/L                     | 0.005   | MAC | <0.00001       | <0.00001       | <0.00001       | <0.00001      | <0.00005       |  |
| T-Calcium         | mg/L                     |         |     | 32.5           | 29.7           | 37.7           | 39            | 36.4           |  |
| T-Chromium        | mg/L                     | 0.05    | MAC | <0.0004        | <0.0004        | 0.0007         | 0.0004        | <0.0025        |  |
| T-Cobalt          | mg/L                     |         |     |                |                | 0.00004        | <0.00002      | <0.0005        |  |
| T-Copper          | mg/L                     | ≤1      | AO  | 0.004          | 0.004          | 0.004          | 0.003         | 0.0062         |  |
| T-Iron            | mg/L                     | ≤0.3    | AO  | 0.191          | 0.172          | 0.121          | 0.061         | 0.135          |  |
| T-Lead            | mg/L                     | 0.010   | MAC | 0.0004         | 0.0007         | 0.0016         | 0.0012        | 0.0007         |  |
| T-Lithium         | mg/L                     |         |     | <0.001         | <0.001         | <0.001         | <0.001        | <0.0025        |  |
| T-Magnesium       | mg/L                     |         | AO  | 11.5           | 10.8           | 13             | 13.4          | 12.7           |  |
| T-Manganese       | mg/L                     | ≤0.05   | AO  | 0.0077         | 0.014          | <0.005         | <0.0050       | <0.0050        |  |
| T-Mercury         | mg/L                     | 0.001   | MAC | <0.01          | <0.00001       | <0.00001       | <0.00001      | <0.00001       |  |
| T-Molybdenum      | mg/L                     |         |     |                |                | <0.0001        | <0.0001       | <0.00025       |  |
| T-Nickel          | mg/L                     |         |     | <0.001         | <0.001         | <0.001         | <0.001        | <0.0010        |  |
| T-Phosphorus      | mg/L                     |         |     | 0.015          | <0.01          | <0.01          |               |                |  |
| T-Potassium       | mg/L                     |         |     | 0.6            | 0.4            | 0.6            | 0.62          | <0.5           |  |
| T-Selenium        | mg/L                     | 0.01    | MAC | <0.0006        | <0.0006        | <0.0006        | <0.0006       | <0.0005        |  |
| T-Silicon         | mg/L                     |         |     |                |                | 14.5           | 14.2          | 14.3           |  |
| T-Silver          | mg/L                     |         |     | <0.00001       | 0.00002        | <0.00001       | 0.00002       | <0.00025       |  |
| T-Sodium          | mg/L                     | ≤200    | AO  | 23.8           | 26.3           | 31.4           | 33.6          | 35.4           |  |
| T-Strontium       | mg/L                     |         |     |                |                | 0.07           | 0.078         | 0.0692         |  |
| T-Thallium        | mg/L                     |         |     |                |                | <0.00001       | <0.00001      | <0.00005       |  |
| T-Tin             | mg/L                     |         |     |                |                | <0.0001        | <0.0001       | <0.0005        |  |
| T-Titanium        | mg/L                     |         |     |                |                | <0.001         | 0.0023        | <0.0025        |  |
| T-Uranium         | mg/L                     | 0.02    | MAC | <0.0004        | <0.0004        | <0.0004        | <0.0004       | <0.00005       |  |
| T-Vanadium        | mg/L                     |         |     |                |                | 0.0001         | 0.0001        | <0.0005        |  |
| T-Zinc            | mg/L                     | ≤5      | AO  | 0.023          | 0.021          | 0.021          | 0.032         | 0.0892         |  |
| Total Coliform    | cfu/100ml                | <1      | MAC | <1.0           | <1.0           | <1.0           | <1.0          | <1.0           |  |
| Fecal Coliform    | cfu/100ml                | <1      | MAC |                |                |                |               |                |  |
| E.coli            | cfu/100ml                | <1      | MAC | <1.0           | <1.0           | <1.0           | <1.0          | <1.0           |  |





# Regional District of Nanaimo - Water Services Department

## Melrose Terrace Water Analysis - 2014 Monthly Report



| Date      | Sample Location (Address) | Health Department |                  | In-House |                  |            |      |                               |                               |              |                      |                   |                  |
|-----------|---------------------------|-------------------|------------------|----------|------------------|------------|------|-------------------------------|-------------------------------|--------------|----------------------|-------------------|------------------|
|           |                           | E. coli *         | Total Coliform * | E.coli * | Total Coliform * | Temp. (°C) | pH   | Free Chlorine Residual (mg/L) | Total Dissolved Solids (mg/L) | Salinity (%) | Conductivity (µS/cm) | Total Iron (mg/L) | Manganese (mg/L) |
| 3-Dec-14  | 3927 Melrose              | 0                 | 0                | 0        | 0                | 9          | 7.02 | 0.01                          | 241.0                         | 0.24         | 500.0                | 0.05              | 0.017            |
| 9-Dec-14  | 3927 Melrose              |                   |                  | 0        | 0                | 8          | 6.77 | 0.02                          | 244.0                         | 0.24         | 505.0                |                   |                  |
| 15-Dec-14 | 3927 Melrose              |                   |                  | 0        | 0                | 8          | 6.78 | 0.01                          | 245.0                         | 0.24         | 507.0                |                   |                  |
|           |                           |                   |                  |          |                  |            |      |                               |                               |              |                      |                   |                  |
|           |                           |                   |                  |          |                  |            |      |                               |                               |              |                      |                   |                  |
|           | <b>Average</b>            | 0                 | 0                | 0        | 0                | 8.3        | 6.9  | 0.01                          | 243.3                         | 0.2          | 504.0                | 0.05              | 0.017            |
|           | <b>Maximum</b>            | 0                 | 0                | 0        | 0                | 9          | 7.02 | 0.02                          | 245                           | 0.24         | 507                  | 0.05              | 0.017            |
|           | <b>Minimum</b>            | 0                 | 0                | 0        | 0                | 8          | 6.77 | 0.01                          | 241                           | 0.24         | 500                  | 0.05              | 0.017            |

**Red font indicates non-compliance with Canadian Drinking Water Guidelines**

Aesthetic Objective for Iron is ≤0.3 mg/L

Aesthetic Objective for Manganese is ≤0.05mg/L

\*Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Yellow Column Coliform tests are completed by Health Department

Blue column tests are completed by RDN

**Comments:**

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.



# Regional District of Nanaimo - Water Services Department

## Melrose Terrace Water Analysis - 2014 Monthly Report



| Date      | Sample Location (Address) | Health Department |                  | In-House |                  |            |      |                               |                               |              |                      |                   |                  |
|-----------|---------------------------|-------------------|------------------|----------|------------------|------------|------|-------------------------------|-------------------------------|--------------|----------------------|-------------------|------------------|
|           |                           | E. coli *         | Total Coliform * | E.coli * | Total Coliform * | Temp. (°C) | pH   | Free Chlorine Residual (mg/L) | Total Dissolved Solids (mg/L) | Salinity (%) | Conductivity (µS/cm) | Total Iron (mg/L) | Manganese (mg/L) |
| 3-Nov-14  | 3927 Melrose              | T                 | T                | 0        | 0                | 12         | 6.77 | 0.04                          | 255.0                         | 0.25         | 526.0                | 0.09              | 0.022            |
| 18-Nov-14 | 3927 Melrose              |                   |                  | 0        | 0                | 10         | 6.72 | 0.02                          | 243.0                         | 0.24         | 501.0                |                   |                  |
| 24-Nov-14 | 3927 Melrose              |                   |                  | 0        | 0                | 9          | 6.76 | 0.01                          | 243.0                         | 0.24         | 503.0                |                   |                  |
|           |                           |                   |                  |          |                  |            |      |                               |                               |              |                      |                   |                  |
|           |                           |                   |                  |          |                  |            |      |                               |                               |              |                      |                   |                  |
|           | <b>Average</b>            | #DIV/0!           | #DIV/0!          | 0        | 0                | 10.3       | 6.8  | 0.02                          | 247.0                         | 0.2          | 510.0                | 0.09              | 0.022            |
|           | <b>Maximum</b>            | 0                 | 0                | 0        | 0                | 12         | 6.77 | 0.04                          | 255                           | 0.25         | 526                  | 0.09              | 0.022            |
|           | <b>Minimum</b>            | 0                 | 0                | 0        | 0                | 9          | 6.72 | 0.01                          | 243                           | 0.24         | 501                  | 0.09              | 0.022            |

Red font indicates non-compliance with Canadian Drinking Water Guidelines

T=Sample not tested. Too long in transit.

Aesthetic Objective for Iron is ≤0.3 mg/L

Aesthetic Objective for Manganese is ≤0.05mg/L

\*Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Yellow Column Coliform tests are completed by Health Department

Blue column tests are completed by RDN

**Comments:**

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.



# Regional District of Nanaimo - Water Services Department

## Melrose Terrace Water Analysis - 2014 Monthly Report



| Date      | Sample Location (Address) | Health Department |                  | In-House |                  |            |      |                               |                               |              |                      |                   |                  |
|-----------|---------------------------|-------------------|------------------|----------|------------------|------------|------|-------------------------------|-------------------------------|--------------|----------------------|-------------------|------------------|
|           |                           | E. coli *         | Total Coliform * | E.coli * | Total Coliform * | Temp. (°C) | pH   | Free Chlorine Residual (mg/L) | Total Dissolved Solids (mg/L) | Salinity (%) | Conductivity (µS/cm) | Total Iron (mg/L) | Manganese (mg/L) |
| 7-Oct-14  | 3927 Melrose              | 0                 | 0                | 0        | 0                | 17         | 7.08 | 0.02                          | 255.0                         | 0.25         | 526.0                | 0.05              | 0.017            |
| 14-Oct-14 | 3927 Melrose              |                   |                  | 0        | 0                | 15         | 7.02 | 0.02                          | 242.0                         | 0.24         | 501.0                |                   |                  |
| 20-Oct-14 | 3927 Melrose              |                   |                  | 0        | 0                | 14         | 6.93 | 0.05                          | 243.0                         | 0.24         | 503.0                |                   |                  |
| 27-Oct-14 | 3927 Melrose              |                   |                  | 0        | 0                | 13         | 6.82 | 0.00                          | 257.0                         | 0.26         | 531.0                |                   |                  |
|           | <b>Average</b>            | 0                 | 0                | 0        | 0                | 14.8       | 7.0  | 0.02                          | 249.3                         | 0.2          | 515.3                | 0.05              | 0.017            |
|           | <b>Maximum</b>            | 0                 | 0                | 0        | 0                | 17         | 7.08 | 0.05                          | 257                           | 0.26         | 531                  | 0.05              | 0.017            |
|           | <b>Minimum</b>            | 0                 | 0                | 0        | 0                | 13         | 6.82 | 0                             | 242                           | 0.24         | 501                  | 0.05              | 0.017            |

**Red font indicates non-compliance with Canadian Drinking Water Guidelines**

Aesthetic Objective for Iron is ≤0.3 mg/L

Aesthetic Objective for Manganese is ≤0.05mg/L

\*Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Yellow Column Coliform tests are completed by Health Department

Blue column tests are completed by RDN

**Comments:**

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.



# Regional District of Nanaimo - Water Services Department

## Melrose Terrace Water Analysis - 2014 Monthly Report



| Date      | Sample Location (Address) | Health Department |                  | In-House |                  |            |      |                               |                               |              |                      |                   |                  |
|-----------|---------------------------|-------------------|------------------|----------|------------------|------------|------|-------------------------------|-------------------------------|--------------|----------------------|-------------------|------------------|
|           |                           | E. coli *         | Total Coliform * | E.coli * | Total Coliform * | Temp. (°C) | pH   | Free Chlorine Residual (mg/L) | Total Dissolved Solids (mg/L) | Salinity (%) | Conductivity (µS/cm) | Total Iron (mg/L) | Manganese (mg/L) |
| 3-Sep-14  | 3927 Melrose              | 0                 | 0                | 0        | 0                | 20         | 6.83 | 0.00                          | 237.0                         | 0.24         | 491.0                | 0.05              | 0.017            |
| 9-Sep-14  | 3927 Melrose              |                   |                  | 0        | 0                | 18         | 7.10 | 0.03                          | 249.0                         | 0.25         | 514.0                |                   |                  |
| 16-Sep-14 | 3927 Melrose              |                   |                  | 0        | 0                | 17         | 6.45 | 0.00                          | 261.0                         | 0.26         | 538.0                |                   |                  |
| 23-Sep-14 | 3927 Melrose              |                   |                  | 0        | 0                | 18         | 6.75 | 0.03                          | 253.0                         | 0.25         | 522.0                |                   |                  |
| 29-Sep-14 | 3927 Melrose              |                   |                  | 0        | 0                | 15         | 6.83 | 0.04                          | 253.0                         | 0.25         | 522.0                |                   |                  |
|           | <b>Average</b>            | 0                 | 0                | 0        | 0                | 17.6       | 6.8  | 0.02                          | 250.6                         | 0.3          | 517.4                | 0.05              | 0.017            |
|           | <b>Maximum</b>            | 0                 | 0                | 0        | 0                | 20         | 7.1  | 0.04                          | 261                           | 0.26         | 538                  | 0.05              | 0.017            |
|           | <b>Minimum</b>            | 0                 | 0                | 0        | 0                | 15         | 6.45 | 0                             | 237                           | 0.24         | 491                  | 0.05              | 0.017            |

Red font indicates non-compliance with Canadian Drinking Water Guidelines

Aesthetic Objective for Iron is ≤0.3 mg/L

Aesthetic Objective for Manganese is ≤0.05mg/L

\*Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Yellow Column Coliform tests are completed by Health Department

Blue column tests are completed by RDN

**Comments:**

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.



# Regional District of Nanaimo - Water Services Department

## Melrose Terrace Water Analysis - 2014 Monthly Report



| Date      | Sample Location (Address) | Health Department |                  | In-House |                  |            |      |                               |                               |              |                      |                   |                  |
|-----------|---------------------------|-------------------|------------------|----------|------------------|------------|------|-------------------------------|-------------------------------|--------------|----------------------|-------------------|------------------|
|           |                           | E. coli *         | Total Coliform * | E.coli * | Total Coliform * | Temp. (°C) | pH   | Free Chlorine Residual (mg/L) | Total Dissolved Solids (mg/L) | Salinity (%) | Conductivity (µS/cm) | Total Iron (mg/L) | Manganese (mg/L) |
| 5-Aug-14  | 3927 Melrose              | 0                 | 0                | 0        | 0                | 20         | 6.82 | 0.01                          | 240.0                         | 0.24         | 497.0                | 0.04              | 0.013            |
| 11-Aug-14 | 3927 Melrose              |                   |                  | 0        | 0                | 19         | 6.98 | 0.07                          | 238.0                         | 0.24         | 493.0                |                   |                  |
| 19-Aug-14 | 3927 Melrose              |                   |                  | 0        | 0                | 19         | 6.50 | 0.05                          | 248.0                         | 0.25         | 512.0                |                   |                  |
| 25-Aug-14 | 3927 Melrose              |                   |                  | 0        | 0                | 17         | 7.10 | 0.06                          | 247.0                         | 0.25         | 511.0                |                   |                  |
|           | <b>Average</b>            | 0                 | 0                | 0        | 0                | 18.8       | 6.9  | 0.05                          | 243.3                         | 0.2          | 503.3                | 0.04              | 0.013            |
|           | <b>Maximum</b>            | 0                 | 0                | 0        | 0                | 20         | 7.1  | 0.07                          | 248                           | 0.25         | 512                  | 0.04              | 0.013            |
|           | <b>Minimum</b>            | 0                 | 0                | 0        | 0                | 17         | 6.5  | 0.01                          | 238                           | 0.24         | 493                  | 0.04              | 0.013            |

**Red font indicates non-compliance with Canadian Drinking Water Guidelines**

Aesthetic Objective for Iron is ≤0.3 mg/L

Aesthetic Objective for Manganese is ≤0.05mg/L

\*Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Yellow Column Coliform tests are completed by Health Department

Blue column tests are completed by RDN

**Comments:**

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.





# Regional District of Nanaimo - Water Services Department

## Melrose Terrace Water Analysis - 2014 Monthly Report



| Date      | Sample Location (Address) | Health Department |                  | In-House |                  |            |      |                               |                               |              |                      |                   |                  |
|-----------|---------------------------|-------------------|------------------|----------|------------------|------------|------|-------------------------------|-------------------------------|--------------|----------------------|-------------------|------------------|
|           |                           | E. coli *         | Total Coliform * | E.coli * | Total Coliform * | Temp. (°C) | pH   | Free Chlorine Residual (mg/L) | Total Dissolved Solids (mg/L) | Salinity (%) | Conductivity (µS/cm) | Total Iron (mg/L) | Manganese (mg/L) |
| 2-Jul-14  | 3927 Melrose              | 0                 | 0                | 0        | 0                | 18         | 6.73 | 0.01                          | 244.0                         | 0.24         | 504.0                | 0.06              | 0.013            |
| 7-Jul-01  | 3927 Melrose              |                   |                  | 0        | 0                | 17         | 6.64 | 0.00                          | 246.0                         | 0.24         | 509.0                |                   |                  |
| 15-Jul-14 | 3927 Melrose              |                   |                  | 0        | 0                | 17         | 6.73 | 0.04                          | 242.0                         | 0.24         | 500.0                |                   |                  |
| 22-Jul-14 | 3927 Melrose              |                   |                  | 0        | 0                | 19         | 6.83 | 0.03                          | 246.0                         | 0.24         | 508.0                |                   |                  |
| 29-Jul-14 | 3927 Melrose              |                   |                  | 0        | 0                | 18         | 6.88 | 0.03                          | 238.0                         | 0.24         | 491.0                |                   |                  |
|           | <b>Average</b>            | 0                 | 0                | 0        | 0                | 17.8       | 6.8  | 0.02                          | 243.2                         | 0.2          | 502.4                | 0.06              | 0.013            |
|           | <b>Maximum</b>            | 0                 | 0                | 0        | 0                | 19         | 6.88 | 0.04                          | 246                           | 0.24         | 509                  | 0.06              | 0.013            |
|           | <b>Minimum</b>            | 0                 | 0                | 0        | 0                | 17         | 6.64 | 0                             | 238                           | 0.24         | 491                  | 0.06              | 0.013            |

**Red font indicates non-compliance with Canadian Drinking Water Guidelines**

Aesthetic Objective for Iron is ≤0.3 mg/L

Aesthetic Objective for Manganese is ≤0.05mg/L

\*Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Yellow Column Coliform tests are completed by Health Department

Blue column tests are completed by RDN

**Comments:**

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.



# Regional District of Nanaimo - Water Services Department

## Melrose Terrace Water Analysis - 2014 Monthly Report



| Date      | Sample Location (Address) | Health Department |                  | In-House |                  |            |      |                               |                               |              |                      |                   |                  |
|-----------|---------------------------|-------------------|------------------|----------|------------------|------------|------|-------------------------------|-------------------------------|--------------|----------------------|-------------------|------------------|
|           |                           | E. coli *         | Total Coliform * | E.coli * | Total Coliform * | Temp. (°C) | pH   | Free Chlorine Residual (mg/L) | Total Dissolved Solids (mg/L) | Salinity (%) | Conductivity (µS/cm) | Total Iron (mg/L) | Manganese (mg/L) |
| 4-Jun-14  | 3927 Melrose              | 0                 | 0                | 0        | 0                | 15         | 6.96 | 0.02                          | 234.0                         | 0.23         | 483.0                | 0.08              | 0.014            |
| 9-Jun-14  | 3927 Melrose              |                   |                  | 0        | 0                | 16         | 7.00 | 0.03                          | 237.0                         | 0.24         | 490.0                |                   |                  |
| 16-Jun-14 | 3927 Melrose              |                   |                  | 0        | 0                | 15         | 6.93 | 0.03                          | 247.0                         | 0.25         | 510.0                |                   |                  |
| 24-Jun-14 | 3927 Melrose              |                   |                  | 0        | 0                | 15         | 7.00 | 0.02                          | 241.0                         | 0.24         | 499.0                |                   |                  |
|           | <b>Average</b>            | 0                 | 0                | 0        | 0                | 15.3       | 7.0  | 0.03                          | 239.8                         | 0.2          | 495.5                | 0.08              | 0.014            |
|           | <b>Maximum</b>            | 0                 | 0                | 0        | 0                | 16         | 7    | 0.03                          | 247                           | 0.25         | 510                  | 0.08              | 0.014            |
|           | <b>Minimum</b>            | 0                 | 0                | 0        | 0                | 15         | 6.93 | 0.02                          | 234                           | 0.23         | 483                  | 0.08              | 0.014            |

**Red font indicates non-compliance with Canadian Drinking Water Guidelines**

Aesthetic Objective for Iron is ≤0.3 mg/L

Aesthetic Objective for Manganese is ≤0.05mg/L

\*Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Yellow Column Coliform tests are completed by Health Department

Blue column tests are completed by RDN

**Comments:**

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.



# Regional District of Nanaimo - Water Services Department

## Melrose Terrace Water Analysis - 2014 Monthly Report



| Date      | Sample Location (Address) | Health Department |                  | In-House |                  |            |      |                               |                               |              |                      |                   |                  |
|-----------|---------------------------|-------------------|------------------|----------|------------------|------------|------|-------------------------------|-------------------------------|--------------|----------------------|-------------------|------------------|
|           |                           | E. coli *         | Total Coliform * | E.coli * | Total Coliform * | Temp. (°C) | pH   | Free Chlorine Residual (mg/L) | Total Dissolved Solids (mg/L) | Salinity (%) | Conductivity (µS/cm) | Total Iron (mg/L) | Manganese (mg/L) |
| 6-May-14  | 3927 Melrose              | 0                 | 0                | 0        | 0                | 11         | 6.79 | 0.02                          | 230.0                         | 0.23         | 475.0                | 0.12              | 0.000            |
| 13-May-14 | 3927 Melrose              |                   |                  | 0        | 0                | 8          | 6.64 | 0.04                          | 233.0                         | 0.23         | 481.0                |                   |                  |
| 21-May-14 | 3927 Melrose              |                   |                  | 0        | 0                | 13         | 7.14 | 0.02                          | 214.0                         | 0.21         | 444.0                |                   |                  |
| 26-May-14 | 3927 Melrose              |                   |                  | 0        | 0                | 13         | 7.08 | 0.03                          | 225.0                         | 0.22         | 466.0                |                   |                  |
|           | <b>Average</b>            | 0                 | 0                | 0        | 0                | 11.3       | 6.9  | 0.03                          | 225.5                         | 0.2          | 466.5                | 0.12              | 0                |
|           | <b>Maximum</b>            | 0                 | 0                | 0        | 0                | 13         | 7.14 | 0.04                          | 233                           | 0.23         | 481                  | 0.12              | 0                |
|           | <b>Minimum</b>            | 0                 | 0                | 0        | 0                | 8          | 6.64 | 0.02                          | 214                           | 0.21         | 444                  | 0.12              | 0                |

**Red font indicates non-compliance with Canadian Drinking Water Guidelines**

Aesthetic Objective for Iron is ≤0.3 mg/L

Aesthetic Objective for Manganese is ≤0.05mg/L

\*Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Yellow Column Coliform tests are completed by Health Department

Blue column tests are completed by RDN

**Comments:**

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.



# Regional District of Nanaimo - Water Services Department

## Melrose Terrace Water Analysis - 2014 Monthly Report



| Date      | Sample Location (Address) | Health Department |                  | In-House |                  |            |      |                               |                               |              |                      |                   |                  |
|-----------|---------------------------|-------------------|------------------|----------|------------------|------------|------|-------------------------------|-------------------------------|--------------|----------------------|-------------------|------------------|
|           |                           | E. coli *         | Total Coliform * | E.coli * | Total Coliform * | Temp. (°C) | pH   | Free Chlorine Residual (mg/L) | Total Dissolved Solids (mg/L) | Salinity (%) | Conductivity (µS/cm) | Total Iron (mg/L) | Manganese (mg/L) |
| 1-Apr-14  | 3927 Melrose              | 0                 | 0                | 0        | 0                | 9          | 6.92 | 0.05                          | 237.0                         | 0.24         | 491.0                | 0.04              | 0.022            |
| 14-Apr-14 | 3927 Melrose              |                   |                  | 0        | 0                | 10         | 6.77 | 0.01                          | 238.0                         | 0.24         | 490.0                |                   |                  |
| 29-Apr-14 | 3928 Melrose              |                   |                  | 0        | 0                | 10         | 6.72 | 0.02                          | 223.0                         | 0.22         | 462.0                |                   |                  |
|           |                           |                   |                  |          |                  |            |      |                               |                               |              |                      |                   |                  |
|           |                           |                   |                  |          |                  |            |      |                               |                               |              |                      |                   |                  |
|           | <b>Average</b>            | 0                 | 0                | 0        | 0                | 9.7        | 6.8  | 0.03                          | 232.7                         | 0.2          | 481.0                | 0.04              | 0.022            |
|           | <b>Maximum</b>            | 0                 | 0                | 0        | 0                | 10         | 6.92 | 0.05                          | 238                           | 0.24         | 491                  | 0.04              | 0.022            |
|           | <b>Minimum</b>            | 0                 | 0                | 0        | 0                | 9          | 6.72 | 0.01                          | 223                           | 0.22         | 462                  | 0.04              | 0.022            |

**Red font indicates non-compliance with Canadian Drinking Water Guidelines**

Aesthetic Objective for Iron is ≤0.3 mg/L      Aesthetic Objective for Manganese is ≤0.05mg/L

\*Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Yellow Column Coliform tests are completed by Health Department

Blue column tests are completed by RDN

**Comments:**

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.



# Regional District of Nanaimo - Water Services Department

## Melrose Terrace Water Analysis - 2014 Monthly Report



| Date      | Sample Location (Address) | Health Department |                  | In-House |                  |            |      |                               |                               |              |                      |                   |                  |
|-----------|---------------------------|-------------------|------------------|----------|------------------|------------|------|-------------------------------|-------------------------------|--------------|----------------------|-------------------|------------------|
|           |                           | E. coli *         | Total Coliform * | E.coli * | Total Coliform * | Temp. (°C) | pH   | Free Chlorine Residual (mg/L) | Total Dissolved Solids (mg/L) | Salinity (%) | Conductivity (µS/cm) | Total Iron (mg/L) | Manganese (mg/L) |
| 4-Mar-14  | 3927 Melrose              | 0                 | 0                | 0        | 0                | 6          | 7.02 | 0.02                          | 238.0                         | 0.24         | 493.0                | 0.04              | 0.008            |
| 10-Mar-14 | 3927 Melrose              |                   |                  | 0        | 0                | 6          | 6.60 | 0.00                          | 247.0                         | 0.25         | 510.0                |                   |                  |
| 18-Mar-14 | 3927 Melrose              |                   |                  | 0        | 0                | 6          | 7.28 | 0.02                          | 219.0                         | 0.22         | 453.0                |                   |                  |
| 24-Mar-14 | 3927 Melrose              |                   |                  | 0        | 0                | 7          | 6.98 | 0.00                          | 236.0                         | 0.24         | 488.0                |                   |                  |
|           | <b>Average</b>            | 0                 | 0                | 0        | 0                | 6.3        | 7.0  | 0.01                          | 235.0                         | 0.2          | 486.0                | 0.04              | 0.008            |
|           | <b>Maximum</b>            | 0                 | 0                | 0        | 0                | 7          | 7.28 | 0.02                          | 247                           | 0.25         | 510                  | 0.04              | 0.008            |
|           | <b>Minimum</b>            | 0                 | 0                | 0        | 0                | 6          | 6.6  | 0                             | 219                           | 0.22         | 453                  | 0.04              | 0.008            |

**Red font indicates non-compliance with Canadian Drinking Water Guidelines**

Aesthetic Objective for Iron is ≤0.3 mg/L

Aesthetic Objective for Manganese is ≤0.05mg/L

\*Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Yellow Column Coliform tests are completed by Health Department

Blue column tests are completed by RDN

**Comments:**

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.





# Regional District of Nanaimo - Water Services Department

## Melrose Terrace Water Analysis - 2014 Monthly Report



| Date      | Sample Location (Address) | Health Department |                  | In-House |                  |            |      |                               |                               |              |                      |                   |                  |
|-----------|---------------------------|-------------------|------------------|----------|------------------|------------|------|-------------------------------|-------------------------------|--------------|----------------------|-------------------|------------------|
|           |                           | E. coli *         | Total Coliform * | E.coli * | Total Coliform * | Temp. (°C) | pH   | Free Chlorine Residual (mg/L) | Total Dissolved Solids (mg/L) | Salinity (%) | Conductivity (µS/cm) | Total Iron (mg/L) | Manganese (mg/L) |
| 3-Feb-14  | 3927 Melrose              | 0                 | 0                | 0        | 0                | 8          | 7.03 | 0.05                          | 237.0                         | 0.24         | 489.0                | 0.11              | 0.019            |
| 11-Feb-14 | 3927 Melrose              |                   |                  | 0        | 0                | 8          | 6.68 | 0.06                          | 230.0                         | 0.23         | 476.0                |                   |                  |
| 18-Feb-14 | 3927 Melrose              |                   |                  | 0        | 0                | 8          | 6.89 | 0.05                          | 234.0                         | 0.23         | 485.0                |                   |                  |
|           |                           |                   |                  |          |                  |            |      |                               |                               |              |                      |                   |                  |
|           |                           |                   |                  |          |                  |            |      |                               |                               |              |                      |                   |                  |
|           | <b>Average</b>            | 0                 | 0                | 0        | 0                | 8.0        | 6.9  | 0.05                          | 233.7                         | 0.2          | 483.3                | 0.11              | 0.019            |
|           | <b>Maximum</b>            | 0                 | 0                | 0        | 0                | 8          | 7.03 | 0.06                          | 237                           | 0.24         | 489                  | 0.11              | 0.019            |
|           | <b>Minimum</b>            | 0                 | 0                | 0        | 0                | 8          | 6.68 | 0.05                          | 230                           | 0.23         | 476                  | 0.11              | 0.019            |

**Red font indicates non-compliance with Canadian Drinking Water Guidelines**

Aesthetic Objective for Iron is ≤0.3 mg/L      Aesthetic Objective for Manganese is ≤0.05mg/L

\*Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Yellow Column Coliform tests are completed by Health Department

Blue column tests are completed by RDN

**Comments:**

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.



# Regional District of Nanaimo - Water Services Department

## Melrose Terrace Water Analysis - 2014 Monthly Report



| Date      | Sample Location (Address) | Health Department |                  | In-House |                  |            |      |                               |                               |              |                      |                   |                  |
|-----------|---------------------------|-------------------|------------------|----------|------------------|------------|------|-------------------------------|-------------------------------|--------------|----------------------|-------------------|------------------|
|           |                           | E. coli *         | Total Coliform * | E.coli * | Total Coliform * | Temp. (°C) | pH   | Free Chlorine Residual (mg/L) | Total Dissolved Solids (mg/L) | Salinity (%) | Conductivity (µS/cm) | Total Iron (mg/L) | Manganese (mg/L) |
| 6-Jan-14  | 3927 Melrose              | 0                 | 0                | 0        | 0                | 7          | 7.06 | 0.00                          | 227.0                         | 0.23         | 468.0                | 0.08              | 0.010            |
| 13-Jan-14 | 3927 Melrose              |                   |                  | 0        | 0                | 8          | 7.07 | 0.04                          | 235.0                         | 0.23         | 485.0                |                   |                  |
| 20-Jan-14 | 3927 Melrose              |                   |                  | 0        | 0                | 7          | 7.08 | 0.03                          | 239.0                         | 0.24         | 495.0                |                   |                  |
| 29-Jan-14 | 3927 Melrose              |                   |                  | 0        | 0                | 8          | 7.01 | 0.02                          | 241.0                         | 0.24         | 499.0                |                   |                  |
|           | <b>Average</b>            | 0                 | 0                | 0        | 0                | 7.5        | 7.1  | 0.02                          | 235.5                         | 0.2          | 486.8                | 0.08              | 0.01             |
|           | <b>Maximum</b>            | 0                 | 0                | 0        | 0                | 8          | 7.08 | 0.04                          | 241                           | 0.24         | 499                  | 0.08              | 0.01             |
|           | <b>Minimum</b>            | 0                 | 0                | 0        | 0                | 7          | 7.01 | 0                             | 227                           | 0.23         | 468                  | 0.08              | 0.01             |

**Red font indicates non-compliance with Canadian Drinking Water Guidelines**

Aesthetic Objective for Iron is ≤0.3 mg/L

Aesthetic Objective for Manganese is ≤0.05mg/L

\*Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Yellow Column Coliform tests are completed by Health Department

Blue column tests are completed by RDN

**Comments:**

Iron and manganese are found naturally in drinking water. Levels found in these samples are not a health concern.

**APPENDIX C**

**EMERGENCY RESPONSE PLAN**

# EMERGENCY RESPONSE PLAN

REGIONAL DISTRICT  
OF NANAIMO

WATER SYSTEMS

This page is intentionally blank.

## Contents

|  |        |
|--|--------|
| <b>Prime Responsibilities</b>                      | 1      |
| <b>Emergency Response and Recovery Actions</b>     | 1      |
| <b>Communication Checklist</b>                     | 2      |
| - RDN Priority Contacts                            | 2      |
| - Key Communication Options                        | 2      |
| <b>Emergency Contact Numbers</b>                   | 3-7    |
| <b>Emergency Response Plans</b>                    | 8      |
| - Contamination of Source (incl. Turbidity events) | 8      |
| - Loss of Source                                   | 8      |
| - Broken Water Main                                | 9      |
| - Chlorination Failure                             | 9      |
| - Pump Failure                                     | 9      |
| - Power Failure                                    | 10     |
| - Backflow or Back Siphonage                       | 10     |
| - Bacteria Count (RDN Lab)                         | 10     |
| - Flood Conditions                                 | 11     |
| <b>Appendices</b>                                  |        |
| - Boil Water Notice                                | 13     |
| - Boil Water Info for the General Public           | 14-26  |
| - Boil Water Order                                 | 27     |
| - Unfit for Drinking Notice                        | 28     |
| - Service Interruption Notice                      | 29     |
| - Decision Tree for Responding to Turbidity Event  | 30     |
| <b>Maps-Water Service Areas</b>                    |        |
| - Nanoose Bay Peninsula                            | Map 1  |
| - Madrona Pt/Wall Beach Neighbourhood              | Map 2  |
| - Fairwinds Neighbourhood                          | Map 3  |
| - Arbutus Park Neighbourhood                       | Map 4  |
| - West Bay Neighbourhood                           | Map 5  |
| - Driftwood Neighbourhood                          | Map 6  |
| - French Creek                                     | Map 7  |
| - Surfside   | Map 8  |
| - San Pareil                                       | Map 9  |
| - Englishman River                                 | Map 10 |
| - Melrose  | Map 11 |
| - Decourcey  | Map 12 |
| - Whiskey Creek                                    | Map 13 |
| - Descanso Bay Reg. Park                           | Map 14 |
| - Horne Lake Reg. Park Water System                | Map 15 |
| - Rollo McClay Community Park Water System         | Map 16 |



## Prime Responsibilities

- Provide safe drinking water.
- Provide potable water for sanitation purposes.
- Provide water for fire suppression.
- Prevent unnecessary loss of stored water.
- Restore the integrity of the entire water system as soon as possible.
- Maintain integrity and quality of supply.

## Emergency Response and Recovery Actions

- Analyze the type and severity of the emergency.
- Provide emergency assistance to save lives.
- Reduce the probabilities of additional injuries or damage.
- Provide situational reporting to appropriate agencies as required.
- Perform emergency repairs based on priority demand.
- Return system to normal levels. (recovery)
- Evaluate response and preparedness plan.
- Revise plan as necessary.
- Provide maps, notices, and direction necessary for water recovery.

## Communication Checklist

In an emergency it will be important to contact the key people shown below. This will help reduce confusion and assist in ensuring any important messaging is done so correctly and quickly.

**IF REQUIRED, CONTACT E.M.B.C. (formerly P.E.P.) or V.I.H.A. BEFORE MAKING THE FOLLOWING CONTACTS AS PER THE EMERGENCY PLANS**

## RDN Priority Contacts

MANAGER OF WATER SERVICES

MIKE DONNELLY  
(250) 390-6560

MGR. REGIONAL & COMMUNITY UTILITIES

RANDY ALEXANDER  
(250) 390-6560

COMMUNICATIONS COORDINATOR

ADRIENNE MERCER  
(250) 390-4111

EMERGENCY COORDINATOR

JANI DREW  
cell (250) 713-2057

## Key Communication Options

### Management Support

- Contact Electoral Area Director
- Contact the local radio station and provide a brief message if public health and safety are at risk. Follow up with a press release.

### Field Staff Support

- Post notices on household front doors.
- Attach warning signs to existing Water Sprinkling Regulation signs in each community.
- Put up roadside signage at the entrance to the community.

### Administrative Support

- Provide information message on the RDN web site & social media.
- Review after hours office and voice mail messaging.
- Provide notification to other RDN staff.

## Emergency Contact Numbers

### Personnel Contacts

| <i>Name</i>       | <i>Position</i>  | <i>Phone / Cell</i> |
|-------------------|--|---------------------|
| Dave Welz         | Chief Operator   | (250) 927-0295      |
| Heather Dorken    | Operator III   | (250) 927-1452      |
| Brian Hale        | Operator III   | (250) 951-8354      |
| Randy Stearman    | Operator II  | (250) 927-1178      |
| Brad Lancaster    | Operator II  | (250) 927-1849      |
| Lyndon Jaworski   | Operator II  | (250) 954-8351      |
| Greg Roberts      | Operator II  | (250) 927-1902      |
| Mike Donnelly     | Manager of Water Services                                | (250) 713-7169      |
| Gerald St. Pierre | Project Engineer, Water Services                         | (250) 713-6957      |
| Deb Churko        | Engineering Technologist                                 | (250) 390-6546      |
| Jack Eubank       | Bylaw Officer<br><i>(Emerg. Coord. Alternate- 24hrs)</i> | (250) 713-4872      |
| Brian Brack       | Bylaw Officer<br><i>(Emerg. Coord. Alternate- 24hrs)</i> | (250) 714-3987      |

## Electoral Area Directors

| <b>Electoral Area</b> | <b>Director</b> | <b>Phone</b> | <b>E-mail Address</b>     |
|-----------------------|-----------------|--------------|---------------------------|
| A                     | Alec McPherson  | 722-9472     | alecmcpherson@shaw.ca     |
| B                     | Howard Houle    | 247-8250     | howardhoule@yahoo.ca      |
| C                     | Maureen Young   | 754-5896     | maureen_young@shaw.ca     |
| E                     | Bob Rogers      | 468-9986     | bobrogers4areaE@telus.net |
| F                     | Julian Fell     | 248-4296     | fjfell.at.rdn@gmail.com   |
| G                     | Joe Stanhope    | 248-6401     | jstanhope@shaw.ca         |
| H                     | Bill Veenhof    | 797-6313     | bill.veenhof@shaw.ca      |

## Government Agency Contacts

|   |                           |   |
|---|---------------------------|---|
| Ministry of Environment   | Nanaimo                   | (250) 751-3100                          |
| Department of Fisheries and Oceans  | Nanaimo                   | (250) 754-0230                          |
| Emergency Management BC (E.M.B.C.)<br>and Dangerous Goods Spills (formerly PEP) | Victoria                  | 1-800-663-3456                          |
| Island Health Office (VIHA)   | Parksville                | (250) 947-8222                          |
| Island Health Office (VIHA)   | Nanaimo                   | (250) 755-6215                          |
| Murray Sexton, Public Health Engineer   | Nanaimo                   | (250) 755-6293                          |
| Medical Health Officer  | Nanaimo<br>or after hours | (250) 740-6988<br>1-800-204-6166        |
| City of Parksville<br>Chief Operator, Scott Churko                              | Parksville                | (250) 248-5412<br>(250) 927-1856 (cell) |
| Town of Qualicum Beach  | Qualicum Beach            | (250) 752-6921                          |
| District of Lantzville<br>Superintendent, Fred Spears                           | Lantzville                | (250) 390-4006<br>(250) 713-0980 (cell) |
| North Cedar Improvement District  | Cedar                     | (250) 722-3711                          |
| Islands Trust Organization (Main office)  | Gabriola Isl              | (250) 247-2063                          |
| Trustee Sheila Malcolmson   | Gabriola Isl              | (250) 247-8078                          |
| Trustee Gisele Rudischer  | Gabriola Isl              | (250) 247-8795                          |

## Emergency Services

|                 |                 |                               |
|-----------------|-----------------|-------------------------------|
| Hospital        | Nanaimo         | (250) 754-2141                |
|                 | Parksville ph.  | (250) 248-2332 (Nan hospital) |
|                 | Oceanside Ctr   | (250) 951-9550                |
|                 | Gabriola Clinic | (250) 247-9922                |
| Ambulance       | Nanaimo         | 911 or (250) 758-8181         |
|                 | Parksville      | 911 or (250) 248-3511         |
| Police          | Nanaimo         | 911 or (250) 754-2345         |
|                 | Parksville      | 911 or (250) 248-6111         |
|                 | Gabriola Isl    | 911 or (250) 247-8333         |
| Fire Department | Parksville      | 911 or (250) 248-3242         |
|                 | Coombs-Hilliers | 911 or (250) 752-2144         |
|                 | Nanoose Bay     | 911 or (250) 468-7141         |
|                 | Qualicum Beach  | 911 or (250) 752-6921         |
|                 | Cedar           | 911 or (250) 722-3122         |
|                 | Gabriola Isl    | 911 or (250) 247-5601         |

## Priority Services

|   |                            |
|---|----------------------------|
| BC Hydro (Qualicum Beach number)                  | (250) 752-8012 or          |
| BC Hydro (Power Outages & Electrical Emergencies) | 1-888-769-3766             |
| Telus   | (250) 811-2323 or          |
| Telus (Paul McGrath cell 248-0983)                | (250) 741-7713 or 741-7716 |
| FortisBC (Teresen Gas)                            | (250) 248-4880             |
| Shaw Cable (Nanaimo)                              | (250) 754-5571             |
| CP Rail   | 1-800-716-9132             |
| French Creek Pollution Control Centre             | (250) 248-5794             |
| Chlorine Manufacturer (Brentagg)                  | 1-800-661-1830             |

## Community Contacts

|  |                              |
|--|------------------------------|
| District 69 School Board Office              | (250) 248-4241               |
| Nanoose Bay School                           | (250) 468-7414               |
| Nanoose Children's Centre                    | (250) 468-1784               |
| Nanoose Place                                | (250) 468-5339               |
| Nanoose Post Office                          | (250) 468-7722               |
| Canadian Forces Base Nanoose                 | (250) 756-5021 or 468-5004   |
|  | or                           |
| Descanso Bay Reg Park Operator- Jim Demler   | (250) 468-2260 (MP Stn-24hr) |
| Horne Lake Reg Park Operator- Bill Woodhouse | (250) 751-5887               |
|  | (250) 927-4790               |

## Excavation Services

|   |                            |
|---|----------------------------|
| Shoreline Equipment (Doug Penny)          | (250) 468-7759 or 755-9502 |
| Rite on Time Excavation & Trucking (Cody) | (250) 927-1645             |
| Degnen Excavators (Gabriola Isl)          | (250) 247-8817             |

## Electrical Contractors

|   |                            |
|---|----------------------------|
| Canem Electric                          | (250) 468-1887             |
| HPS Power Ltd. (Harvey Sommerfeld)      | (250) 954-7463             |
| TC Trades (Tom Frenette)                | (250) 756-0077 or 668-0078 |
| Ron Ruckman (Descanso Bay/Gabriola Isl) | (250) 247-0050             |

## Other Services

|  |                            |
|--|----------------------------|
| Plumbing Services (Maci Motor – Pump Repair)           | (250) 248-4423             |
| JC Plumbing (Descanso Bay/Gabriola Isl)                | (250) 247-7574 or 713-6700 |
| EPCOR (Parksville)                                     | (250) 951-2460             |
| Sand and Gravel (Ozero)                                | (250) 752-1482             |
| Sand and Gravel (Lussier & Sons)                       | (250) 468-9994             |
| Sand and Gravel (Porter Wood)                          | (250) 248-3693             |
| EMCON Road Maintenance (Gabriola Isl)                  | (250) 247-9420             |
| EMCON (Parksville) After Hours Emerg 1-866-353-3136 or | (250) 248-6212             |



## Other Services

|   |                       |
|---|-----------------------|
| Pump Trucks (Action Tank Service)             | (250) 248-3833        |
| Pump Trucks and Toilet Rentals (A-1 Septic)   | (250) 248-4438        |
| Portable Washrooms (Coast Toilet Rentals)     | (250) 753-7552        |
| Bulk water supply (BC Water Service)          | (250) 954-3628        |
| Bottled water supply (Water Pure & Simple)    | (250) 752-1373        |
| Island H2O Services                           | (250) 754-4721        |
| Summer Rain Water Delivery (Gabriola Isl)     | (250) 247-9136        |
| Kalicum Drilling                              | (250) 245-1220        |
| Red Williams (Water Hauling Service)          | (250) 947-5197 (Mark) |
| RDN- Use our own water hauling tank and truck | (250) 248-4914        |

## Suppliers

|   |                |
|---|----------------|
| Four Star Waterworks (piping)                         | (250) 954-3546 |
| EMCO Water Works                                      | (250) 756-3344 |
| Corix Water Products                                  | (250) 746-8877 |
| Andrew Sheret (Parksville)                            | (250) 954-9997 |
| Andrew Sheret (Nanaimo)                               | (250) 758-7383 |
| Hwy Four Rentals (equipment & pumps)                  | (250) 248-1100 |
| Irritex Pumps and Irrigation – (pumps)                | (250) 248-7028 |
| Windsor Plywood (miscellaneous building supplies)     | (250) 752-3122 |
| Albertsons Hardware (miscellaneous building supplies) | (250) 248-6888 |
| Robinson Rentals                                      | (250) 753-2465 |
| United Rentals  | (250) 758-3911 |

## Media Services

|   |                            |
|---|----------------------------|
| Adrienne Mercer, RDN Communications Coordinator | 1-877-607-4111 or 713-1075 |
| Radio Station (CKWV) Nanaimo and Parksville     | (250) 758-1131             |
| TV Station (CHEK)                               | (250) 383-2435             |
| Newspaper (PQ News and The Weekender)           | (250) 248-4341             |
| Nanaimo Daily News / Harbour City Star          | (250) 729-4212             |
| Gabriola Sounder                                | (250) 247-9337             |

## Emergency Response Plans

### Contamination of Source (Turbidity Events over 1 NTU, Spills, Accidents, Vandalism)

#### Actions:

- Notify Island Health Officer (VIHA) (Ph. 250-947-8222 or after-hours Medical Health Officer at 1-800-204-6166)
- Shut down pump
- Notify E.M.B.C. (Emergency Management BC) (formerly PEP)
- Notify all users if necessary under direction of Health Unit
- Contact government agencies for advice and assistance
- Contact local media for public service announcements
- Post signs and deliver notices to homes and businesses. (See attached samples)
- Arrange alternate source if necessary – i.e., bottled or bulk water
- Advise RDN supervisory personnel
- Advise local fire dept not to use fire hydrants

#### Contacts:

- Island Health Office (VIHA)
- E.M.B.C. (Emergency Management BC) (formerly PEP), RCMP
- Ministry of Environment
- All schools and community centers – see “*Priority Contacts*” List
- RCMP if there has been vandalism

### Loss of Source (Loss Of Reservoir or Supply Lines)

#### Actions:

- Ensure pumps are shut off. (To protect pump)
- Notify all users
- Contact government agencies for advice and assistance
- Arrange alternate source – i.e., bottled water, bulk water, storage tank
- Advise RDN supervisory personnel if necessary

#### Contacts:

- Island Health Office (VIHA) and Ministry of Environment

## Emergency Response Plans Cont'd

### Broken Water Main

Actions:

- Shut pump off when backflow conditions have been prevented
- Call for repairs as required – i.e. excavator, backhoe
- Notify all users of interruption of service
- Advise Island Health Officer (VIHA)
- Arrange alternate source if necessary
- Advise RDN supervisory personnel

Contacts:

- Island Health Office (VIHA)

### Chlorination Failure

Actions:

- Advise Island Health Officer (VIHA)
- Shut off well pumps. Monitor reservoir levels.
- Notify all users to boil water for two minutes or take other disinfection procedures in accordance with recommendations of local health officials
- Post signs or deliver notices if necessary. (See attached samples)
- Arrange chlorinator repairs
- Arrange for alternate disinfection if necessary
- Advise RDN supervisory personnel

Contacts:

- Island Health Office (VIHA)
- Chlorinator manufacturer

### Pump Failure

Actions:

- Notify all users of interruption of service
- Call for repairs: pump manufacturer if necessary
- Advise Island Health Officer (VIHA) (if interruption is not short term)
- Arrange alternate source if necessary – bottled or bulk water, etc.
- Advise RDN supervisory personnel if necessary

Contacts:

- Island Health Office (VIHA)

## Emergency Response Plans Cont'd

### Power Failure

Actions:

- Call BC Hydro. Find out when power will be restored
- Start back-up generator or arrange to get one
- Notify all users about interruption of service if backup not capable of maintaining supply
- Post signs or deliver notices if necessary. (See attached samples)
- Advise Island Health Officer (VIHA)
- Arrange alternate source if necessary – bottled or bulk water, etc.
- Arrange for alternate disinfection at Descanso Bay and Horne Lake Reg Parks
- Advise RDN supervisory personnel

Contacts:

- Island Health Office (VIHA)

### Backflow or Back Siphonage

Actions:

- Advise Medical Health Officer at Island Health Office (VIHA)
- Notify all users to boil water for two minutes or take other disinfection procedures in accordance with recommendations of local health officials. (See attached samples)
- Purge and disinfect lines as directed, after corrections have been made
- Post signs or deliver notices if necessary. (See attached samples)
- Advise RDN supervisory personnel

Contacts:

- Island Health Office (VIHA)

### Bacteria Count (RDN Lab)

Actions:

- Advise Medical Health Officer Island Health Office (VIHA)
- Follow procedures in accordance with recommendations of local health officials
- Post signs or deliver notices if necessary. (See attached samples)
- Check if UV unit is working at Descanso Bay Reg Park, clean the UV bulb
- Arrange for alternate disinfection at Descanso Bay Reg Park if the UV unit is not working
- Advise RDN supervisory personnel

Contacts:

- Island Health Office (VIHA)

## Emergency Response Plans Cont'd

### Flood Conditions:

#### Actions:

- Notify Island Health Officer (VIHA) (Ph. 250-947-8222 or after-hours Medical Health Officer at 1-800-204-6166)
- Notify all users regarding the potential for water contamination, loss of pump, power, etc, Users should be advised to store some drinking water in advance, and to boil any suspect water for two minutes or disinfect with chlorine when flood conditions exist
- Phone government contacts
- Contact local media for public service announcement when customers can not be reached by phone
- Post signs or deliver notices if necessary. (See attached samples)
- Arrange alternate source if possible – i.e. bottled water, bulk hauler or storage tank
- Advise RDN supervisory personnel

#### Contacts:

- Island Health Office (VIHA), E.M.B.C. (Emergency Management BC) (formerly PEP), and Ministry of Environment

## APPENDICES

|   |       |
|---|-------|
| Boil Water Notice                               | 13    |
| Boil Water Info for the General Public          | 14-26 |
| Boil Water ORDER                                | 27    |
| Unfit for Drinking Notice                       | 28    |
| Service Interruption Notice                     | 29    |
| Decision Tree for Responding to Turbidity Event | 30    |



**SAMPLE**

# BOIL WATER NOTICE

**Effective date:** \_\_\_\_\_

Please note that all water used for domestic purposes (drinking, cooking, etc.) should be boiled before consumption. The boiling should be at a rolling boil and for a minimum of one minute.

RDN Water Services staff are continually monitoring the water supply system and will provide updates as they become available.

Watch for information updates at [www.rdn.bc.ca](http://www.rdn.bc.ca) (Water Services) and listen to your local radio station for more information.

This notice will be in effect until further notice.

For further information contact the

**Regional District of Nanaimo at:  
1-877-607-4111 or 1-250-390-4111  
Water Services Field Office: 1-250-248-4914**

**BOIL WATER NOTICE INFORMATION FOR THE GENERAL PUBLIC  
DURING A BOIL WATER NOTICE CAUSED BY:  
INADEQUATE DISINFECTION**

This information is provided as a guide to help individuals reduce the risk of becoming ill from ingesting non-potable water. Individuals who follow these guidelines will greatly reduce their chance of becoming ill.

**What is a Boil Water Notice?**

A Boil Water Notice is a public announcement advising water system users that they should boil their tap water for drinking and other domestic purposes. It is a notice intended to protect the Publics' health from waterborne infectious agents that could be present or are known to be present in the community's drinking water supply.

**What is the difference between a Boil Water Notice and a Boil Water Order?**

A Boil Water Notice is a notice issued to the public as a health warning. In most cases it is the water supplier who notifies the public.

A Boil Water Order is legal document issued to the water supplier by the Health Authority requiring the water supplier to notify the public of a boil water notice.

**What are the health risks during a Boil Water Notice?**

The health risks are associated with ingesting water that contains microbiological agents that can cause disease. These pathogenic (disease causing) agents could include *Giardia*, *Cryptosporidia*, *E. coli*, *Campylobacter*, *Salmonella* and *Hepatitis A*. Boiling tap water for one minute is sufficient to destroy pathogens that could be present in the water.

There are numerous factors that influence whether a person becomes ill. First, there must be pathogens present in the water you consume. Not every glass of water is likely to contain pathogens. Even if the water you consume contains pathogens, those pathogens that are present must be viable. That is, they must be in a state where they can cause an illness and they must be present in large enough numbers to cause an illness. The number of pathogens needed to cause illness depends on the type of pathogen present, a person's size, age, and immune status.

The incubation period (time for symptoms to develop) will vary depending on the type of pathogen. For example, Giardia (beaver fever) could take up to four weeks to develop symptoms whereas E. coli could take up to ten days and as little as two days. For more information on waterborne diseases go to the following BC Health File;

<http://www.bchealthguide.org/healthfiles/hfile49a.stm>

Any persons believing that they are ill should see their doctor. Patients are sometimes requested to submit samples for laboratory analysis to assist in waterborne outbreak investigations.

It is important to note that Boil Water Notices are specific to microbiological threats. They are not appropriate to address threats from chemical contamination. Boiling chemically contaminated water will only result in the chemical becoming more concentrated or release the chemical into the air where it could be inhaled.

When there is a threat to a water supply from a chemical contaminated a more appropriate public health notice of "Do Not Drink the Water" would be issued.

### **What am I trying to kill when I'm boiling the water?**

Boiling water is recommended to kill pathogenic microbes that may be present in contaminated water. Bacteria such as *E. coli* and *Salmonella* are killed rapidly at temperatures over 60°C and a temperature of 72.4°C for 1 minute is needed to inactivate cryptosporidium. *Hepatitis A* and *Norovirus* are rapidly inactivated at temperatures above 65°C.

Based on the above information there is no need to boil water for prolonged periods of time. Although heating water to boiling is not needed it is the only end point easily recognized by the public without the use of thermometers. It is therefore recommended that the public bring the water to a rolling boil for one minute to ensure that all pathogens have been inactivated.

One minute should be added to the above boiling times if the water is cloudy or highly colored to ensure proper mixing and that all pathogens have been exposed to the high temperature. When boiling water at altitudes above 2000m (6,500 ft), water should be boiled for 2 minutes.

### **How can the water become contaminated?**

The water can become contaminated in a variety of ways. Some of these include:

- Heavy rainfall can wash contaminants into the water source
- Accidental spills in the water supply
- Breakdown of the disinfection process
- Break in water supply mains
- Vandalism
- Connections within the water system between potable and non-potable piping.

**Is it necessary to boil all the water in the home during a boil water notice?**

No, it is not necessary to boil all your water. Water used for bathing, showering, laundry, toilet flushing and mopping of floors does not need to be boiled. During bathing, young children should be cautioned against swallowing the bath water or alternatively young children could be sponge bathed.

All other water should be boiled. Simply put, any water that has a chance of being ingested should be boiled. This would include water used for drinking, beverage concentrates, ice cubes, washing fruits and vegetables, or brushing teeth.

Severely immune-compromised individuals should always boil their tap water for the purposes above. See the link to BC Health Files number 56, December 2003.

<http://www.bchealthguide.org/healthfiles/hfile56.stm>.

Infant formulas should always be prepared by using boiled tap water or bottled water that is boiled. See the link to BC Health Files number 69b, May 2006.

<http://www.bchealthguide.org/healthfiles/hfile69b.stm>.

Drinking water for pets including dogs, cats, birds and reptiles should also be boiled.

**How should tap water be boiled properly?**

Tap water should be boiled for at least one minute. Use any clean pot or kettle. Kettles that have automatic shut offs are acceptable.

**How should tap water be boiled properly? (continued)**

Health Canada suggests that microwave ovens can also be used using microwave-safe containers but cautions against forming superheated water (water heated above its boiling point without the formation of steam). When using microwaves, Health Canada suggests inserting a glass rod, wooden or plastic spoon in the container to prevent forming superheated water.

After boiling, let the water cool by leaving it on the counter or in the refrigerator in covered containers. Once the water is boiled, it can be stored in food grade containers at room temperature or in the refrigerator.

Shaking the water in the container or pouring the water between two containers and/or adding a pinch of salt can bring back flavor after boiling.

**Are there alternatives to boiling water?**

Yes, there are. Although there are alternatives, not all of them will be feasible or practical in all situations. In part, it will depend on how much water you need and what you need it for. Safe alternatives to boiling water include:

- Using commercially prepared bottled water
- Obtaining water from an approved source that is not on a boil water notice, or
- Using bleach to disinfect small quantities of tap water. See the following chart or website for a guide to using bleach.

<http://www.bchealthguide.org/healthfiles/hfile49b.stm>

Disinfection using unscented household bleach (5% chlorine) works best with warm water. Add bleach to the water, shake or stir for thorough mixing and then let it stand for at least 30 minutes before drinking.



| Gallons of water to disinfect<br>(equivalent shown in brackets) | Amount of Household bleach (5%)<br>to add* |
|---|--|
| 1 gal. (4.5 litres)   | 2 drops (0.18 mL)                          |
| 2 ½ gal. (10 litres)  | 5 drops (0.4 mL)                           |
| 5 gal. (23 litres)  | 11 drops (0.9 mL)                          |
| 10 gal. (45 litres)   | 22 drops (1.8 mL)                          |
| 22 gal. (100 litres)  | ¾ teaspoon (4 mL)                          |
| 45 gal. (205 litres)  | 1 ½ teaspoons (8 mL)                       |
| 50 gal. (230 litres)  | 1 ¾ teaspoons (9 mL)                       |
| 100 gal. (450 litres)   | 3 ½ teaspoons (18 mL)                      |
| 220 gal. (1000 litres)  | 8 teaspoons (40 mL)                        |
| 500 gal. (2200 litres)  | 6 tablespoons (90 mL)                      |
| 1000 gal. (4550 litres)   | 6 ½ ounces or 12 tablespoons (180 mL)      |

A slight chlorine odour should still be noticeable at the end of the 30-minute waiting period if you have added enough bleach. If not, repeat the dosage and allow the water to stand an additional 15 minutes. If the water has too strong a chlorine taste, allow the water to stand exposed to the air for a few hours or pour it from one clean container to another several times.

The disinfection action of bleach depends as much on the waiting time after mixing as to the amount used. The longer the water is left to stand after adding bleach, the more effective the disinfection process will be.

**NOTE: Bleach does not work well in killing off *Cryptosporidium* parasites.**

The amount of bleach needed to kill *Cryptosporidium* makes the water almost impossible to drink. If *Cryptosporidium* is in the water, boiling is the best way to ensure that the water is safe to drink.

### **I have my own water treatment device do I still need to boil my water?**

If the device is designed to improve taste or reduce odour such as an activated carbon filter the answer is **YES** you should still boil your water.

If the device is designed to improve the chemical quality of the water such as reducing the iron content then the answer is **YES** you should still boil your water.

If the device is designed to improve water that is already potable the answer again is **YES** you should still boil your water.

There are numerous filters on the market designed to remove microorganisms and particulates. Most of these filters are not capable of removing viruses. Therefore, you should boil your water if you have a unit that cannot remove viruses.

If the device is designed to disinfect (destroy pathogens) water such as in an ultraviolet light (UV) disinfection unit you **might not** need to boil your water. There are numerous ultraviolet units; some are designed to disinfect raw water and some are designed to disinfect water that has already been disinfected at a central facility. For example, if the unit is classified by the National Sanitation Foundation (NSF) as meeting NSF Standard 55 Class A, it is designed to disinfect raw water. However, if the water within the distribution system is too turbid or cloudy, even a UV unit meeting NSF Standard 55 Class A may not work properly and you should still boil your water.

Reverse osmosis (RO) units are designed to filter water at the molecular level and should provide water that is free of pathogens. Thus, you **do not** have to boil your water if you have a reverse osmosis water treatment device.

There are many types of units on the market each designed to address specific water quality issues. It is recommended that you check with the unit's manufacturer to know exactly what your unit can do.

### **Can I purchase water from vending machines?**

It depends on how the water is treated. Local vending machines that use local water would only be acceptable if the vending machine can kill pathogens that might be present in the water. Check with the store or manufacturer to see if the unit is capable of providing water that is safe to drink.

Warning signs should be posted on vending units that are not capable of providing safe water. Alternatively, the machine should be turned off.

### **Are there any people or groups of people at higher risk?**

Yes. These people include any individual whose immune system is not fully developed or whose immune system is under stress such as infants, the elderly, immune compromised individuals and individuals already suffering from an illness. For more information go to the following BC Ministry of Health websites:

BC Health File: weakened immune systems

<http://www.bchealthguide.org/healthfiles/hfile56.stm>.

BC Health File: preparing infant formula

<http://www.bchealthguide.org/healthfiles/hfile69b.stm>.

### **Boil water or provide an alternative safe supply of water that is used for:**

- Drinking purposes- This includes all beverage concentrates such as fruit juice and iced tea
- Food preparation- This includes washing of fruits and vegetables
- Food contact surfaces

**Boil water or provide an alternative safe supply of water that is used for:  
(continued)**

Food contact surfaces are all those surfaces that food comes into contact with during the food preparation process. These surfaces include counter tops, cutting boards and chopping blocks. Food contact surfaces should be washed with clean water and then sanitized using an acceptable sanitizing agent. Sanitizing agents for food contact surfaces include bleach (12-15 mL of 5% bleach per litre of water), iodophors, quaternary ammonia compounds or hydrogen peroxide (3% solution).

- Oral hygiene (brushing teeth)
- Infant formula; see BC Health File; preparing infant formula at <http://www.bchealthguide.org/healthfiles/hfile69b.stm>.
- Ice making

It is important to note that freezing does not destroy most pathogens. Bacteria and viruses can survive in frozen products for long periods of time. Discard any ice made from contaminated or potentially contaminated water.

### **Hand washing**

Using warm water and soap should be sufficient. Applying a hand sanitizer after washing with tap water would add an extra barrier of protection.

### **Dishwashing by hand**

Dishes washed by hand should be sanitized for two minutes in a separate sink using a bleach solution (2 mL of bleach per litre of water) after the dishes have been washed and rinsed. The dishes should then be left to **air dry** prior to being used. Attempting to wash and sanitize dishes in the same sink at the same time is not recommended because soap, grease and food particles interfere with the sanitizing process.

### **Mechanical dishwashers**

Most residential home-style dishwashers do not provide a high enough temperature to kill all pathogens. Dishwashing units that reach 82 degrees Celsius (180 Fahrenheit) for twelve seconds (or an equivalent time-temperature relationship) during the final rinse cycle will destroy pathogens.

To optimize the disinfection process while using a residential dishwasher you should consider:

1. Using the highest temperature setting possible.
2. Running dishes through the dishwasher twice.
3. Sanitizing dishes afterwards in a sink containing a weak bleach solution (see dishes washed by hand above).
4. Letting the dishes air dry prior to use

### **Fruit and vegetable washing**

Thoroughly wash all produce with potable water especially those that are going to be eaten raw. This is a common sense practice that should be applied even when there is no public boil water notice.

### **Coffee Machines**

Coffee machines usually produce water around 70 to 80 degrees Celsius, which is sufficient to destroy pathogens. However, a sufficient amount of time is needed to ensure that all harmful organisms are destroyed. Therefore, let the coffee stand for at least five minutes before drinking.

### **Home canning**

To be safe, postpone home canning until the boil water notice has been rescinded.

### **Beer and wine making**

To be safe, postpone beer and wine making until the boil water notice has been rescinded.

### **When will the Boil Water Notice be rescinded?**

Only when the water supplier can provide potable water will the Health Authority rescind the Boil Water Notice. Once or more of the following usually achieves confirmation that the water is once again safe to drink.

These include:

- Identifying and fixing the source or sources of the problem,
- Implementing procedures to eliminate or reduce the chance for reoccurrence
- Performing water quality tests
- Flushing and disinfecting distribution lines and water storage facilities

### **Precautions to consider when the Boil Water Notice is lifted**

- Flush all water-using fixtures for 1 minute
- Run cold-water faucets and drinking fountains for 1 minute before using water
- Drain and flush all ice-making machines in your refrigerator
- Run water softeners through a regeneration cycle
- Drain and refill hot water heaters set below 45 deg C (normal setting is 60 deg C)
- Change any pre-treatment filters (under sink style and refrigerator water filters, carbon block, activated carbon, sediment filters, etc.)

**Can I speak to a person in Public Health if I have a question about the Boil Water Notice?**

Yes you can. For further information contact Island Health Officers at the following locations:

- Victoria
- Nanaimo ph. 250-755-6215
- Parksville ph. 250-947-8222
- Courtenay
- Island Health Office 6475 Metral Drive, Nanaimo, BC
- Island Health Office 249 West Hirst Avenue, Parksville BC

After hours Medical Health Officer on call is 1-800-204-6166.

**Additional information can be found at the following BC, Canadian and US websites. These are:**

BC Health File; how to disinfect drinking water

<http://www.bchealthguide.org/healthfiles/hfile49b.stm>

BC Health File; weekend immune systems and water-borne infections

<http://www.bchealthguide.org/healthfiles/hfile56.stm>

BC Health File; waterborne disease in BC

<http://www.bchealthguide.org/healthfiles/hfile49a.stm>

BC Health File; cryptosporidiosis

<http://www.bchealthguide.org/healthfiles/hfile48.stm>

BC Health File; giardiasis

<http://www.bchealthguide.org/healthfiles/hfile10.stm>

BC Health File; safely preparing and storing baby formula

<http://www.bchealthguide.org/healthfiles/hfile69b.stm>



US EPA how to boil water and use bleach

<http://www.epa.gov/ogwdw000/faq/emerg.html>

US Centre for Disease Control; preventing cryptosporidiosis infection

<http://www.cdc.gov/ncidod/dpd/parasites/cryptosporidiosis/default.htm>

US Centre for Disease Control; Giardia fact sheet

[http://www.cdc.gov/ncidod/dpd/parasites/giardiasis/factsht\\_giardiasis.htm#prevention](http://www.cdc.gov/ncidod/dpd/parasites/giardiasis/factsht_giardiasis.htm#prevention)

US Centre for Disease Control; Preventing Cryptosporidium; a guide to water filters & bottled water

[http://www.cdc.gov/ncidod/dpd/parasites/cryptosporidiosis/factsht\\_crypto\\_prevent\\_water.htm](http://www.cdc.gov/ncidod/dpd/parasites/cryptosporidiosis/factsht_crypto_prevent_water.htm)

#### **Information sources for developing this package includes**

- BC Ministry of Health
- Health Canada
- Alberta Environmental Health
- Washington State Department of Health
- BC Centre for Disease Control
- US EPA (Environmental Protection Agency)
- US Center for Disease Control
- NSF (National Sanitation Foundation)
- DWO (Drinking Water Officer's) Guide

SAMPLE

# NOTICE

## Boil Water Order

**Effective date:** \_\_\_\_\_

Please note that all water used for domestic purposes (drinking, cooking, etc.) should be boiled before consumption. The boiling should be at a rolling boil and for a minimum of two minutes.

RDN Water Services staff are continually monitoring the water supply system and will provide updates as they become available.

Watch for information updates at [www.rdn.bc.ca](http://www.rdn.bc.ca) (Water Services) and listen to your local radio station for more information.

This order will be in effect until further notice.

For further information contact the

**Regional District of Nanaimo at:  
1-877-607-4111 or 1-250-390-4111  
Water Services Field Office: 1-250-248-4914**

**SAMPLE**

# WARNING

**This Water is  
Considered  
Unfit for Drinking  
or Domestic Use**

**Effective date:** \_\_\_\_\_

For further information contact the

**Regional District of Nanaimo at:**

**1-877-607-4111 or 1-250-390-4111**

**Water Services Field Office: 1-250-248-4914**

**SAMPLE**

# NOTICE

## Water Supply Service Interruption

**Effective date:** \_\_\_\_\_

Please be advised that your water service may be interrupted or off for periods during the day.


When service is resumed, the water may be discoloured. This is due to disturbed deposits in the pipes and is not harmful.

This Notice will be in effect until further notice.

For further information contact the

**Regional District of Nanaimo at:  
1-877-607-4111 or 1-250-390-4111  
Water Services Field Office: 1-250-248-4914**

Decision Tree for Responding to a Turbidity Event in Unfiltered Drinking Water




# MAPS

## Water Service Areas

|  |        |
|--|--------|
| Nanoose Bay Peninsula Water Service Area | Map 1  |
| Madrona Pt/Wall Beach Neighbourhood      | Map 2  |
| Fairwinds Neighbourhood                  | Map 3  |
| Arbutus Park Neighbourhood               | Map 4  |
| West Bay Neighbourhood                   | Map 5  |
| Driftwood Neighbourhood                  | Map 6  |
| French Creek Water Service Area          | Map 7  |
| Surfside Water Service Area              | Map 8  |
| San Pareil Water Service Area            | Map 9  |
| Englishman River Water Service Area      | Map 10 |
| Melrose Water Service Area               | Map 11 |
| Decourcey Water Service Area             | Map 12 |
| Whiskey Creek Water Service Area         | Map 13 |
| Descanso Bay Reg. Park Water System      | Map 14 |
| Horne Lake Reg. Park Water System        | Map 15 |
| Rollo McClay Community Park Water System | Map 16 |





MAP 1 NANOOSSE BAY  
PENINSULA









FAIRWINDS AREA OF NANOOSE BAY  
WATER SERVICE AREA  
(BL 867.02)


Legend

-  Service Area
-  Building and Address


3124








**MAP 4 ARBUS PAK**




**MAP 5 WEST BAY**





**MAP 6 DRIFTWOOD**



**MAP 7 FRENCH CREEK**




**SURFSIDE PROPERTIES WATER SERVICE AREA (BL 694)**


## Legend

Service Area


Building and Address








**MAP 9 SAN PAREIL**








MAP 11 MELROSE







**MAP 13 WHISKEY CREEK**

descanso bay regional park



MAP 14 DESCANSO BAY REG. PARK



horne lake regional park





