Appendix D:

Nanoose Bay Pollution Control Centre Upgrade Study



LIQUID WASTE MANAGEMENT PLAN AMENDMENT

This page is intentionally left blank



Regional District of Nanaimo

Nanoose Pollution Control Centre Upgrade Study -Report

Prepared by:

AECOM Canada Ltd. 1901 Rosser Avenue, Floor 6, Burnaby, BC, Canada V5C 6S3 T 604.298.6181 F 604.294.8597 www.aecom.com

Project Number:

114501

Date:

March 26, 2010

AECOM 1901 Rosser Avenue, Floor 6 Burnaby, BC, Canada V5C 6S3 www.aecom.com

604 298 6181 tel 604 294 8597 fax

March 26th, 2010

Project Number: 114501.03

Mr. Sean De Pol Manager of Wastewater Services Regional District of Nanaimo 6300 Hammond Bay Road Nanaimo, BC V9T 6N2

Dear Sean,

Re: Nanoose Pollution Control Center Upgrade Study - Report

In order to support the RDN in developing a strategic upgrade plan for the Nanoose Pollution Control Centre (NPCC), AECOM has reviewed past cost estimates and design reports prepared for the RDN as they relate to the optimization and upgrade of the NPCC to secondary treatment.

AECOM has with the help of the RDN gathered the most up-to-date plant performance, population growth, and future development information to put the upgrade to secondary treatment into the most relevant context. This report provides updated cost estimates for trunk sewers to connect the various service areas to the NPCC, as well as cost estimates to upgrade the NPCC to secondary treatment without increasing flow capacity. Several cost estimates have also been provided to upgrade the NPCC to secondary treatment and increase its service capacity.

Please provide any comments on this report to the undersigned at 604-473-8518, or to Norm Barmeier, Project Engineer, at 604-298-6181.

Sincerely, AECOM Canada Ltd.

Son win w.

Will F. Wawrychuk, P.Eng. Program Manager

Encl:

/nb

AECOM

Executive Summary

Review of past studies, annual monitoring reports, the Official Community Plan, current population numbers, past and current population projections, cost estimates, and service areas has provided the information summarized below:

- The plant currently operates at approximately 42% of its current design capacity.
- The plant encounters little inflow and infiltration.
- Previous population and sewer connection projections have significantly overestimated actual population growth in the area.
- Observed population growth is approximately 0.3% per year.
- The NPCC currently (2009) has approximately 766 sewer connections, of which 596 are being actively billed including 3 commercial properties. These connections are all from the Fairwinds area.
- The Madrona area will connect to the French Creek Pollution Control Centre. This will reduce the NPCC service area to Beach Comber, Delanice Way, Dophin Drive, Shooner Cove, Garry Oak, Red Gap, and Fairwinds.
- The total cost for trunk sewers to connect these areas to the NPCC is approximately \$6,500,000.
- The cost to upgrade the NPCC to secondary treatment and service 1,500 residents (625 properties) is approximately **\$3,500,000**.
- The cost to upgrade the NPCC to secondary treatment and service 3,000 residents (1250 properties) is approximately **\$7,500,000**.
- The cost to increase the capacity to 6,000 residents (2500 properties) and upgrade to secondary treatment as well as to provide sludge thickening and dewatering equipment is approximately \$11,000,000.

Callandof DataMed, M412011450517 Report Final Report AECOM

Table of Contents

Letter of Transmittal Executive Summary

		p	age
1.	NPC	CC Performance	1
	11	Hydraulic Capacity	. 1
	1.2	Population Projections for the Area Serviced by the NPCC	2
2.	Upd	lated Capital Cost Estimates	3
	21	Trunk Sewer Projects	3
	22	Upgrade to Secondary Treatment	
3.	Con	clusions	6

List of Figures

Figure 1	Summary of Annual Mo	onitoring Reports – Average and Maximum Daily Flows	1
----------	----------------------	---	---

List of Tables

Table 1	Population Projections	2
Table 2	Updated Trunk Sewer Cost Estimates	
Table 3	Conceptual Cost Estimates for Various Technologies	4
Table 4	Conceptual Cost Estimate – Secondary Upgrade to SBR for more Residents	. 4

Appendices

- A. Trunk Sewer Cost Estimate Details
- B. Secondary Upgrade Cost Estimate Details

NPCC Performance 1.

1.1 Hydraulic Capacity

The Nanoose Pollution Control Centre (NPCC) was originally designed for a population of 3,000 (1250 properties¹), an average dry weather flow of 530 m³/d, and a peak wet weather flow of 2,780 m³/d. During construction only enough pumping capacity was installed to serve a population of 1,500 (625 properties¹), the existing sedimentation tanks can support primary treatment for a population of 3,000 (1250 properties¹) with the addition of sludge pumps.

The NPCC currently sees an average flow of approximately 220 m³/d and a maximum flow of approximately 450 m³/d. It is of particular note that this plant does not encounter peak hourly flows that approach the rated peak flow capacity of 2,780 m³/d. The plant currently operates at approximately 42% of its original design capacity.

- 1. The NPCC catchment collection system is relatively new and is isolated from wet weather flows; minimal I&I.
- 2. The NPCC average daily flow is currently 220 m³/d.
- 3. The NPCC has an hydraulic capacity of 2,780 m³/d.

Flow data from the annual monitoring reports for NPCC has been summarized and plotted in Figure 1 to illustrate the change in flow through the plant since 1999. The average annual flow has increased from 120 m³/d to 220 m³/d over the past 10 years.






Figure 1 Summary of Annual Monitoring Reports – Average and Maximum Daily Flows

The plant was originally designed to handle approximately five times the average dry weather flow in order to accommodate peak hourly flows associated with wet weather events. However the collection system

assume 2.4 residents per property

connected to the NPCC is strictly a sanitary sewer system which is isolated from storm water inflow. Operations staff has confirmed that the collection system is also relatively new and little infiltration through cracks or poor piping joints has been observed.

1.2 Population Projections for the Area Serviced by the NPCC

Based on the Nanoose Bay Official Community Plan there are nine areas that form part of the NPCC catchment area. These are Madrona, Beach Comber, Delanice Way, Dophin Drive, Shooner Cove, Garry Oak, Red Gap, the Department of National Defence, and Fairwinds. Madrona will be serviced by the French Creek Pollution Control Center. Fairwinds is the only neighbourhood currently physically connected to the NPCC. In addition, there are 129 parcels of land at Gary Oak with the potential to connect immediately, for a total of 846 physical sanitary sewer connections to the plant. The remaining areas use private septic fields.

The Schooner Cove condominium complex was connected this summer and has added an estimated 49 residential connections to be serviced by NPCC bringing current active sewer connections to 766, however according to the latest billing information provided by the RDN only 596 connections are being actively billed.

There have been several population projections made in the past and Table 1 summarizes past lot counts, house counts, and latest population projections. Generally, the actual population growth and sewer connections observed have been significantly less than had been projected in the past. The observed population growth is approximately 0.3%.

Area	2006 lot count	2009 house count*	2009 Population based on house count**	Projected population based on OCP build out**
Madrona	n/a	n/a	n/a	0 - Connecting to FCPCC
Beachcomber	n/a	465	1116	1320
Delanice Way	n/a	27	67	84
Dolphin Drive	366	328	788	1174
Shooner Cover	n/a	49***	118	449
Garry Oak	138	129	310	762
Red Gap	165	252-290	504-580	1000-1100
DND	n/a	n/a	40-74	131
Fairwinds	658	623***	1495	5366
TOTALS			~3600	~10400

Table 1 House Count and Population Projections

Notes: * the current house count is based on recent discussions with RDN staff.

** Populations are based on a factor of 2.4 people per lot applied to the projected OCP build out lots *** denotes houses that are physically connected to the NPCC

2. Updated Capital Cost Estimates

2.1 Trunk Sewer Projects

Original cost estimates for trunk sewers put forward by Dayton & Knight in 1997 included the following trunk sewers:

- 1. Madrona pump station and trunk connection to Beachcomber pump station;
- 2. Delanice Way pump station and trunk connection to Madrona trunk connection;
- 3. Beachcomber pump station and trunk connection to NPCC;
- 4. Red Gap pump station and trunk connection to NPCC; and
- 5. Garry Oak pump station (part of Red Gap trunk connection to NPCC).

In the current context Madrona will no longer require sewage treatment from NPCC as a recent referendum was passed to connect Madrona to the French Creek Pollution Control Center.

The following Table 2 summarizes original and updated cost estimates for Delanice Way, Beachcomber, Red Gap, and Garry Oak, based on the technical details outlined in Dayton & Knight 1997 Sewer System Concept Design report on file at the RDN. Update cost estimates are based on the trunk sewer lengths and diameters put forward by Dayton & Knight. Current labour and material costs have been applied to generate the 2009 estimates.

Table 2 Updated Trunk Sewer Cost Estimates

Area	1997 Estimates	2009 Estimate
Madrona pump station and trunk connection to Beachcomber pump station	\$778,000	n/a
Delanice Way pump station and trunk connection to Madrona trunk connection	\$338,000	\$659,295
Beachcomber pump station and trunk connection to NPCC (option b)	\$1,401,000	\$2,873,850
Red Gap pump station and trunk connection to NPCC	\$1,234,000	\$2,502,675
Garry Oak pump station (part of Red Gap trunk connection to NPCC)	\$352,000	\$527,546
TOTAL	\$4,103,000	\$6,563,366

Details of the original and revised cost estimates are attached as Appendix A.

2.2 Upgrade to Secondary Treatment

In 1996 Dayton & Knight provided the RDN cost estimates to take the NPCC to secondary treatment. Several treatment alternatives were screened and compared on a capital cost basis. The total project cost included 10% contingencies, 15% engineering and project management fees, 8% interim financing, and 6% taxes. The technologies and original cost estimates are summarized in Table 3 using 1996 dollars. The total project cost for conversion to sequencing batch reactors in 1996 was \$2,910,000.

Technology	1996 Cost Estimate (\$)	
Oxidation Ditch	\$3,060,000	
Sequencing Batch Reactor	\$2,910,000	
Trickling Filter/Solids Contact	\$3,220,000	
Ecofluid	\$3,890,000	
Hydroxyl	\$4,110,000	
Solar Aquatics	\$3,560,000	
ZenoGem	\$3,710,000	

Table 3 Conceptual Cost Estimates for Various Technologies

It is important to note that the design basis for the upgrade to secondary treatment put forward in 1996 assumed that the existing primary sedimentation tanks would be converted to SBR basins, and that three additional SBR basins would be required to service an anticipated 6,000 people.

AECOM prepared an independent conceptual level cost estimate to convert the NPCC to secondary treatment using SBR technology based on an ADWF of 530 m³/d. This cost estimate is summarized in Table 4 below. AECOM estimates it will cost approximately \$3,500,000 to convert the NPCC to secondary treatment using SBR technology without making allowances for expansion of the plant for additional flow capacity.

ltem	Description		AECOM Estimate (\$)	1
		1,500 resident	3,000 residents	6,000 residents
1.0	General	\$65,000	\$65,000	\$65,000
2.0	Structural	\$316,000	\$602,000	\$1,024,000
3.0	Process Mechanical	\$1,234,000	\$2,911,000	\$4,190,000
4.0	Building Mechanical	\$85,000	\$85,000	\$85,000
5.0	Electrical	\$250,000	\$350,000	\$500,000
6.0	Instrumentation	\$250,000	\$350,000	\$600,000
	Subtotal	\$2,200,000	\$4,363,000	\$6,464,000
	Engineering (15%)	\$330,000	\$654,450	\$969,600
	Contractor's Overhead and Profit (10%)	\$220,000	\$436,300	\$646,400
	Subtotal	\$2,750,000	\$5,453,750	\$8,080,000
	Contingency Allowance (25%)	\$687,500	\$1,908,813	\$2,828,000
	TOTAL (not including taxes)	\$3,437,500	\$7,362,563	\$10,908,000

Table 4 Conceptual Cost Estimate – Secondary Upgrade to SBR for more Residents

The 1996 Dayton and Knight report also recommends SBR in combination with thickening untreated waste biosolids and trucking the thickened biosolids to the FCPCC for treatment and reuse.

AECOM therefore also prepared an independent conceptual level cost estimate to convert the NPCC to secondary treatment using SBR technology and adding sludge thickening and dewatering capabilities based on a population of 3,000 and 6,000. This cost estimate is summarized in Table 4 above. AECOM estimates it will cost approximately \$7,500,000 to treat sewage from 3,000 residents and approximately \$11,000,000 for 6,000 residents by converting the NPCC to secondary treatment using SBR technology. The property is large enough to accommodate the additional infrastructure required for this upgrade.

Detailed cost estimates are attached as Appendix B.

3. Conclusions

Based on the review that AECOM has completed of previous information, and updated capital cost estimates, the following can be concluded:

- NPCC is currently running at 42% of full capacity and providing adequate primary treatment.
- An upgrade to secondary treatment for 1,500 residents will cost approximately \$ 3,500,000 using SBR technology.
- An upgrade to secondary treatment for 3,000 residents will cost approximately \$ 7,500,000 using SBR technology.
- An upgrade to secondary treatment for 6,000 residents will cost approximately \$ 11,000,000 based on SBR technology and the inclusion of sludge thickening equipment.
- Trunk sewers to connect the entire catchment area will cost approximately \$ 6,500,000.

11

Nanoose Pollution Control Centre Upgrade Study Report

APPENDIX A TRUNK SEWER COST ESTIMATE DETAILS

Area	2009 Estimates	1997 Estimate
Pump Station – 2 – 350 m ³ /d pumps, \pm 5 HP c/w S/B generator	\$225,000	\$150,000
Forcemain, paved road; 75 mm, 600 m x \$200/m	\$120,000	\$42,000
Forcemain, unpaced easement; 75 mm, 200 m x \$150/m	\$30,000	\$13,000
Forcemain tie-ins	\$3,000	n/a
Allowance for rock 450 m ³ x \$150/m ³	\$67,500	\$36,000
Clearing, allowance	\$3,000	\$2,000
Subtotal	\$448,500	\$243,000
Engineering & Contingency (30% in 1997, 40% in 2009)	\$179,400	\$73,000
Subtotal	\$627,900	\$316,000
GST (7% in 1997, 5% in 2009)	\$31,395	\$22,000
TOTAL	\$659,295	\$338,000

Updated trunk sewer cost estimate - Delanice Way Pump Station

Updated Trunk Sewer Cost Estimate – Beachcomber Pump Station (Option B*)

Area	2009 Estimates	1997 Estimate
Pump Station – 2 – 1640 m ³ /d pumps, ± 25 HP c/w S/B generator	\$325,000	\$200,000
Forcemain, paved road; 200 mm, 2200 m x \$270/m	\$594,000	\$308,000
Forcemain, unpaced easement;200 mm, 1900 m x \$225/m	\$427,500	\$202,000
Forcemain and sewer tie-ins	\$10,000	n/a
Gravity sewer, unpaved easement; 250 mm, 400 m x \$360/m	\$144,000	\$61,000
1050 mm sanitary manholes 4 x \$4000 each	\$16,000	n/a
Allowance for rock 2550 m ³ x \$150/m ³	\$382,500	\$204,000
Allowance for clearing, 2.8 ha x \$20,000/ha	\$56,000	\$34,000
Subtotal	\$1,955,000	\$1,009,000
Engineering & Contingency (30% in 1997, 40% in 2009)	\$782,000	\$301,000
Subtotal	\$2,737,000	\$1,310,000
GST (7% in 1997, 5% in 2009)	\$136,850	\$91,000
TOTAL	\$2,873,850	\$1,401,000

* Refer to Dayton and Knight 1996 Pre-Design Report Phase 1 for details

Cavans01/DataWork(11400011452105 ReportFinal

Report 201 Marzo Dur-

- A1-

Area	2009 Estimates	1997 Estimate
Pump Station – 2 – 2380 m ³ /d pumps, ± 50 HP c/w S/B generator	\$350,000	\$225,000
Forcemain, paved road; 200 mm, 2100 m x \$270/m	\$567,000	\$294,000
Forcemain, proposed road;200 mm, 2000 m x \$225/m	\$450,000	\$212,000
Forcemain and sewer tie-ins	\$10,000	n/a
Gravity sewer, proposed road; 250 mm, 300 m x \$360/m	\$108,000	\$46,000
1050 mm sanitary manholes 3 x \$4000 each	\$12,000	n/a
Allowance for rock 1370 m ³ x \$150/m ³	\$205,500	\$110,000
Subtotal	\$1,702,500	\$887,000
Engineering & Contingency (30% in 1997, 40% in 2009)	\$681,000	\$266,000
Subtotal	\$2,383,500	\$1,153,000
GST (7% in 1997, 5% in 2009)	\$119,175	\$81,000
TOTAL	\$2,502,675	\$1,234,000

Updated Trunk Sewer Cost Estimate – Red Gap Pump Station

Updated Trunk Sewer Cost Estimate – Garry Oak Pump Station

Area	2009 Estimates	1997 Estimate
Pump Station – 2 – 2750 m ³ /d pumps, ± 35 HP c/w S/B generator	\$350,000	\$250,000
Forcemain, paved road; 100 mm, 15 m x \$225/m	\$3,375	\$1,500
Forcemain and sewer tie-ins	\$4,000	n/a
Allowance for rock	\$1,500	\$1,500
Subtotal	\$358,875	\$253,000
Engineering & Contingency (30% in 1997, 40% in 2009)	\$143,550	\$76,000
Subtotal	\$502,425	\$329,000
GST (7% in 1997, 5% in 2009)	\$25,121	\$23,000
TOTAL	\$527,546	\$352,000

Davarisof Data Work 114/201114601/03 Report Final

- A2 -

۰.

APPENDIX B SECONDARY UPGRADE COST ESTIMATE DETAILS

Regional District of Nanaimo	Nanonse Bollintion Control Control Landa 64 4

Nanoose Pollution Control Centre Upgrade Study – Report

AECOM

]

]

]

J

1

٥
2
C
a
-
2
LC.
- 1500 Peonla
1
C.
ā
Ε
Ŧ
- 60
Cost Estimate
S
20
U
5
8
Pre-Design
5
2
Ц

			aidoalu				Rev 0
ltem	Description	Quantity	Unit	Unit Price	Total Material	Total Labour	Extension (\$)
1.0	GENERAL						
1.1	Mobilization/Demobilization	•	U	CAD 000			
1.2	Start-up and Commissioning		2 2	\$5 000			\$40,000
1.3	Landscaping		0.0	\$20,000			000'04
	TOTAL 1.0 - GENERAL			000			\$65 000
2.0	STRUCTURAL						000,000
2.1	Modify Existing Primary Sedimentation Tanks					_	
	2.1.1 Demolition and modification	1	S.	\$50 000			000 010
2.2	Ne		2	000,000			000'00\$
	2.2.1 Two new basins similar in size to modified sed tanks (12x2.75x3.6)	1	S	\$116 000			C112 000
2.3	Bu						000,011\$
2	2.3.1 Extension to accommodate new equipment	-	LS	\$150,000			\$150 000
	TOTAL 2.0 - STRUCTURAL						\$316,000
3.0	PROCESS MECHANICAL						000'0-04
3.1	Headworks						
3.	3.1.1 In-Channel Spiral Screen	-	ca	\$100,000	\$100 000	#7F 000	
Э	3.1.2 Manual Screen (bypass)	. *	5 0		000,000	000'000	000,651¢
3.2	-	-	a d	000,61¢	\$15,000	\$5,000	\$20,000
3.	3.2.1 Blowers (one per basin + common standby - 7.5 kW each)	5	a	\$20,000	\$100,000	42E 000	
ю.	Fine Bubble Aeration			\$40,000	\$40,000	\$44,000	\$130,000
З.	3.2.3 SBR Decanters and Controls	4		\$65 000	\$40,000 \$	\$14,000	\$54,000
	3.2.4 Waste Solids Pumps			#7 F00	\$45 000	480,000	000,0654
ы. С	3.2.5 Effluent Pumps	4 0	2 20	\$45 000	000'01¢	000'6\$	\$20,000
Э.	-	1 +	00.00	\$300,000	\$300,000	\$30,000	\$120,000
	TOTAL 3.0 - PROCESS MECHANICAL		.in		000,0000	\$ 100,000	\$400,000
4.0	BUILDING MECHANICAL						\$1,234,000
4.1	Odour Control	-	U	ERE DOD			
	TOTAL 4.0 – BUILDING MECHANICAL		3	000,000			\$85,000
5.0	ELECTRICAL						nnn'co¢
5.1	Electrical	-	U	\$750 000			
	TOTAL 5.0 - ELECTRICAL		3	000,0024			\$250,000
6.0	INSTRUMENTATION						000'007¢
6.1	Instrumentation		S	\$250,000			#7E0 000
	TOTAL 6.0 - INSTRUMENTATION						\$250 000
	TOTAL						\$2 200,000
						-	44,400,000

IICavans01IDataIWork114000/114501103-Report/Final ReportAppendix B_NPCC Secondary Upgrade Cost Estimate - 1500 People_B1_Rev 0). Docx

8

	Pre-Design Cost Estimate – 3000 People	stimate – 3(00 People	-			Rev 0
ltem	Description	Quantity	Unit	Unit Price	Total Material	Total Labour	Extension (\$)
1.0	GENERAL						
1.1	Mobilization/Demobilization	-	U.	\$40,000			
1.2	Start-up and Commissioning		2 4	\$5 000			\$40,000
1.3	Landscaping	• •	2 4	\$20,000			000'9\$
	TOTAL 1.0 - GENERAL		3	000'07¢			\$20,000
2.0	STRUCTURAI						000,004
2.1	Modify Existing Primary Sedimentation Tanks						
2.1.1	-	F	0	\$50 000			000 014
2.2	New SBR Basins	-	3	000,000			000'06\$
2.2.1	-	-	S	\$116,000			£116.000
2.2.2	Two new, deeper basins (12x3.3x5.6)	1	S	\$136,000			\$126,000
2.3	Bui						000,000 \$
2.3.1	-	1	LS	\$300.000			\$300.000
	TOTAL 2.0 - STRUCTURAL						602,000
	PROCESS MECHANICAL						0001400
	Headworks						
3.1.1		-	ea	\$100.000	\$100 000	\$35,000	\$135 000
3.1.2	Manual Screen (bypass)	-	a	\$15,000	\$15 000	65 000	
	SB		5	0001014	000	000,00	000'07¢
3.2.1		4	ea.	\$30.000	\$120,000	\$35,000	\$155 000
3.2.2		-	ea.	\$110,000	\$110,000	\$20,000	\$130,000
3.2.3		9	ea.	\$65,000	\$390,000	\$120,000	\$510,000
3.2.4	Wast	6	ea.	\$7,500	\$45,000	\$16.000	\$61.000
3.2.5		2	ea.	\$60,000	\$120,000	\$30,000	\$150.000
3.2.6	_	-	ea.	\$650,000	\$650,000	\$225,000	\$875,000
	Sluc						
3.3.1		1	ea.	\$150,000	\$150,000	\$60,000	\$210.000
3.3.2		1	ea.	\$350,000	\$350.000	\$110,000	\$460 000
3.3.3	Pipi	F	ea.	\$150,000	\$150,000	\$55,000	\$205,000
	TOTAL 3.0 - PROCESS MECHANICAL						\$2 911 MM
	BUILDING MECHANICAL						000511054
	Odour Control	-	S	\$85 000			PDE DOD
	TOTAL 4.0 – BUILDING MECHANICAL			000			400,000
	ELECTRICAL					Ī	000,004
	Electrical		0	82E0 000			
	TOTAL 5.0 - ELECTRICAL	-	3	000,000¢			\$350,000
	INSTRUMENTATION						nnn'nes¢
	Instrumentation	1	LS	\$350.000			\$350,000
	TOTAL 6.0 - INSTRUMENTATION						000,000
							C360 000

IICavans01/DataIWork/114000/114501/03-Report/Final ReportAppendix B_NPCC Secondary Upgrade Cost Estimate - 3000 People_B2_Rev 0). Docx

B2

	Pre-Design Cost Estimate – 6000 People	timate – 60(00 People				Rev 0
ltem	Description	Quantity	Unit	Unit Price	Total Material	Total	Extension (\$)
1.0	GENERAL					Laboui	
1.1	Mobilization/Demobilization	1	LS	\$40,000			CUU UU
1.2	Start-up and Commissioning	1	LS	\$5,000			\$5,000
1.3		1	LS	\$20,000			\$20,000
	TOTAL 1.0 – GENERAL						\$65 000
	STRUCTURAL						00,004
	Modify Existing Primary Sedimentation Tanks						
2.1.1	Demolition and modification	-	U.	\$50 000			000
	New SBR Basins	-	3	000,000			nnn'ne¢
2.2.1	Two new basins similar in size to modified sed tanks (12x2.75x3.6)	-	LS L	\$116,000			\$116,000
2.2.2	Six new, deeper basins (12x3x5.6)	1	LS	\$408,000			\$408,000
120	Euliding and Gallery Modifications						
1.0.4		-	LS	\$450,000			\$450,000
	IUIAL 2.0 - SIRUCIURAL						\$1,024,000
	PROCESS MECHANICAL						
	Headworks						
3.1.1	In-Channel Spiral Screen		-	69	\$100 000	\$100,000	625 000
3.1.2	Manual Screen (bypass)			ea	\$15,000	\$15,000	\$5,000
	SBR			5	000	000-0-+	00,00
3.2.1	Blowers (one per basin + common standby - 15 kW each)	5	ea.	\$30,000	\$150.000	\$35.000	\$185 000
3.2.2	Fine Bubble Aeration	1	ea.	\$160,000	\$600.000	\$35,000	\$195,000
3.2.3	SBR Decanters and Controls	8	ea.	\$65,000	\$520,000	\$180,000	\$700,000
3.2.4	Waste Solids Pumps	8	ea.	\$7,500	\$60,000	\$40,000	\$100 000
3.2.5	Effluent Pumps	2	ea.	\$75,000	\$150,000	\$30,000	\$180,000
3.2.0	Pripring, Valves and Gates	F	ea.	\$1,000,000	\$1,000,000	\$350,000	\$1,350,000
100	Sudge Inickening and Dewatering						
0.0.0		2	ea	\$150,000	\$300,000	\$100,000	\$400,000
2.2.5		-	ea	\$350,000	\$350,000	\$110,000	\$460,000
0.0.0		1	ea	\$250,000	\$250,000	\$80,000	\$330,000
							\$4,190,000
	BUILDING MECHANICAL						
	Odour Control	-	S	\$85.000			000 200
	TOTAL 4.0 – BUILDING MECHANICAL			200			
	ELECTRICAL						200,000
	Electrical	+	0	\$500 000			
	TOTAL 5.0 - ELECTRICAL	_	3	000,000¢			\$500,000
	INSTRUMENTATION						\$500,000
	Instrumentation		U	\$600 000			
	TOTAL 6.0 - INSTRUMENTATION		3	000,0004			\$600,000

IICavans01/DataIWork114000/114501/03-Report/Final Report/Appendix B_NPCC Secondary Upgrade Cost Estimate - 6000 People_B3 (Rev 0). Docx

B3

AECOM

AECOM 3292 Production Way, Floor 4 Burnaby, BC, Canada V5A 4R4 www.aecom.com

604 444 6400 tel 604 294 8597 fax

Technical Memorandum

То	Shelley Norum	Page 1	
СС	Sean De Pol		
Subject	Nanoose Pollution Control Ce	nter Cost Estimate Update	
From	Susan Spruston, P.Eng.		
Reviewed By	David Lycon, P.Eng.		
Date	July 16, 2012	Project Number 6024625	
			_

BACKGROUND

In response to the request from the Regional District of Nanaimo on June 1, 2012, the preliminary cost estimate for the secondary upgrade to the Nanoose Pollution Control Center has been updated for a population of 2,000 PE. This estimate is based on the Nanoose Pollution Control Center Upgrade Study that was completed by AECOM in March 2010.

DESIGN BASIS

A summary of the design parameters are provided in Table 1 below.

Table 1. Design Parameters

Parameter	Value
Population	2,000
ADWF, m ³ /d (based on 350L/c/d)	700
Influent BOD ₅ Concentration, mg/L	165
Influent BOD₅ Load, kg/d	116

As per the pre-design study that was completed in 2010 it is assumed that the secondary expansion would consist of the following works:

- Conversion of the existing primary sedimentation tanks to SBRs.
- Construction of two additional/larger SBR tanks.
- Supply and installation of a new headworks screens, one mechanical fine screen and one bypass screen.
- Supply and install of new aeration blowers, waste solids pumps, effluent pumps and associated piping, valving and gates.
- Expansion to the existing building and gallery to accommodate the new mechanical equipment.
- Electrical and instrumentation components to complete the works noted above.



COST ESTIMATE

Sub-Total

Total

Contingency (30%)

Table 2. presents a cost estimate breakdown, the total project cost is estimated to be \$4,101,000.

\$ 660,000

\$ 794,000 \$ 4,101,000

\$ 2,647,000

Table 2. Cost Estimate – 2,000 PE	
Description	AECOM Estimate
1.0 General	\$ 135,000
2.0 Civil	\$ 66,000
3.0 Structural	\$ 455,000
4.0 Process Mechanical	\$ 1,331,000
5.0 Building Mechanical	\$ 100,000
6.0 Electrical	\$ 280,000
7.0 Instrumentation	\$ 280,000

Table 2. Cost Estimate – 2,000 P

Engineer and Administration (25%)

The following assumptions were made in development of the estimate above.

- Sludge will continue to be shipped to FCPCC with storage in the existing sludge storage tank. ٠ During the design of the secondary expansion it is recommended that an analysis be completed to review the economics of dewatering on site prior to hauling off-site.
- Civil costs exclude ground improvements and dewatering. Further investigation shall be completed during the design. The contingency value allocated above should cover these costs if required.
- Excludes any remedial work on existing tankage or systems that may be recommended to be • completed at the time of the upgrade.