



## **REQUEST FOR TENDER No. 20-030**

### **Pump Station Electrical Kiosks (2) – Remove and Replace**

#### **Addendum 1**

**Issued: April 24, 2020**

**Closing Date & Time: on or before 3:00 PM Pacific Time on May 5, 2020**

#### **Questions & Answers**

Q1. Would you be able to supply a RAL number for the paint color?

A1. RAL 6005.

Q2. What is happening with the old kiosks once removed?

A2. Successful contractor is to remove and legally dispose.

Q3. The meter height does not appear to meet current BC Hydro requirements for height above grade.

A3. The RDN is checking with Hydro and will advise in a future addendum.

Q4. Please clarify if the internal components will remain (meter base, utility power distribution panels, pump etc.) and the enclosure itself is to be replaced? No need to price in new electrical components.

A4. At this time, it is anticipated everything is staying in. Some EYS connections that are mounted to the kiosks will have to be removed and replaced as they cannot be reused. The RDN is checking with Hydro and will advise in a future addendum.

End of Addendum 1