

Suite 1, 1351 Estevan Road Tel 250 716 3336
 Nanaimo BC
 Canada V9S 3Y3



DATE	DESTINATION EMAIL	NO OF PAGES (INCL THIS PAGE)	FILE
August 14, 2020	n/a		RDN Tender 20-049
TO	FROM		
ALL DOCUMENT HOLDERS	M.C. Pascual		
COMPANY	ORIGINALS TO BE:		
	<input type="checkbox"/> Filed <input type="checkbox"/> Mailed <input type="checkbox"/> Couriered		
CITY	OTHER (SPECIFY)		

MESSAGE

**THE REGIONAL DISTRICT OF NANAIMO
 WHITE HEATHER LANE FIREWATER STORAGE TANK - ACCESS**

Attached, please find Addendum # 1 for the above noted project.

Electronic PDF includes:

- 1 page(s) – Cover
- 4 page(s) – Addendum #1
- 1 page(s) – Schedule of Quantities

Addendum # 1

The following information and corrections are added to the Tender Documents for this project:

1. Instruction to Tenderers Part I – IT-3 – Revise 3.3 Tender Submission:

e.) Other than the acknowledgement of receipt of addenda, or request for withdrawal or revision, documents submitted as part of the tender **will not be considered** if received by any of the Owner's facsimile machine.

2. Instruction to Tenderers Part I – IT-3 – Add 3.4 Tender Submission by Email:

3.4 Tender Submission by Email

a) The Regional District of Nanaimo has permitted tenderers to submit their bids by email. The electronic submission should be signed by the tenderer and be saved in .pdf format. Submissions will only be accepted to mpascual@mcelhanney.com and is subject to the same tender closing date and time.

The email subject should read:

“RDN Tender No. 20-049 – White Heather Lane Firewater Tank – Access – Tender Bid”

b) Email submissions received will be considered the same as hardcopy submissions; these submissions are bound to the same tender instructions outlined in this Tender Document.

c) All submissions via email will remain unopened until after the tender closing time.

It is the sole responsibility of the tenderers to ensure that their bid is received by the Contract Administrator within the proper time allocation. The Contract Administrator's computer is set to the local time zone; the time stamp on the email submission will determine the time that the bid was received. The tenderer assumes all risks involved with sending their bid by email. Late submissions will be rejected by the Regional District of Nanaimo.

d) All submissions must be signed by an authorized representative of the Tenderer.

e) The tenderer may update, change, or withdraw their submission at any time prior to the closing date and time. For any updates or changes, the tenderer should not submit only the revised parts of their bid but instead submit a complete revised package clearly indicating that this replaces any prior submissions.

Addendum # 1

f) McElhanney Ltd. will send a confirmation email confirming that the email submission(s) has/have been received. However, the emailed tender bid will be left unopened; the tenderer should confirm that all attachments are in working order. The Owner and the Contract Administrator assume no responsibilities with regards to corrupted files.

g) Any and all attachments must be contained within the email submission. No links for downloading the files are to be accepted. If multiple emails are required due to the collective size of the attachments exceeding the limit, the tenderer may send the attachments in several emails with clear instructions how to collate all of the sent files.

h) The submission of a bid by email indicates the acceptance of the tenderer of the conditions outlined within the Tender Documents.

3. Supplementary Specifications – 8.1 Measurement and Payment – Revise Appendix 1 Item No. 2.11 Signage:

Appendix 1 Item No. 2.11 Signage

Signage shall include all labour and materials required to install no two (2) parking tow-away zone signages and one (1) MOTI W-054-R sign as shown in the Contract Drawings. All materials and their installation are to conform to BC Ministry of Transportation and Infrastructure standards.

Measurement for this item shall be per unit. Payment shall be made at the tendered price for the unit complete for installation of the signs with all associated works.

4. Supplementary Specifications – 8.1 Measurement and Payment – Add Appendix 1 Item No. 2.16 [Optional Work] Remove and Reinstall Sign

Appendix 1 Item No. 2.16 [Optional Work] Remove and Reinstall Sign


Remove and reinstall sign shall include all labour and materials to remove and reinstall the existing sign as required and as shown in the Contract Drawings. All materials and their installation are to conform to BC Ministry of Transportation and Infrastructure standards.

Remove and reinstall sign shall be per unit. Payment shall be measured at the tendered price for the unit complete as compensation in full for the removal and relocation of the sign with all associated works.

Addendum # 1

5. Can you please advise if the culvert is supposed to be backfilled with certain material i.e. Type I bedding?

Answer: Please refer to the updated Section A-A below.



6. Can you clarify the installation of new barriers and the removal and reinstatement of existing barriers?

Answer: Installation of new barriers at the west side of the proposed access will be paid under Item 2.12 while the removal and reinstatement of existing barrier (located at the east side of the proposed access) will be paid under Item 2.13 as per updated Schedule of Quantities.

7. With regards to the bid bond, the tender documents state to check item 5.2. of the tender instructions. There is no item 5.2. Please clarify if a bid bond is required or just the performance bond and a labour and material bond.

Answer: Item 5.2 refers to the tender security as outlined in the Instructions to Tenderer's – Part II found within the Master Municipal Construction Documents, Platinum Edition, Volume II (2009).

Addendum # 1

- 8. The tender document refers to the Master Municipal Construction Documents, Platinum Edition, Volume II (2009) but it is not included. Are you able to provide this?**

Answer: It is the Contractor's responsibility to carefully review the documents including the Instruction to Tenderers, the specified edition of the "Master Municipal Construction Documents Platinum Edition Volume II (2009) – General Conditions, Specifications and Standard Detail Drawings" and any addenda. It is assumed that all Contractors have their own copy of the mentioned MMCD book. If not, the book may be purchased at the link below:

<https://www.mmcd.net/documents/platinum-edition/>

- 9. Please advise which colour the bollards are to be painted?**

Answer: Bollards to be painted yellow.

Drawings not re-issued

-----**END**-----

Regional District of Nanaimo - White Heather Lane Firewater Storage Tank - Access						
ITEM NO.	MMCD REF.	DESCRIPTION	UNIT	QUANTITY	UNIT PRICE	AMOUNT
1.0	GENERAL CONDITIONS					
1.1	Refer to Supplementary Specifications	Mobilization and Demobilization	Lump Sum	1.00		
	01 55 00	TRAFFIC CONTROL, VEHICLE ACCESS, AND PARKING:				
1.2	Refer to Supplementary Specifications	Control of Public Traffic	Lump Sum	1.00		
	01 57 01	ENVIRONMENTAL PROTECTION:				
1.3	Refer to Supplementary Specifications	Site Maintenance and Sediment Management	Lump Sum	1.00		
		GENERAL CONDITIONS SUBTOTAL				
2.0	ROAD WORKS					
		SITE PREPARATION:				
2.1	31 11 01 1.4.1/2	Clearing and grubbing (includes offsite disposal)	Square metre	100.00		
2.2	31 22 01 1.4.4	Stripping unsuitable material (300mm thickness), off-site disposal	Cubic Metre	30.00		
2.3	31 24 13 1.8.5.1	Common excavation, off-site disposal	Cubic metre	160.00		
2.4	31 24 13 1.8.9	Subgrade preparation	Square metre	100.00		
2.5	31 24 13 1.8.5	Remove existing asphalt (all thickness), off-site disposal	Square metre	20.00		
	32 11 16	GRANULAR SUB-BASE:				
2.6	32 11 16.1 1.4.3/4	Granular sub-base - 75mm thickness	Square metre	100.00		
	32 11 23	GRANULAR BASE:				
2.7	32 11 23 1.4.2/3	Granular base - 300mm thickness	Square metre	100.00		
	32 12 16	HOT-MIX ASPHALT CONCRETE PAVING:				
2.8	32 12 16 1.5.1/2	Asphaltic concrete paving - 50mm thickness	Square metre	100.00		
2.9	32 12 16 1.5.7	Sawcut existing asphalt	Linear metre	32.00		
		MISCELLANEOUS				
2.10	Refer to Supplementary Specifications	Hydraulic seeding, all disturbed areas	Lump Sum	1.00		
2.11	Refer to Supplementary Specifications	Signage	Each	3.00		
2.12	03 40 01 1.4.4	Concrete Barriers	Linear metre	10.00		
2.13	Refer to Supplementary Specifications	Remove and reinstate existing barriers	Lump Sum	1.00		
2.14	Refer to Supplementary Specifications	Support existing pole	Each	1.00		
2.15	Refer to Supplementary Specifications	Hydrant Bollards	Lump Sum	1.00		
2.16	Refer to Supplementary Specifications	[Optional Work] Remove and reinstate sign	Each	1.00		
		ROAD WORKS SUBTOTAL				
3.0	STORM SEWER					
3.1	31 23 01 1.10.4	Remove existing culvert and headwalls	Lump Sum	1.00		
3.2	33 42 13 1.5.2	Pipe - 600mm HDPE - Boss 2000	Lineal metre	32.50		
3.3	33 42 13 1.5.3	Concrete Headwalls, refer to drawings	Each	2.00		
		STORM SEWER SUBTOTAL				

Tender's Initials: _____