



Addendum #1: Request for Proposals No. 21-001

Professional Engineering Services

For

Nanoose Bay Peninsula Watermain Projects

This addendum (Addendum #1) is a compilation of questions received from possible proponents up to 4:30pm on Dec 4th, 2020, and the answers to these questions.

1) Question:

Please confirm the material of the existing watermain on Dorcas Point Road.

Answer:

The 1100m portion of existing watermain along Dorcas Point Road was incorrectly identified as PVC in the RFP documents. This watermain material is actually Asbestos Cement (AC).

2) Question:

Is there a water model available from the RDN to evaluate fireflows and determine appropriate pipe sizing or will the RDN be providing the pipe size requirements?

Answer:

The RDN will supply the successful proponent with pipe size requirements based on a previously completed water distribution study.

3) Question:

Does RDN have a standing agreement with a geotechnical engineer or will the proponent be expected to provide a price for geotechnical services?

Answer:

The RDN does not anticipate that geotechnical engineering services will be required as part of the project scope.

End of Addendum