



**REQUEST FOR TENDER No. 21-012**

**Church Road Transfer Station Residential Transfer Building Upgrade**

**Addendum 3**

**Issued: September 17, 2021**

**Total Pages: 3**

**Closing Date & Time: on or before 3:00 PM Pacific Time on September 29, 2021**

This addendum shall be read in conjunction with and considered as an integral part of the Request for Tender. Revisions supersede the information contained in the original Tender or previously issued Addendum. No consideration will be allowed for any extras due to any Vendor not being familiar with the contents of this Addendum. All other terms and conditions remain the same.

**Enclosed is Addendum 3 from the Project Engineer, Herold Engineering Ltd.**

End of Addendum 3

**Attn:** Kurtis Felker  
Regional District of Nanaimo  
6300 Hammond Bay Road  
Nanaimo BC V9T 6N2

**DATE:** September 17, 2021      **PROJECT No.:** 0837-068  
**PROJECT NAME:**  
CRTS - Phase 1: Ventilation System  
860 Church Road, Parksville BC

**From:** Erich Streit, Arch HTL, Project Manager

3 Pages Following

---

**ADDENDUM – 03**

---

1. *This Addendum shall be read in conjunction with and considered as an integral part of the Contract Documents; revisions supersede the information contained in the original drawings, specifications or previously issued Addendum.*
2. *Tender Price submitted shall include all items of this Addendum.*
3. *No consideration will be allowed for any extras due to any bidder not being familiar with the contents of this Addendum.*

**Addendum Information:**

1. Electrical Addendum  
Refer to attached Electrical Addendum E1 issued by RB Engineering Ltd., dated September 17, 2021

**Per:**           Erich Streit, Arch HTL          

**CC:** Kurtis Felker - RDN  
Kevin Guizzetti / Ben Routledge - RDN  
BC Bid & RDN Website  
All Sub-Consultants

## **Electrical Addendum**

**Project:** CRTS Ventilation System Upgrade Phase 1  
Parksville, BC  
19-3308

**Addendum:** E1

**Date:** September 17<sup>th</sup>, 2021

This Addendum forms part of the Contract Documents and is to be read, interpreted and coordinated with all other parts. The cost of all work contained herein shall be included in the Contract Sum. The following revisions supersede the information contained in the original drawings and specifications issued for the above named project to the extent referenced and shall become part thereof.

The following relates to the wiring methods:

1. All wiring to be contained in conduit. Refer to Conduit section of Specifications on electrical drawings for installation requirements.