

NOTES:

1. REPLACE PIPING AND VALVES FROM PUMP DISCHARGE TO OUTSIDE WET WELL WALL.
2. EXISITING PUMPS TO REMAIN.
3. THE EXISTING SLUICE GATE [G-120] WITH ACTUATOR TO REMAIN AS IS
4. PROVIDE IO SIGNAL WIRING FROM ALL INSTRUMENTS / DEVICES, WHETHER EXISTING OR NEW TO NEW PLC PANEL CPRS-CP-100.

DRAWING NO.	TITLE

REFERENCE DRAWINGS

REV	DATE	DESCRIPTION	DRN	CHK	APP
2	JAN 2022	ISSUED FOR CONSTRUCTION	JH	JG	JG
1	AUG 2021	ISSUED FOR CONSTRUCTION	RY	JG	JG
0	JUN 2021	ISSUED FOR CONSTRUCTION	JH	JG	JG

REVISIONS

REGIONAL DISTRICT OF NANAIMO

PROFESSIONAL ENGINEER — PROVINCE OF BRITISH COLUMBIA — J. G. GERWIEN # 213214 — 2022-01-17

PROJECT NAME: CHASE RIVER PUMP STATION UPGRADES

DRAWN: MP
DESIGNED: AK
CHECKED: JG
APPROVED: JG

CHASE RIVER PUMP STATION
PROCESS
P & I DIAGRAM
PUMP STATION

JACOBS

PROJECT NO.: 707564
SCALE: NTS
DRAWING NUMBER: CPRS-P-102
SHEET:
DATE: APR 2021
REV: 2