



REQUEST FOR TENDER No. 23-021

CHURCH ROAD TRANSFER STATION (CRTS) HAULING MUNICIPAL SOLID WASTE, FOOD WASTE AND YARD AND GARDEN WASTE

Addendum 1 Issued: March 13, 2023

Closing Date & Time: on or before 3:00 PM Pacific Time on Mach 24, 2023

This addendum shall be read in conjunction with and considered as an integral part of the Request for Tender. Revisions supersede the information contained in the original Tender or previously issued Addendum. No consideration will be allowed for any extras due to any Vendor not being familiar with the contents of this Addendum. All other terms and conditions remain the same.

Question & Answer

Q1. During the site visit on Friday, I believe Greg from CW said the maximum height inside the building was 32 feet? What was the maximum height of the bay door openings as they are now? Greg also mentioned that one of the openings would be changed to a 'barn door' opening, which allows for greater height clearance. Do you have the height figures on that, and when the new doors are anticipated to be installed?

A1. Current door height is 24' to max of the overhead door bottom when up, once the new style door is in place on the tip floor side, top of door frame is 26'. Once the existing overhead door is removed from the frame this will give a maximum inside the building height of 32', keeping in mind this is inside the door opening and behind the exterior door upper frame.

6-8 weeks is what the manufacturer quoted for installation of the doors. They are still in production, that time line isn't guaranteed, it's a "best guess".

End of Addendum 1