



## **REQUEST FOR TENDER No. 23-072**

### **Village Way Path Paving**

#### **Addendum 4**

**Issued: November 21, 2023**

**Closing Date & Time: on or before 3:00 PM Pacific Time on November 23, 2023**

This addendum shall be read in conjunction with and considered as an integral part of the Request for Tender. Revisions supersede the information contained in the original Tender or previously issued Addendum. No consideration will be allowed for any extras due to any Vendor not being familiar with the contents of this Addendum. All other terms and conditions remain the same.

#### **Question #1**

Pay item 1.4.1 States aggregate to be 25 mm clear crushed gravel. May we use the alternate material of 19mm Clear crushed gravel as it is more easily available?

#### **Response #1**

Yes, 19mm clear crushed gravel will be accepted as an alternate to 25mm clear crushed gravel.

End of Addendum 4