



INVITATION TO TENDER No. 24-039

Nile Creek Pedestrian Bridge Construction

Addendum 3

Issued: August 2, 2024

Closing Date & Time: on or before 3:00 PM Pacific Time on August 8, 2024

This addendum shall be read in conjunction with and considered as an integral part of the Invitation to Tender. Revisions supersede the information contained in the original Invitation to Tender or previously issued Addendum. No consideration will be allowed for any extras due to any Proponent not being familiar with the contents of this Addendum. All other terms and conditions remain the same.

Questions and Answers

Q1) The specifications state that the yellow cedar is required to be graded to Group No. 1, or better. Would No. 2 and better appearance be an adequate alternative?

A1) The grading requirement is structural, and all timber must be graded No. 1 or better.

Q2) The environmental assessment references the removal of the existing timber bridge that has been decommissioned, however, it is not mentioned in the drawings or schedule of values in the tender form. Can you confirm if the removal and disposal of the existing bridge is to be included in the tender submission?

A2) Removal of the existing bridge is not part of this tender scope.

End of Addendum 3