

## **REQUEST FOR PROPOSALS No. 25-036**

## **NBPCC Final Effluent Chamber Piping Replacement**

# Addendum 2

Issued: July 24<sup>th</sup>, 2025

### Closing Date & Time: on or before 3:00 PM Pacific Time on July 31<sup>st</sup>, 2025

This addendum shall be read in conjunction with and considered as an integral part of the Request for Proposals. Revisions supersede the information contained in the original Proposal or previously issued Addendum. No consideration will be allowed for any extras due to any Vendor not being familiar with the contents of this Addendum. All other terms and conditions remain the same.

#### **Request for Proposals Addendum Sections**

a. Clarification to question 2 from Addendum 1.

End of Addendum 1



## Addendum 2a Responses to Vendor Questions

1. **Clarification of Question 2 in Addendum 1a:** Correction on the available power for tie-in of bypass pumps. There is a single 60amp switch with a 30amp thermal trip available for use. This powers all 3 pumps currently in the Final Effluent Chamber.





