

REQUEST FOR PROPOSALS NO. 26-036
Addendum #1

DAFT Polymer for Greater Nanaimo Pollution Control Centre

Issued: October 19, 2026

Closing Date & Time: on or before 3:00 PM Pacific Time on October 27, 2026

This addendum shall be read in conjunction with and considered as an integral part of the Request for Proposals. Revisions supersede the information contained in the original Request for Proposals. No consideration will be allowed for any extras due to any Proponent not being familiar with the contents of this Addendum. All other terms and conditions remain the same.

Questions and Answers

This following is a compilation of questions received from possible proponents up to 3:00 pm on Wednesday, October 14, and the answers to these questions

(1) Question

What is your current polymer dosing rate?

Response

The current polymer dose is 0.30% @ 60 mL/s

(2) Question

What is the current flow rate for the Dissolved Air Flotation system?

Response

Current Waste Activated Sludge (WAS) flow is 11 L/s.

(3) Question

For this application, does the RDN prefer an anionic or cationic polymer?

Response

The RDN would be evaluating the function of shortlisted polymer within the operational trials.

Currently, a cationic polyacrylamide polymer is used for this application (see enclosed SDS in RFP).