

CDWG=Canadian Drinking Water Guidelines
OG= Operational Guidance Value

MAC=Maximum Acceptable Concentration
AO= Asthetic Objective.



Red font indicates non-compliance with Canadian Drinking Water Guidelines

	Units	CDWG		November 4 2014	October 26 2015	October 27 2016	October 18 2017	November 8 2018	October 10 2019
Miscellaneous Inorganics									
Fluoride	mg/L	1.5	MAC	0.08	0.11	0.11	0.11	0.13	0.11
Alkalinity (total as CaCO ₃)	mg/L			130	129	133	140	130	130
Anions									
Dissolved Sulphate	mg/L	500	AO	26.9	34.4	35.9	28.9	47.3	38
Dissolved Chloride	mg/L	250	AO	6.1	7.2	6.7	7.2	7.4	8.4
Nitrite	mg/L	1	MAC	0.12	<0.0050	<0.0050	0.0051	<0.0050	<0.005
Miscellaneous									
Apparent Colour	Colour Unit			6	10	5	15	5	5
Nutrients									
Total Ammonia	mg/L			0.26	0.29	0.3	0.22	0.24	0.36
Physical Properties									
Conductivity	µS/cm			317	337	344	341	354	350
pH	pH	7.0:10.5	AO	8.3	8.35	8.24	8.28	8.21	8.08
TDS	mg/L	500	AO	206	196	190	190	206	200
Turbidity	NTU			<0.5	0.2	0.48	0.85	0.32	0.18
Microbiological Parameters									
E.coli	MPN/100mL	<1	MAC	<1.0	<1.0	<1.0	<1.0	<1.0	0
Total Coliforms	MPN/100mL	<1	MAC	<1.0	<1.0	<1.0	<1.0	<1.0	0
Calculated Parameters									
Total Hardness (CaCO ₃)	mg/L			150	148	148	157	161	162
Nitrate	mg/L	10	MAC	<0.05	<0.020	<0.020	0.095	<0.020	<0.02
Elements									
Total Mercury	mg/L	0.001	MAC	<0.00001	<0.00001	<0.00001	<0.00001	<0.000002	<0.000002
Total Metals									
Total Aluminum	mg/L	0.1	OG	<0.005	<0.003	<0.003	<0.003	<0.003	<0.003
Total Antimony	mg/L	0.006	MAC	<0.0001	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005
Total Arsenic	mg/L	0.01	MAC	0.00015	<0.0001	0.00017	0.00011	0.00019	0.00014
Total Barium	mg/L	1	MAC	0.0173	0.0174	0.0182	0.016	0.0182	0.0189
Total Beryllium	mg/L			<0.00005	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Total Bismuth	mg/L			<0.0001	<0.001	<0.001	<0.001	<0.001	<0.001
Total Boron	mg/L	5	MAC	0.019	<0.050	<0.050	<0.050	<0.050	<0.05
Total Cadmium	mg/L	0.005	MAC	<0.00001	<0.00001	<0.00001	<0.00001	<0.00001	<0.00001
Total Chromium	mg/L	0.05	MAC	<0.0005	<0.001	<0.001	<0.001	<0.001	<0.001
Total Cobalt	mg/L			<0.0001	<0.0005	<0.0005	<0.0002	<0.0002	<0.0002
Total Copper	mg/L	1	AO	0.0005	0.0002	0.00047	0.0268	<0.0002	<0.0002
Total Iron	mg/L	0.3	AO	0.094	0.0835	0.0585	0.223	0.115	0.139
Total Lead	mg/L	0.01	MAC	<0.0001	<0.0002	<0.0002	0.00198	<0.0002	<0.0002
Total Manganese	mg/L	0.05	AO	0.145	0.134	0.133	0.122	0.147	0.151
Total Molybdenum	mg/L			0.00073	<0.001	<0.001	<0.001	<0.001	<0.001
Total Nickel	mg/L			0.0003	<0.001	<0.001	0.0027	<0.001	<0.001
Total Selenium	mg/L	0.05	MAC	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Total Silicon	mg/L			10.7	11.7	10.7	12.5	10.1	11.1
Total Silver	mg/L			<0.00005	<0.00002	<0.00002	<0.00002	<0.00002	<0.00002
Total Strontium	mg/L			0.147	0.146	0.148	0.145	0.165	0.162
Total Thallium	mg/L			<0.00001	<0.00005	<0.00005	<0.00001	<0.00001	<0.00001
Total Tin	mg/L			0.0011	<0.005	<0.005	<0.005	<0.005	<0.005
Total Titanium	mg/L			<0.0005	<0.005	<0.005	<0.005	<0.005	<0.005
Total Uranium	mg/L	0.02	MAC	<0.00001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Total Vanadium	mg/L			0.0002	<0.005	<0.005	<0.005	<0.005	<0.005
Total Zinc	mg/L	5	AO	0.0074	<0.005	0.0068	0.117	<0.005	<0.005
Total Zirconium	mg/L				<0.0005	<0.0005	<0.0001	<0.0001	<0.0001
Total Calcium	mg/L			36.8	37.4	36.5	37.8	39.8	41.2
Total Magnesium	mg/L			13.4	13.3	13.8	15.1	14.9	14.4
Total Potassium	mg/L			2.4	2.39	2.32	2.53	2.51	2.45
Total Sodium	mg/L	200	AO	9.2	9.5	8.58	9.47	9.11	8.99
Total Sulphur	mg/L				11.7	12.4	9.7	14.1	12.2

CDWG=Canadian Drinking Water Guidelines
OG= Operational Guidance Value

MAC=Maximum Acceptable Concentration
AO= Asthetic Objective.



Red font indicates non-compliance with Canadian Drinking Water Guidelines

	Units	CDWG		November 4 2014	October 26 2015	October 27 2016	October 18 2017	November 8 2018	October 10 2019
Miscellaneous Inorganics									
Fluoride	mg/L	1.5	MAC	0.09	0.11	0.11	0.11	0.13	0.11
Alkalinity (total as CaCO ₃)	mg/L			130	125	134	135	130	130
Anions									
Dissolved Sulphate	mg/L	500	AO	18.9	19.4	19.8	26.7	20.1	21
Dissolved Chloride	mg/L	250	AO	8.3	6.9	7.2	8.6	8.4	9.2
Nitrite	mg/L	1	MAC	<0.05	<0.0050	<0.0050	<0.0050	<0.0050	<0.0050
Miscellaneous									
Apparent Colour	Colour Unit			6	10	10	10	5	10
Nutrients									
Total Ammonia	mg/L			0.4	0.42	0.47	0.37	0.4	0.49
Physical Properties									
Conductivity	µS/cm			309	309	319	326	312	320
pH	pH	7.0:10.5	AO	8.2	8.17	8.27	8.28	8.19	8.1
TDS	mg/L	500	AO	196	194	162	174	196	190
Turbidity	NTU			<0.5	0.19	0.27	0.48	0.2	0.22
Microbiological Parameters									
E.coli	MPN/100mL	<1	MAC	<1.0	<1.0	<1.0	<1.0	<1.0	0
Total Coliforms	MPN/100mL	<1	MAC	<1.0	<1.0	<1.0	<1.0	<1.0	0
Calculated Parameters									
Total Hardness (CaCO ₃)	mg/L			140	135	133	152	138	141
Nitrate	mg/L	10	MAC	<0.05	<0.020	<0.020	<0.020	<0.020	<0.02
Elements									
Total Mercury	mg/L	0.001	MAC	<0.00001	<0.00001	<0.00001	<0.00001	<0.000002	<0.000002
Total Metals									
Total Aluminum	mg/L	0.1	OG	<0.005	<0.003	<0.003	<0.003	<0.003	<0.003
Total Antimony	mg/L	0.006	MAC	<0.0001	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005
Total Arsenic	mg/L	0.01	MAC	0.00013	<0.0001	<0.0001	0.0001	<0.0001	0.00011
Total Barium	mg/L	1	MAC	0.014	0.0134	0.0137	0.0147	0.0134	0.0142
Total Beryllium	mg/L			<0.00005	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Total Bismuth	mg/L			<0.0001	<0.001	<0.001	<0.001	<0.001	<0.001
Total Boron	mg/L	5	MAC	0.023	<0.05	<0.050	<0.050	<0.050	<0.05
Total Cadmium	mg/L	0.005	MAC	<0.00001	<0.00001	<0.00001	<0.00001	<0.00001	<0.00001
Total Chromium	mg/L	0.05	MAC	<0.0005	<0.001	<0.001	<0.001	<0.001	0.001
Total Cobalt	mg/L			<0.0001	<0.0005	<0.0005	<0.0002	<0.0002	<0.0002
Total Copper	mg/L	1	AO	0.0009	0.00042	<0.0002	0.00024	0.00081	0.00059
Total Iron	mg/L	0.3	AO	0.122	0.118	0.124	0.149	0.13	0.138
Total Lead	mg/L	0.01	MAC	<0.0001	0.00023	<0.0002	<0.0002	<0.0002	<0.0002
Total Manganese	mg/L	0.05	AO	0.15	0.136	0.141	0.149	0.145	0.146
Total Molybdenum	mg/L			0.00054	<0.001	<0.001	<0.001	<0.001	<0.001
Total Nickel	mg/L			<0.0002	<0.001	<0.001	<0.001	<0.001	<0.001
Total Selenium	mg/L	0.05	MAC	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Total Silicon	mg/L			12.2	13.2	11.9	13	11.5	12.3
Total Silver	mg/L			<0.00005	<0.00002	<0.00002	<0.00002	<0.00002	<0.00002
Total Strontium	mg/L			0.135	0.129	0.133	0.14	0.134	0.139
Total Thallium	mg/L			<0.00001	<0.00005	<0.00005	<0.00001	<0.00001	<0.00001
Total Tin	mg/L			0.0005	<0.005	<0.005	<0.005	<0.005	<0.005
Total Titanium	mg/L			<0.0005	<0.005	<0.005	<0.005	<0.005	<0.005
Total Uranium	mg/L	0.02	MAC	<0.00001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Total Vanadium	mg/L			0.0003	<0.005	<0.005	<0.005	<0.005	<0.005
Total Zinc	mg/L	5	AO	0.0156	0.0061	<0.005	<0.005	0.0065	<0.005
Total Zirconium	mg/L				<0.0005	<0.0005	<0.0001	<0.0001	<0.0001
Total Calcium	mg/L			34.2	33.1	31.8	37.1	32.5	34.7
Total Magnesium	mg/L			13.1	12.7	12.9	14.4	13.8	13.2
Total Potassium	mg/L			2.6	2.42	2.39	2.54	2.56	2.41
Total Sodium	mg/L	200	AO	12	10.7	9.45	10	9.79	9.72
Total Sulphur	mg/L				5.6	7.2	8.5	6.8	7

CDWG=Canadian Drinking Water Guidelines

MAC=Maximum Acceptable Concentration

OG= Operational Guidance Value

AO= Asthetic Objective.



Red font indicates non-compliance with Canadian Drinking Water Guidelines

	Units	CDWG		November 4 2014	October 26 2015	October 18 2017	November 8 2018	October 10 2019	
Miscellaneous Inorganics									
Fluoride	mg/L	1.5	MAC	0.11	0.16	0.16	0.18	0.15	
Alkalinity (total as CaCO ₃)	mg/L			120	125	127	118	120	
Anions									
Dissolved Sulphate	mg/L	500	AO	<0.5	<0.50	<1.0	<1.0	<1.0	
Dissolved Chloride	mg/L	250	AO	5.7	7	7.4	7	6.9	
Nitrite	mg/L	1	MAC	<0.05	<0.0050	<0.0050	<0.0050	<0.005	
Miscellaneous									
Apparent Colour	Colour Unit			32	30	30	30	80	
Nutrients									
Total Ammonia	mg/L			1.5	1.6	1.5	1.5	1.3	
Physical Properties									
Conductivity	µS/cm			252	260	259	245	260	
pH	pH	7.0:10.5	AO	7.8	8.26	8.16	8.04	7.92	
TDS	mg/L	500	AO	166	166	146	140	140	
Turbidity	NTU			0.9	0.44	0.73	4.01	8.3	
Microbiological Parameters									
E.coli	MPN/100mL	<1	MAC	<1.0	<1.0	<1.0	<1.0	0	
Total Coliforms	MPN/100mL	<1	MAC	<1.0	<1.0	<1.0	<1.0	0	
Calculated Parameters									
Total Hardness (CaCO ₃)	mg/L			83	80.2	81.2	75.4	77.9	
Nitrate	mg/L	10	MAC	<0.05	<0.020	<0.020	<0.020	<0.02	
Elements									
Total Mercury	mg/L	0.001	MAC	<0.00001	<0.00001	<0.00001	<0.000002	77.9	
Total Metals									
Total Aluminum	mg/L	0.1	OG	0.007	<0.003	0.0045	0.0041	0.0068	
Total Antimony	mg/L	0.006	MAC	<0.0001	<0.0005	<0.0005	<0.0005	0.00058	
Total Arsenic	mg/L	0.01	MAC	0.00037	0.00031	0.00039	0.00027	0.00043	
Total Barium	mg/L	1	MAC	0.0063	0.0055	0.0059	0.0076	0.0153	
Total Beryllium	mg/L			<0.00005	<0.0001	<0.0001	<0.0001	<0.0001	
Total Bismuth	mg/L			<0.0001	<0.001	<0.001	<0.001	<0.001	
Total Boron	mg/L	5	MAC	0.057	0.064	0.062	0.057	0.061	
Total Cadmium	mg/L	0.005	MAC	<0.00001	<0.00001	<0.00001	<0.00001	<0.00001	
Total Chromium	mg/L	0.05	MAC	<0.0005	<0.001	<0.001	<0.001	0.0012	
Total Cobalt	mg/L			<0.0001	<0.0005	<0.0002	<0.0002	<0.0002	
Total Copper	mg/L	1	AO	1.71	0.00247	0.00142	0.00744	0.0999	
Total Iron	mg/L	0.3	AO	0.674	0.683	0.725	1.74	2.87	
Total Lead	mg/L	0.01	MAC	0.0001	<0.0002	<0.0002	0.0122	0.238	
Total Manganese	mg/L	0.05	AO	0.18	0.177	0.181	0.206	0.246	
Total Molybdenum	mg/L			0.00073	<0.001	<0.001	0.001	0.0012	
Total Nickel	mg/L			<0.0002	<0.001	<0.001	<0.001	0.0021	
Total Selenium	mg/L	0.05	MAC	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	
Total Silicon	mg/L			18.4	20.5	19.1	12.3	11.1	
Total Silver	mg/L			<0.00005	<0.00002	<0.00002	<0.00002	0.00003	
Total Strontium	mg/L			0.0707	0.0656	0.0700	0.0723	0.0703	
Total Thallium	mg/L			<0.00001	<0.00005	<0.00001	<0.00001	<0.00001	
Total Tin	mg/L			0.0004	<0.005	<0.005	<0.005	0.0062	
Total Titanium	mg/L			0.001	<0.005	<0.005	<0.005	<0.005	
Total Uranium	mg/L	0.02	MAC	<0.00001	<0.0001	<0.0001	<0.0001	<0.0001	
Total Vanadium	mg/L			0.0011	<0.005	<0.005	<0.005	<0.005	
Total Zinc	mg/L	5	AO	0.0191	0.0173	0.0265	0.766	2.91	
Total Zirconium	mg/L				<0.0005	<0.0001	<0.0001	<0.0001	
Total Calcium	mg/L			20.2	19.5	19	18	18.4	
Total Magnesium	mg/L			7.87	7.67	8.17	7.41	7.75	
Total Potassium	mg/L			2.7	2.61	2.67	2.52	2.52	
Total Sodium	mg/L	200	AO	22.1	23.7	22.5	20.1	21	
Total Sulphur	mg/L				<3.0	<3.0	<3.0	<3	

CDWG=Canadian Drinking Water Guidelines
 OG= Operational Guidance Value

 MAC=Maximum Acceptable Concentration
 AO= Asthetic Objective.


Red font indicates non-compliance with Canadian Drinking Water Guidelines

	Units	CDWG		November 4 2014	October 26 2015	October 27 2016	October 18 2017	November 8 2018	October 10 2019
Miscellaneous Inorganics									
Fluoride	mg/L	1.5	MAC	0.09	0.15	0.14	0.14	0.17	0.14
Alkalinity (total as CaCO ₃)	mg/L			110	106	105	105	105	100
Anions									
Dissolved Sulphate	mg/L	500	AO	<0.5	<0.50	<0.50	<1.0	<1.0	<1.0
Dissolved Chloride	mg/L	250	AO	4.6	4.5	4.1	4.5	4.4	4.8
Nitrite	mg/L	1	MAC	0.12	<0.0050	<0.0050	<0.0050	<0.0050	<0.005
Miscellaneous									
Apparent Colour	Colour Unit			30	30	30	30	15	20
Nutrients									
Total Ammonia	mg/L			1.04	1.2	1.4	1	1.1	1.2
Physical Properties									
Conductivity	µS/cm			217	216	217	213	209	210
pH	pH	7.0:10.5	AO	7.8	8.24	8.1	8.08	8.09	7.91
TDS	mg/L	500	AO	126	136	140	122	124	140
Turbidity	NTU			1.2	0.62	0.83	0.55	0.54	0.67
Microbiological Parameters									
E.coli	MPN/100mL	<1	MAC	<1.0	<1.0	<1.0	<1.0	<1.0	0
Total Coliforms	MPN/100mL	<1	MAC	<1.0	<1.0	<1.0	<1.0	<1.0	0
Calculated Parameters									
Total Hardness (CaCO ₃)	mg/L			78	85.5	72.3	75.8	75.1	70.7
Nitrate	mg/L	10	MAC	<0.05	<0.020	<0.020	<0.020	<0.020	<0.02
Elements									
Total Mercury	mg/L	0.001	MAC	<0.00001	<0.00001	<0.00001	<0.00001	<0.000002	<0.000002
Total Metals									
Total Aluminum	mg/L	0.1	OG	<0.005	<0.003	<0.003	<0.003	0.0138	<0.003
Total Antimony	mg/L	0.006	MAC	<0.0001	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005
Total Arsenic	mg/L	0.01	MAC	0.00121	0.00139	0.00118	0.0014	0.00116	0.00113
Total Barium	mg/L	1	MAC	0.0048	0.0055	0.0044	0.0046	0.0041	0.0041
Total Beryllium	mg/L			<0.00005	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Total Bismuth	mg/L			<0.0001	<0.001	<0.001	<0.001	<0.001	<0.001
Total Boron	mg/L	5	MAC	0.032	<0.050	<0.050	<0.050	<0.050	<0.05
Total Cadmium	mg/L	0.005	MAC	<0.00001	<0.00001	<0.00001	<0.00001	<0.00001	<0.00001
Total Chromium	mg/L	0.05	MAC	0.0006	<0.001	<0.001	<0.001	<0.001	0.0012
Total Cobalt	mg/L			<0.0001	<0.0005	<0.0005	<0.0002	<0.0002	<0.0002
Total Copper	mg/L	1	AO	0.0024	0.00182	0.00117	0.00073	0.00206	0.00099
Total Iron	mg/L	0.3	AO	0.812	0.873	0.817	0.814	0.842	0.806
Total Lead	mg/L	0.01	MAC	0.0005	0.00089	0.00044	0.00055	0.00058	<0.0002
Total Manganese	mg/L	0.05	AO	0.162	0.182	0.157	0.161	0.161	0.167
Total Molybdenum	mg/L			0.00092	<0.001	<0.001	<0.001	0.001	<0.001
Total Nickel	mg/L			0.0003	<0.001	<0.001	<0.001	<0.001	<0.001
Total Selenium	mg/L	0.05	MAC	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Total Silicon	mg/L			17	20.6	16.7	16.9	16.7	16.1
Total Silver	mg/L			<0.00005	<0.00002	<0.00002	<0.00002	<0.00002	<0.00002
Total Strontium	mg/L			0.0571	0.0654	0.0553	0.0576	0.0547	0.0514
Total Thallium	mg/L			<0.00001	<0.00005	<0.00005	<0.00001	<0.00001	<0.00001
Total Tin	mg/L			0.0006	<0.005	<0.005	<0.005	<0.005	<0.005
Total Titanium	mg/L			0.0008	<0.005	<0.005	<0.005	<0.005	<0.005
Total Uranium	mg/L	0.02	MAC	<0.00001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Total Vanadium	mg/L			0.0013	<0.005	<0.005	<0.005	<0.005	<0.005
Total Zinc	mg/L	5	AO	0.0243	0.0262	0.0387	0.0169	0.0242	0.0179
Total Zirconium	mg/L				<0.0005	<0.0005	0.00012	0.00015	0.00012
Total Calcium	mg/L			18.8	20	16.8	16.9	17.3	16.4
Total Magnesium	mg/L			7.5	8.63	7.35	8.14	7.74	7.19
Total Potassium	mg/L			2	2.29	1.86	2.06	2.01	1.91
Total Sodium	mg/L	200	AO	17	18	13.7	15.6	15.2	14.3
Total Sulphur	mg/L				<3.0	<3.0	<3.0	<3.0	<3.0

CDWG=Canadian Drinking Water Guidelines
OG= Operational Guidance Value

MAC=Maximum Acceptable Concentration
AO= Asthetic Objective.



Red font indicates non-compliance with Canadian Drinking Water Guidelines

	Units	CDWG		November 4 2014	October 26 2015	October 27 2016	October 18 2017	November 8 2018	October 10 2019
Miscellaneous Inorganics									
Fluoride	mg/L	1.5	MAC	0.09	0.1	0.1	0.1	0.11	0.094
Alkalinity (total as CaCO ₃)	mg/L			140	142	150	149	149	150
Anions									
Dissolved Sulphate	mg/L	500	AO	32.4	24.7	26.7	30.3	31.2	23
Dissolved Chloride	mg/L	250	AO	4.5	5.6	5.4	6.4	7.1	9.4
Nitrite	mg/L	1	MAC	0.17	<0.0050	<0.0050	<0.0050	<0.0050	<0.005
Miscellaneous									
Apparent Colour	Colour Unit			6	10	10	10	<5.0	5
Nutrients									
Total Ammonia	mg/L			0.26	0.29	0.36	0.28	0.28	0.34
Physical Properties									
Conductivity	µS/cm			339	332	348	351	349	350
pH	pH	7.0:10.5	AO	8.2	8.35	8.33	8.24	8.25	8.11
TDS	mg/L	500	AO	210	202	214	196	194	210
Turbidity	NTU			<0.5	0.16	0.23	0.25	0.28	0.34
Microbiological Parameters									
E.coli	MPN/100mL	<1	MAC	<1.0	<1.0	<1.0	<1.0	<1.0	0
Total Coliforms	MPN/100mL	<1	MAC	<1.0	<1.0	<1.0	<1.0	<1.0	0
Calculated Parameters									
Total Hardness (CaCO ₃)	mg/L			160	169	154	165	170	164
Nitrate	mg/L	10	MAC	<0.05	<0.020	<0.020	<0.020	<0.020	<0.02
Elements									
Total Mercury	mg/L	0.001	MAC	<0.00001	<0.00001	<0.00001	<0.00001	<0.000002	<0.000002
Total Metals									
Total Aluminum	mg/L	0.1	OG	<0.005	<0.003	<0.003	<0.003	<0.003	<0.003
Total Antimony	mg/L	0.006	MAC	<0.0001	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005
Total Arsenic	mg/L	0.01	MAC	0.00011	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Total Barium	mg/L	1	MAC	0.016	0.0187	0.016	0.0152	0.0165	0.165
Total Beryllium	mg/L			<0.00005	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Total Bismuth	mg/L			<0.0001	<0.001	<0.001	<0.001	<0.001	<0.001
Total Boron	mg/L	5	MAC	0.018	<0.05	<0.050	<0.050	<0.050	<0.05
Total Cadmium	mg/L	0.005	MAC	<0.00001	<0.00001	<0.00001	<0.00001	<0.00001	<0.00001
Total Chromium	mg/L	0.05	MAC	<0.0005	<0.001	<0.001	<0.001	<0.001	<0.001
Total Cobalt	mg/L			<0.0001	<0.0005	<0.0005	<0.0002	<0.0002	<0.0002
Total Copper	mg/L	1	AO	0.0003	0.00046	0.00025	<0.0002	<0.0002	<0.0002
Total Iron	mg/L	0.3	AO	0.121	0.125	0.123	0.127	0.13	0.149
Total Lead	mg/L	0.01	MAC	<0.0001	<0.0002	<0.0002	<0.0002	<0.0002	<0.0002
Total Manganese	mg/L	0.05	AO	0.143	0.148	0.139	0.144	0.152	0.147
Total Molybdenum	mg/L			0.00057	<0.001	<0.001	<0.001	<0.001	<0.001
Total Nickel	mg/L			0.0008	<0.001	<0.001	<0.001	<0.001	<0.001
Total Selenium	mg/L	0.05	MAC	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Total Silicon	mg/L			11.6	13.5	11.7	12	11.4	11.8
Total Silver	mg/L			<0.00005	<0.00002	<0.00002	<0.00002	<0.00002	<0.00002
Total Strontium	mg/L			0.15	0.169	0.147	0.131	0.162	0.152
Total Thallium	mg/L			<0.00001	<0.00005	<0.00005	<0.00001	<0.00001	<0.00001
Total Tin	mg/L			0.0008	<0.005	<0.005	<0.005	<0.005	<0.005
Total Titanium	mg/L			<0.0005	<0.005	<0.005	<0.005	<0.005	<0.005
Total Uranium	mg/L	0.02	MAC	<0.00001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Total Vanadium	mg/L			0.0002	<0.005	<0.005	<0.005	<0.005	<0.005
Total Zinc	mg/L	5	AO	0.0049	<0.005	<0.005	<0.005	0.0224	0.0309
Total Zirconium	mg/L				<0.0005	<0.0005	<0.0001	<0.0001	<0.0001
Total Calcium	mg/L			40.2	40.1	37.5	39.3	40.6	40.4
Total Magnesium	mg/L			14.8	16.8	14.7	16.2	16.7	15.3
Total Potassium	mg/L			2.5	2.66	2.34	2.59	2.6	2.37
Total Sodium	mg/L	200	AO	9.5	10.9	8.89	9.59	9.57	8.5
Total Sulphur	mg/L				8.7	8.7	10.2	10.5	8.1