



# Regional District of Nanaimo - Water Services Department

## San Pareil Water Analysis - 2024 Monthly Report

Date	Sample Location (Address)	BC Centre for Disease Control		RDN In-House Laboratory and Spectrophotometer								
		E. coli *	Total Coliform *	E.coli *	Total Coliform *	Temp. (°C)	pH	Free Chlorine Residual (mg/L)	Total Dissolved Solids (mg/L)	Salinity (%)	Conductivity (µS/cm)	Turbidity (NTU)
3-Jan-24	793 San Malo	0	0	0	0	9	6.77	0.62	35.7	0.03	75.8	0.14
10-Jan-24	995 Sabine	0	0	0	0	9	6.50	0.74	34.9	0.03	74.1	0.29
31-Jan-24	962 Ballenas	0	0	0	0	9	6.70	0.69	34.2	0.03	75.0	0.28
31-Jan-24	1090 Plummer	0	0	0	0	9	6.80	0.66	35.6	0.03	74.9	0.33
CDN Drinking Water Guidelines		<1	<1	<1	<1	n/a	7.0-10.5	n/a	500	n/a	n/a	<1

### Legend:

\* Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Green font indicates a value flagged for operational consideration

Red font indicates non-compliance with the Maximum Acceptable Concentration (MAC) in the CDWG

### Comments:

A full potability scan, including metals and minerals, is completed once per year at an external lab.

Notes below about pH (2015) from [https://www.canada.ca/en/health-canada/services/environmental-workplace-health/reports-publications/water-quality/guidelines-canadian-drinking-water-quality-summary-table.html#\\_ftn1](https://www.canada.ca/en/health-canada/services/environmental-workplace-health/reports-publications/water-quality/guidelines-canadian-drinking-water-quality-summary-table.html#_ftn1)

Type	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Comments
Treatment-related	pH (2015)	None	7.0-10.5	Not applicable	Not applicable	The control of pH is important to maximize treatment effectiveness, control corrosion and reduce leaching from distribution system and plumbing components.



# Regional District of Nanaimo - Water Services Department

## San Pareil Water Analysis - 2024 Monthly Report

Date	Sample Location (Address)	BC Centre for Disease Control		RDN In-House Laboratory and Spectrophotometer								
		E. coli *	Total Coliform *	E.coli *	Total Coliform *	Temp. (°C)	pH	Free Chlorine Residual (mg/L)	Total Dissolved Solids (mg/L)	Salinity (%)	Conductivity (µS/cm)	Turbidity (NTU)
6-Feb-24	793 San Malo	0	0	0	0	8	6.83	0.45	36.3	0.04	77.0	0.24
14-Feb-24	962 Ballenas	0	0	0	0	9	6.96	0.19	42.5	0.04	90.0	0.24
21-Feb-24	995 Sabine	0	0	0	0	8	6.60	0.55	36.6	0.04	77.7	0.27
28-Feb-24	995 Sabine	0	0	0	0	8	6.97	0.72	36.1	0.04	76.9	0.16
CDN Drinking Water Guidelines		<1	<1	<1	<1	n/a	7.0-10.5	n/a	500	n/a	n/a	<1

**Legend:**

\* Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Green font indicates a value flagged for operational consideration

Red font indicates non-compliance with the Maximum Acceptable Concentration (MAC) in the CDWG

**Comments:**

A full potability scan, including metals and minerals, is completed once per year at an external lab.

Notes below about pH (2015) from [https://www.canada.ca/en/health-canada/services/environmental-workplace-health/reports-publications/water-quality/guidelines-canadian-drinking-water-quality-summary-table.html#\\_ftn1](https://www.canada.ca/en/health-canada/services/environmental-workplace-health/reports-publications/water-quality/guidelines-canadian-drinking-water-quality-summary-table.html#_ftn1)

Type	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Comments
Treatment-related	pH (2015)	None	7.0-10.5	Not applicable	Not applicable	The control of pH is important to maximize treatment effectiveness, control corrosion and reduce leaching from distribution system and plumbing components.



# Regional District of Nanaimo - Water Services Department

## San Pareil Water Analysis - 2024 Monthly Report

Date	Sample Location (Address)	BC Centre for Disease Control		RDN In-House Laboratory and Spectrophotometer								
		E. coli *	Total Coliform *	E.coli *	Total Coliform *	Temp. (°C)	pH	Free Chlorine Residual (mg/L)	Total Dissolved Solids (mg/L)	Salinity (%)	Conductivity (µS/cm)	Turbidity (NTU)
4-Mar-24	793 San Malo	0	0	0	0	8	6.71	0.46	35.1	0.03	74.7	0.14
19-Mar-24	1090 Plummer	0	0	0	0	9	7.20	0.47	32.4	0.03	68.8	0.29
19-Mar-24	793 San Malo	0	0	0	0	9		0.45				0.31
27-Mar-24	962 Ballenas	0	0	0	0	9	7.34	0.29	34.9	0.03	74.0	0.45
CDN Drinking Water Guidelines		<1	<1	<1	<1	n/a	7.0-10.5	n/a	500	n/a	n/a	<1

**Legend:**

\* Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Green font indicates a value flagged for operational consideration

Red font indicates non-compliance with the Maximum Acceptable Concentration (MAC) in the CDWG

**Comments:**

A full potability scan, including metals and minerals, is completed once per year at an external lab.

Notes below about pH (2015) from [https://www.canada.ca/en/health-canada/services/environmental-workplace-health/reports-publications/water-quality/guidelines-canadian-drinking-water-quality-summary-table.html#\\_ftn1](https://www.canada.ca/en/health-canada/services/environmental-workplace-health/reports-publications/water-quality/guidelines-canadian-drinking-water-quality-summary-table.html#_ftn1)

Type	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Comments
Treatment-related	pH (2015)	None	7.0-10.5	Not applicable	Not applicable	The control of pH is important to maximize treatment effectiveness, control corrosion and reduce leaching from distribution system and plumbing components.



# Regional District of Nanaimo - Water Services Department

## San Pareil Water Analysis - 2024 Monthly Report

Date	Sample Location (Address)	BC Centre for Disease Control		RDN In-House Laboratory and Spectrophotometer								
		E. coli *	Total Coliform *	E.coli *	Total Coliform *	Temp. (°C)	pH	Free Chlorine Residual (mg/L)	Total Dissolved Solids (mg/L)	Salinity (%)	Conductivity (µS/cm)	Turbidity (NTU)
10-Apr-24	793 San Malo	0	0	0	0	10	7.00	0.63	32.0	0.03	68.1	0.23
17-Apr-24	962 Ballenas	0	0	0	0	10	6.80	0.54	32.2	0.03	68.3	0.25
23-Apr-24	1090 Plummer			0	0	11	6.77	0.76	31.9	0.03	67.9	0.20
CDN Drinking Water Guidelines		<1	<1	<1	<1	n/a	7.0-10.5	n/a	500	n/a	n/a	<1

**Legend:**

\* Coliforms are measured in colony forming units (CFU) per 100 millilitres of water (CFU/100mL)

Green font indicates a value flagged for operational consideration

Red font indicates non-compliance with the Maximum Acceptable Concentration (MAC) in the CDWG

**Comments:**

A full potability scan, including metals and minerals, is completed once per year at an external lab.

Notes below about pH (2015) from [https://www.canada.ca/en/health-canada/services/environmental-workplace-health/reports-publications/water-quality/guidelines-canadian-drinking-water-quality-summary-table.html#\\_ftn1](https://www.canada.ca/en/health-canada/services/environmental-workplace-health/reports-publications/water-quality/guidelines-canadian-drinking-water-quality-summary-table.html#_ftn1)

Type	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Comments
Treatment-related	pH (2015)	None	7.0-10.5	Not applicable	Not applicable	The control of pH is important to maximize treatment effectiveness, control corrosion and reduce leaching from distribution system and plumbing components.